



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
Mailroom
30 Victoria street
Gatineau, Quebec, J8X 0B3

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
Mailroom
30 Victoria street
Gatineau, Quebec, J8X 0B3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
Salleducourier
30 rue Victoria
Gatineau (Quebec) J8X 0B3

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
Salleducourier
30 rue Victoria
Gatineau (Quebec) J8X 0B3

Title: Structural Rehabilitation of Four Structures Terra Nova National Park		
Solicitation No.: / N° de l'invitation : 5P201-18-0008/A	Amendment No.: / N° de modification de l'invitation : 002	Date: April 6, 2018 Date : 6 avril 2018
GETS Reference No.: / N° de référence de SEAG : PW-18-00820494		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: April 6, 2018	Time Zone: Eastern Daylight Time (EDT)
À : 14h00	Le : 6 avril 2018	Fuseau horaire : Heure avancée de l'est (HAE)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : 819-420-9868	Fax No.: / N° de télécopieur :	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 002

This amendment is being raised to respond to questions submitted in response to solicitation 5P201-18-0008/A:

A. QUESTIONS AND ANSWERS

Q3. Can you confirm the total Concrete Patch Repair quantity (Type 1 + Type 2) is correct at 90m²? With the quantities listed for Big Brook Bridge and calculating the repairs mapped/shown for the Bread Cove Brook and Salton's Brook culverts we are coming up with significantly less of a quantity.

A3. The actual measured quantity according to our calculations and measurements is 73 square metres for Type 1 and Type 2. The tendered quantity is for 90 square metres. This is higher due to the likelihood of the patching requirements being larger than measured due to the expected larger areas once chipping starts etc.

Q4. We interpret requirements as follows - all Type 1 and Type 2 patch repairs are to be completed with the Emaco S66-CI repair mortar with the exception of the larger repair at the pier bases on big brook for which the contractor has the option of using ready mix concrete – can you please confirm this understanding is correct?

A4. The interpretation is correct.

All other terms and conditions remain the same.