



Parks Canada
Parcs Canada



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: 1-866-246-6893

AMENDMENT / MODIFICATION

001

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Wasagamung Main Parking Lot Upgrade – Riding Mountain National Park		
Solicitation No. - No. de l'invitation 5P420-18-0021/A		Date: April 13, 2018
GETS Reference No. – No de reference de SEAG PW-18-00823590		Amendment No. - N° de la modif. 1
Solicitation Closes:		
at – à 02:00 PM	on – le May 9, 2018	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Rebecca Chen		
Telephone No. - No de téléphone (403) 292-8509		Fax No. – No de FAX: 1-866-246-6893
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 01

This amendment is being raised to distribute questions and answers.

A) QUESTIONS AND ANSWERS

Q1 For the crushed sub-base materials you reference limestone in the ITT but in the specifications there is no reference to the material needing to originate from limestone. Would it be acceptable to use a granular material produced to the gradations and specs outlined in your specification document?

A1 Yes, a non-limestone granular is acceptable provided the Manitoba Infrastructure standards and specifications are followed.

All other terms and conditions remain unchanged.