

Part 1 General

1.1 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with all Division 1 sections.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for all fixtures and accessories.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Saskatchewan, Canada.
 - .2 Indicate on drawings:
 - .1 Mounting arrangements.
 - .2 Operating and maintenance clearances.
 - .3 Shop drawings and product data accompanied by:
 - .1 Detailed drawings of bases, supports, and anchor bolts.
 - .2 Manufacturer to certify current model production.
 - .3 Certification of compliance to applicable codes.
 - .4 In addition to transmittal letter referred to in Section 01 33 00- Submittal Procedures: use MCAC "Shop Drawing Submittal Title Sheet". Identify section and paragraph number.
- .4 Sustainable Design Submittals:
 - .1 Construction Waste Management:
 - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.

1.2 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with all Division 1 sections.
- .2 Operation and Maintenance Data: submit operation and maintenance data for all plumbing work.
 - .1 Operation and maintenance manual approved by, and final copies deposited with, Consultant before final inspection.
 - .2 Operation data to include:
 - .1 Control schematics for systems including environmental controls.
 - .2 Description of systems and their controls.
 - .3 Description of operation of systems at various loads together with reset schedules and seasonal variances.
 - .4 Operation instruction for systems and component.
 - .5 Description of actions to be taken in event of equipment failure.
 - .6 Valves schedule and flow diagram.

- .7 Colour coding chart.
- .3 Maintenance data to include:
 - .1 Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
 - .2 Data to include schedules of tasks, frequency, tools required and task time.
- .4 Performance data to include:
 - .1 Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
 - .2 Equipment performance verification test results.
 - .3 Special performance data as specified.
 - .4 Testing, adjusting and balancing reports as specified in Section 23 05 93- Testing, Adjusting and Balancing for HVAC.
- .5 Approvals:
 - .1 Submit two (2) copies of draft Operation and Maintenance Manual to Consultant for approval. Submission of individual data will not be accepted unless directed by Consultant.
 - .2 Make changes as required and re-submit as directed by Consultant.
- .6 Additional data:
 - .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
- .7 Site records:
 - .1 Consultant will provide one (1) set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
 - .2 Transfer information to reproducibles, revising reproducibles to show work as actually installed.
 - .3 Use different colour waterproof ink for each service.
 - .4 Make available for reference purposes and inspection.
- .8 As-built drawings:
 - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
 - .2 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
 - .3 Submit to Consultant for approval and make corrections as directed.
 - .4 Perform testing, adjusting and balancing for HVAC using as-built drawings.
 - .5 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.

- .9 Submit copies of as-built drawings for inclusion in final TAB report.

1.3 MAINTENANCE MATERIAL SUBMITTALS

- .1 Submit in accordance with Section 01 78 00- Closeout Submittals.
- .2 Furnish spare parts as follows:
 - .1 One set of packing for each pump.
 - .2 One casing joint gasket for each size pump.
 - .3 One glass for each gauge glass.
- .3 Provide one set of special tools required to service equipment as recommended by manufacturers.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00- Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Replace defective or damaged materials with new.
- .4 Develop Waste Reduction work plan related to Work of this Section.

Part 2 Products

2.1 NOT USED

- .1 Not used.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of work site and all previously installed work under other Sections or Contracts are acceptable for this contract.
 - .1 Inform consultant of unacceptable conditions immediately upon discovery.
 - .2 Proceed with installation only after unacceptable conditions have been remedied.

3.2 PAINTING REPAIRS AND RESTORATION

- .1 Do painting in accordance with Section 09 91 23- Interior Painting.
- .2 Prime and touch up marred finished paintwork to match original.
- .3 Restore to new condition, finishes which have been damaged.

3.3 CONNECTIONS TO EXISTING SYSTEM

- .1 Where connecting to existing water/sanitary provide new tee of equal material to existing line. Cut minimum amount of existing material as required to fit new tee. Where similar material not available or no longer in common use dielectric couplings.

3.4 SYSTEM CLEANING

- .1 Clean interior and exterior of all systems including strainers. Vacuum interior of ductwork and air handling units.

3.5 FIELD QUALITY CONTROL

- .1 Field Services:
 - .1 Provide review of product use recommendations and product installation in accordance with manufacturer's instructions.

3.6 DEMONSTRATION

- .1 Consultant will use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.
- .2 Trial usage to apply to following equipment and systems:
 - .1 All fixtures
- .3 Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance.
- .4 Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.

3.7 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11- Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11- Cleaning.

3.8 PROTECTION

- .1 Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 22 05 00 – Common Work Results for Plumbing.

1.2 REFERENCE STANDARDS

- .1 CSA Group
 - .1 CSA B242-05, Groove and Shoulder Type Mechanical Pipe Couplings.
- .2 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC S101-07, Fire Endurance Tests of Buildings Construction and Materials.
 - .2 CAN/ULC S102.2-10, Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings and Miscellaneous Materials and Assemblies.
 - .3 CAN/ULC S115-11, Standard Method of Fire Tests of Firestop.
- .3 National Sanitation foundation (NSF)
 - .1 NSF/ANSI 61-13, Drinking Water System Components-Health Effects.
 - .2 NSF 372-11, Drinking Water System Components - Lead Content.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .5 National Research Council (NRC)
 - .1 National Plumbing Code of Canada (NPC) 2015.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data
 - .1 Provide manufacturer's printed product literature and datasheets for insulation and adhesives, and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Closeout Submittals:
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00- Closeout Submittals.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Handle and dispose of all materials in accordance with Regional and Municipal regulations.

1.5 SUSTAINABLE REQUIREMENTS

- .1 Construction:

- .1 Construction requirements detailed in Section 01 47 15- Sustainable Requirements: Construction form integral part of this project including materials and products of this Section. Sustainable construction requirements include:
 - .1 Specific construction requirements for project.
 - .2 Administrative, temporary and procedural requirements for the use of materials and methods of construction products.

1.6 PIPING

- .1 Domestic hot, cold and recirculation systems, within building.
 - .1 Above ground:
 - .1 Copper tube, hard drawn, type L to ASTM B88M.
 - .2 PEX Piping to CSA B137.5 where indicated on drawing.

1.7 FITTINGS

- .1 Bronze pipe flanges and flanged fittings, Class 150: to ANSI/ASME B16.24.
- .2 Cast bronze threaded fittings, Class 250: to ANSI/ASME B16.15.
- .3 Cast copper, solder type: to ANSI/ASME B16.18.
- .4 Wrought copper and copper alloy, solder type: to ANSI/ASME B16.22.

1.8 JOINTS

- .1 Rubber gaskets, 1.6 mm thick: to AWWA C111.
- .2 Bolts, nuts, hex head and washers: to ASTM A307, heavy series.
- .3 Solder: tin copper alloy 95/5.
- .4 Teflon tape: for threaded joints.
- .5 Grooved couplings: designed with angle bolt pads to provide rigid joint, complete with EPDM gasket.
- .6 Dielectric connections between dissimilar metals: dielectric fitting, complete with thermoplastic liner.

1.9 BALL VALVES

- .1 NPS 2 and under, screwed:
 - .1 Class 150.
 - .2 Bronze body, stainless steel, or chrome plated brass ball, PTFE adjustable packing, brass gland and PTFE seat, steel lever handle as specified Section 23 05 23.01- Valves - Bronze.
- .2 NPS 2 and under, soldered:
 - .1 To ANSI/ASME B16.18, Class 150.
 - .2 Bronze body, stainless steel or chrome plated brass ball, PTFE adjustable packing, brass gland and PTFE seat, steel lever handle, with NPT to copper adaptors as specified Section 23 05 23.01- Valves - Bronze.

- .3 NPS 2 and under, mechanical:
 - .1 To CSA B137.5 and ASTM F1960.
 - .2 Lead free brass body.

Part 2 Execution

2.1 PREPARATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

2.2 INSTALLATION

- .1 Install in accordance with NPC, and all local regulations.
- .2 Assemble piping using fittings manufactured to ANSI and Standard Council of Canada (SCC) standards.
- .3 Install CWS piping below and away from HWS and HWC and other hot piping so as to maintain temperature of cold water as low as possible.
- .4 Connect to fixtures and equipment in accordance with manufacturer's written instructions unless otherwise indicated.
- .5 Valves
 - .1 Isolate equipment, fixtures and branches with gate or ball valves.
 - .2 Balance recirculation system using lockshield globe valves. Mark settings and record on as-built drawings on completion.

2.3 FIELD QUALITY CONTROL

- .1 Pressure Tests
 - .1 Test pressure: greater of 1 times maximum system operating pressure or 860 kPa.

2.4 FLUSHING

- .1 Flush entire system for 8 h. Ensure outlets flushed for 2 hours. Let stand for 24 hours, then draw one (1) sample off longest run. Submit to testing laboratory to verify that system is clean copper to Federal and Provincial potable water guidelines. Let system flush for additional 2 hours, then draw off another sample for testing.

2.5 PRE-START-UP INSPECTIONS

- .1 Systems to be complete, prior to flushing, testing and start-up.
- .2 Verify that system can be completely drained.
- .3 Ensure that pressure booster systems are operating properly.
- .4 Ensure that air chambers, expansion compensators are installed properly.

2.6 DISINFECTION

- .1 Flush out, disinfect and rinse system to requirements of authority having jurisdiction.

2.7 START-UP

- .1 Timing: start up after:
 - .1 Pressure tests have been completed.
 - .2 Disinfection procedures have been completed.
 - .3 Certificate of static completion has been issued.
 - .4 Water treatment systems operational.
- .2 Provide continuous supervision during start-up.
- .3 Start-up procedures:
 - .1 Establish circulation and ensure that air is eliminated.
 - .2 Check pressurization to ensure proper operation and to prevent water hammer, flashing and/or cavitation.
 - .3 Monitor piping HWS and HWC piping systems for freedom of movement, pipe expansion as designed.
 - .4 Check control, limit, safety devices for normal and safe operation.
- .4 Rectify start-up deficiencies.

2.8 PERFORMANCE VERIFICATION

- .1 Scheduling:
 - .1 Verify system performance after pressure and leakage tests and disinfection are completed, and Certificate of Completion has been issued by authority having jurisdiction.
- .2 Procedures:
 - .1 Verify that flow rate and pressure meet Design Criteria.
 - .2 TAB HWC in accordance with Section 23 05 93- Testing, Adjusting and Balancing for HVAC.
 - .3 Adjust pressure regulating valves while withdrawal is maximum and inlet pressure is minimum.
 - .4 Verify compliance with safety and health requirements.
 - .5 Check for proper operation of water hammer arrestors. If water hammer occurs, replace water hammer arrestor or re-charge air chambers.
 - .6 Confirm water quality consistent with supply standards, and ensure no residuals remain as result of flushing or cleaning.
- .3 Reports:
 - .1 In accordance with Section 01 91 13- General Commissioning (Cx) Requirements: Reports, using report forms as specified in Section 01 91 13- General Commissioning (Cx) Requirements: Report Forms and Schematics.
 - .2 Include certificate of water flow and pressure tests conducted on incoming water service, demonstrating adequacy of flow and pressure.

2.9 CLEANING

- .1 Clean in accordance with Section 01 74 11- Cleaning.
- .2 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21- Construction/Demolition Waste Management and Disposal.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 22 05 00 – Common Work Results for Plumbing.

1.2 REFERENCE STANDARDS

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA-Series B1800-06, Thermoplastic Nonpressure Pipe Compendium - B1800 Series.
- .2 National Research Council Canada (NRC)
 - .1 National Plumbing Code of Canada 2015(NPC).

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for piping and adhesives, and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Provide 2 (two) copies WHMIS MSDS - Material Safety Data Sheets.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 01 61 00- Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Store at temperatures and conditions recommended by manufacturer.

Part 2 Products

2.1 MATERIAL

- .1 Sustainable Requirements: materials and products in accordance with Section 01 47 15 - Sustainable Requirements: Construction.
- .2 Adhesives and Sealants: 07 92 00- Joint Sealants
 - .1 Maximum VOC limit 70 g/L.

2.2 PIPING AND FITTINGS

- .1 For above ground DWV piping to:
 - .1 CAN/CSA B1800.

- .2 For above ground DWV piping located in plenums (all ceiling spaces are considered plenum space) ensure pipe is XFR rated.

2.3 JOINTS

- .1 Solvent weld for PVC: to ASTM D2564.

Part 3 Execution

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 In accordance with Section 23 05 00- Common Work Requirements for Plumbing.
- .2 Install in accordance with local authority having jurisdiction, and the National Plumbing Code.

3.3 TESTING

- .1 Pressure test buried systems before backfilling.
- .2 Hydraulically test to verify grades and freedom from obstructions.

3.4 PERFORMANCE VERIFICATION

- .1 Cleanouts:
 - .1 Ensure accessible and that access doors are correctly located.
 - .2 Open, cover with linseed oil and re-seal.
 - .3 Verify cleanout rods can probe as far as the next cleanout, at least.
- .2 Test to ensure traps are fully and permanently primed.
- .3 Ensure fixtures are properly anchored, connected to system and effectively vented.
- .4 Affix applicable label (storm, sanitary, vent, pump discharge) c/w directional arrows every floor or 4.5 m (whichever is less).

3.5 CLEANING

- .1 Clean in accordance with Section 01 74 11- Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for recycling or reuse in accordance with Section 01 74 21- Construction/Demolition Waste Management and Disposal

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 22 05 00 – Common Work Results for Plumbing

1.2 REFERENCE STANDARDS

- .1 CSA International
 - .1 CSA-B64 Series-11, Backflow Preventers and Vacuum Breakers.
 - .2 CSA B79-08, Commercial and Residential Drains and Cleanouts.
 - .3 CAN/CSA-B356-10, Water Pressure Reducing Valves for Domestic Water Supply Systems.
- .2 National Research Council Canada (NRC)
 - .1 National Plumbing Code of Canada 2015 (NPC).

1.3 ADMINISTRATIVE REQUIREMENTS

- .1 Pre-installation Meetings:
 - .1 Convene pre-installation meeting one (1) week prior to beginning on-site installation work, with Consultant in accordance with Section 01 31 19- Project Meetings to:
 - .1 Verify project requirements.
 - .2 Review installation and substrate conditions.
 - .3 Co-ordination with other building construction subtrades.
 - .4 Review manufacturer's written installation instructions and warranty requirements.

1.4 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for plumbing products and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit two (2) copies of WHMIS MSDS in accordance with Section 01 35 29.06- Health and Safety Requirements. Indicate VOC's.
- .3 Shop Drawings:
 - .1 Submit drawings to be reviewed by professional engineer registered or licensed in Saskatchewan, Canada.
- .4 Instructions: submit manufacturer's installation instructions.
- .5 Manufacturers' Field Reports: manufacturers' field reports specified.
- .6 Sustainable Design Submittals:

- .1 Construction Waste Management:
 - .1 Submit project Waste Reduction Workplan highlighting recycling and salvage requirements.

1.5 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00- Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for plumbing specialties and accessories for incorporation into manual.
 - .1 Description of plumbing specialties and accessories, giving manufacturers name, type, model, year and capacity.
 - .2 Details of operation, servicing and maintenance.
 - .3 Recommended spare parts list.

1.6 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section with manufacturer's written instructions 01 61 00- Common Product Requirements.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect plumbing materials from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.

1.7 CLEANOUTS

- .1 Cleanout Plugs: heavy cast iron male ferrule with brass screws and threaded brass or bronze plug. Sealing-caulked lead seat or neoprene gasket.
- .2 Access Covers:
 - .1 Wall Access: face or wall type, round, polished nickel bronze, or stainless steel with cover with flush head securing screws, bevelled edge frame complete with anchoring lugs.
 - .2 Floor Access: round cast iron body and frame with adjustable secured nickel bronze top or cast box with anchor lugs and:
 - .1 Plugs: bolted bronze with neoprene gasket.
 - .2 Cover for Unfinished Concrete Floors: nickel bronze square, or round cast iron gasket, vandal-proof screws.
 - .3 Cover for Terrazzo Finish: polished nickel bronze or brass with recessed cover for filling with terrazzo, vandal-proof locking screws.
 - .4 Cover for Tile and Linoleum Floors: polished nickel bronze with recessed cover for linoleum or tile infill, complete with vandal-proof locking screws.

- .5 Cover for Carpeted Floors: polished nickel bronze with deep flange cover for carpet infill, complete with carpet retainer vandal-proof locking screws.

1.8 WATER HAMMER ARRESTORS

- .1 Copper or Stainless steel construction: to PDI-WH201.

1.9 STRAINERS

- .1 Y type with 20 mesh, bronze or stainless steel removable screen.
- .2 NPS 2 and under, bronze body, screwed ends, with brass cap.
- .3 NPS 2 1/2 and over, cast iron body, flanged ends, with bolted cap.

Part 2 Execution

2.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for plumbing specialties and accessories installation in accordance with manufacturer's written instructions.
 - .1 Visually inspection.
 - .2 Inform Consultant of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Consultant.

2.2 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.

2.3 INSTALLATION

- .1 Install in accordance with National Plumbing Code of Canada (NPC), local authority having jurisdiction, and all provincial and local regulations.
- .2 Install in accordance with manufacturer's instructions and as specified.

2.4 CLEANOUTS

- .1 Install cleanouts at base of soil and waste stacks, and rainwater leaders, at locations required code, and as indicated.
- .2 Bring cleanouts to wall or finished floor unless serviceable from below floor.

2.5 WATER HAMMER ARRESTORS

- .1 Install on branch supplies to fixtures or group of fixtures.

2.6 START-UP

- .1 General:
 - .1 In accordance with Section 01 91 13- General Commissioning (Cx) Requirements: General Requirements, supplemented as specified herein.
- .2 Timing: start-up only after:
 - .1 Pressure tests have been completed.
 - .2 Disinfection procedures have been completed.
 - .3 Certificate of static completion has been issued.
 - .4 Water treatment systems operational.
- .3 Provide continuous supervision during start-up.

2.7 TESTING AND ADJUSTING

- .1 General:
 - .1 Test and adjust plumbing specialties and accessories in accordance with Section 01 91 13- General Commissioning (Cx) Requirements: General Requirements, supplemented as specified.
- .2 Timing:
 - .1 After start-up deficiencies rectified.
 - .2 After certificate of completion has been issued by authority having jurisdiction.
- .3 Application tolerances:
 - .1 Pressure at fixtures: +/- 70 kPa.
 - .2 Flow rate at fixtures: +/- 20%.
- .4 Adjustments:
 - .1 Verify that flow rate and pressure meet design criteria.
 - .2 Make adjustments while flow rate or withdrawal is (1) maximum and (2) 25% of maximum and while pressure is (1) maximum and (2) minimum.
- .5 Floor drains:
 - .1 Verify operation of trap seal primer.
 - .2 Prime, using trap primer. Adjust flow rate to suit site conditions.
 - .3 Check operations of flushing features.
 - .4 Check security, accessibility, removability of strainer.
 - .5 Clean out baskets.
- .6 Access doors:
 - .1 Verify size and location relative to items to be accessed.
- .7 Cleanouts:
 - .1 Verify covers are gas-tight, secure, yet readily removable.
- .8 Water hammer arrestors:

- .1 Verify proper installation of correct type of water hammer arrester.

2.8 CLOSEOUT ACTIVITIES

- .1 Commissioning Reports: in accordance with Section 01 91 13- General Commissioning (Cx) Requirements: reports, supplemented as specified.

2.9 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11- Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11- Cleaning.
- .3 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21- Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

2.10 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by plumbing specialties and accessories installation.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 22 05 00 – Common Work Results for Plumbing

1.2 REFERENCE STANDARDS

- .1 CSA Group
 - .1 CAN/CSA-B45 Series-02(R2013), Plumbing Fixtures, (Consists of B45.0, B45.1, B45.2, B45.3, B45.4, B45.5, B45.6, B45.7, B45.8 and B45.9).
 - .2 CSA B125.3-12, Plumbing Fittings.
 - .3 CSA B651-12, Accessible Design for the Built Environment.
- .2 National Research Council Canada (NRC)
 - .1 National Building Code of Canada 2015 (NBC).

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for washroom fixtures and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Indicate fixtures and trim:
 - .1 Dimensions, construction details, roughing-in dimensions.
 - .2 Factory-set water consumption per flush at recommended pressure.
 - .3 (For water closets, urinals): minimum pressure required for flushing.
- .3 Sustainable Design Submittals:
 - .1 Construction Waste Management:
 - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.

1.4 CLOSEOUT SUBMITTALS

- .1 Include:
 - .1 Description of fixtures and trim, giving manufacturer's name, type, model, year, capacity.
 - .2 Details of operation, servicing, maintenance.
 - .3 List of recommended spare parts.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00- Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect materials from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan for Work of this Section.

Part 2 Products

2.1 SUSTAINABLE MATERIAL

- .1 Adhesives and sealants: maximum VOC limit 70g/L.

2.2 MANUFACTURED UNITS

- .1 Fixtures: manufacture in accordance with CAN/CSA-B45 series.
- .2 Trim, fittings: manufacture in accordance with CSA B125.3.
- .3 Exposed plumbing brass to be chrome plated.
- .4 Number, locations: as indicated.
- .5 Fixtures in any one location to be product of one manufacturer and of same type.
- .6 Trim in any one location to be product of one manufacturer and of same type.
- .7 Water closets:
 - .1 WC-1: Floor mounted, flush tank, barrier free
 - .2 Fixture: White vitreous china with elongated rim, 432 mm high, high efficiency flush bowl, siphon jet action with fully glazed 50 mm ball pass trapway, 4.8 L/F. 300 mm rough-in.
- .8 Water Closet Seats.
 - .1 Seat: White extra heavy duty, moulded solid plastic with open front with cover, self-sustaining, stainless steel hinge.
- .9 Washroom Lavatories:
 - .1 L-1: Vitreous China, Wall Mount, Barrier free with Carrier, Electronic Faucet.
 - .2 Fixture: White vitreous china, contoured rectangular basin, rear overflow, mounting bracket, back splash ledge, for concealed arm carrier installation.
 - .3 Faucet: Deck mount electronic faucet, all metal spout construction, Proximity Sensing Technology, hardwire c/w 24 VAC to 6 VDC converter (installed by

- electrical division). Surface mount control box, vandal resistant 1.9 l/m laminar outlet. Provide transformer and thermostatic mixing valve.
- .4 Thermostatic Mixing Valve: Thermostatic valve with check stops on inlets, adjustable set point, positive shutoff of hot supply when cold supply is lost.
- .5 Drainage: Offset open grid strainer, cast brass chrome plated with overflow holes. Cast brass chrome plated p-trap with cleanout plug. Cover trap, offset and water supplies with preformed vinyl covered insulation guard, white in colour.
- .6 Carrier: Heavy duty steel uprights with welded feet, cast iron adjustable headers, concealed arms, steel sleeve, alignment truss and mounting fasteners.
- .10 Fixture piping:
 - .1 Hot and cold water supplies to fixtures:
 - .1 Chrome plated supply pipes with handwheel stop, reducers, escutcheon.
 - .2 Waste:
 - .1 Brass P trap with clean out on fixtures not having integral trap.
 - .2 Chrome plated in exposed places.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for washroom fixtures installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Consultant.
 - .2 Inform Consultant of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied.

3.2 INSTALLATION

- .1 Mounting heights:
 - .1 As per manufacturer or National Building Code requirements.

3.3 ADJUSTING

- .1 Conform to water conservation requirements specified this section.
- .2 Adjustments:
 - .1 Adjust water flow rate to design flow rates.
 - .2 Adjust pressure to fixtures to ensure no splashing at maximum pressures.
 - .3 Adjust flush valves to suit actual site conditions.
 - .4 Set controls of automatic flush valves for WCs and urinals to prevent unnecessary flush cycles.
- .3 Checks:
 - .1 Water closets, urinals: flushing action.

- .2 Vacuum breakers, backflow preventers: operation under all conditions.
- .4 Thermostatic controls:
 - .1 Verify temperature settings, operation of control, limit and safety controls.

3.4 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11- Cleaning.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11- Cleaning.
- .3 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21- Construction/Demolition Waste Management and Disposal.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 22 05 00 – Common work Results for Plumbing

1.2 REFERENCE STANDARDS

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA-B45 Series-02(R2008), Plumbing Fixtures.
 - .2 CAN/CSA-B125.3-05, Plumbing Fittings.
 - .3 CAN/CSA-B651-04, Accessible Design for the Built Environment.
- .2 National Research Council Canada (NRC)
 - .1 National Building Code of Canada 2015 (NBC).

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for fixtures, and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data in accordance with Section 01 78 00- Closeout Submittals.
- .2 Include:
 - .1 Description of fixtures and trim, giving manufacturer's name, type, model, year, capacity.
 - .2 Details of operation, servicing, maintenance.
 - .3 List of recommended spare parts.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 01 61 00- Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.

Part 2 Products

2.1 MANUFACTURED UNITS

- .1 Fixtures: manufacture in accordance with CAN/CSA-B45 series.
- .2 Trim, fittings: manufacture in accordance with CAN/CSA-B125.

- .3 Exposed plumbing brass to be chrome plated.
- .4 Number, locations: architectural drawings to govern.
- .5 Fixtures to be product of one manufacturer.
- .6 Trim to be product of one manufacturer.
- .7 Stainless steel counter top sinks.
 - .1 S-1: Single Compartment Sink.
 - .1 Sink: Type 304, 18-10 stainless steel, 20 ga. self-rimming with positive hold down clamps. Satin finish on exposed surfaces. Undercoated on bottom. 89 mm crumb cup wastes. Ledge back drilled to fit faucet. Approximate Bowl dimensions: 432 mm (w) x 305 mm (f/b) 160 mm (deep - maximum).
 - .2 Trim: Deckmount, 200mm centres, two handle with gooseneck faucet. Chrome plated cast brass with 5.7 l/m vandal resistant flow control aerator and 76 mm blade handles. Ceramic trim.
 - .2 Fixture piping:
 - .3 Hot and cold water supplies to each fixture:
 - .1 Chrome plated supply pipes each with handwheel stop, reducers, escutcheon.
 - .4 Waste:
 - .1 Brass P trap with clean out on each fixture not having integral trap.
 - .2 Chrome plated in all exposed places.

Part 3 Execution

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Mounting heights:
 - .1 Standard: to comply with manufacturer's recommendations unless otherwise indicated or specified.
 - .2 Wall-hung fixtures: as per manufacturers recommended height.
 - .3 Physically handicapped: to comply with most stringent of either NBC or CAN/CSA-B651.

3.3 ADJUSTING

- .1 Conform to water conservation requirements specified this section.
- .2 Adjustments:
 - .1 Adjust water flow rate to design flow rates.

- .2 Adjust pressure to fixtures to ensure no splashing at maximum pressures.
- .3 Checks:
 - .1 Aerators: operation, cleanliness.
 - .2 Vacuum breakers, backflow preventers: operation under all conditions.
 - .3 Wash fountains: operation of flow-actuating devices.
- .4 Thermostatic controls:
 - .1 Verify temperature settings, operation of control, limit and safety controls.

3.4 CLEANING

- .1 Clean in accordance with Section 01 74 11- Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for recycling, reuse in accordance with Section 01 74 21- Construction/Demolition Waste Management and Disposal.

END OF SECTION