

## **ADDENDUM No. 2**

The following changes to the tender documents are effective immediately and will form part of the contract documents:

### **1. GENERAL**

1.1	The Bidding Documents are amended as noted in this Addendum, which consists of one (1) page plus the following attachments: 1. Drawing #A0.0 – Cover Sheet, Project Information & Drawing List. 2. Drawing #A3.1 – Custom Post Arm Details.
1.2	This Addendum is issued prior to bid closing to incorporate revisions noted herein. Include in the Bid price all such revisions which will become part of the Work. Perform all such Work in accordance with the Contract Documents.
1.3	All affected drawings, schedules and panel changes shall be reflected in final as-built and manual submissions.

### **2. ANSWERS TO BIDDERS' QUESTIONS**

2.1	Question: Under Entrance Plan Detail 6/A2.3 we understand that directional drilling is required under concrete sidewalk. Can the conduit under asphalt road be trenched and patched or does it also require directional drilling? Answer: Directional drilling required under asphalt road as well.
-----	--

### **3. SPECIFICATIONS**

3.1	Not used.
-----	-----------

### **4. DRAWINGS**

4.1	Drawing #A0.0 – Cover Sheet, Project Information & Drawing List: 1) See attached revised drawing.
4.2	Drawing #A3.1 – Custom Post Arm Details: 1) See attached revised drawing.

**END OF ADDENDUM NO. 2**