



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS A :**

Bid Receiving/Réception des sousmissions  
Procurement & Contracting Services  
c/o Commissionaires, F Division  
6101 Dewdney Ave  
Regina, SK S4P 3K7

Fax No. - No de FAX:  
(306) 780-5232

**SOLICITATION  
AMENDMENT**

**MODIFICATION DE  
L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments: - Commentaries :

THIS DOCUMENT CONTAINS A SECURITY REQUIREMENT

LE PRÉSENT DOCUMENT COMPORTE UNE EXIGENCE EN MATIÈRE DE SÉCURITÉ

<b>Title – Sujet: Furnace and Air Conditioning Replacement, Drayton Valley, AB</b>		<b>Date : April 25, 2018</b>
<b>Solicitation No. – N° de l'invitation</b> M5000-18-6325/A		<b>Amendment No. – N° de la modification</b>
<b>Client Reference No. - No. De Référence du Client</b> 201806325		
<b>Solicitation Closes – L'invitation prend fin</b>		
<b>At /à :</b>	2 :00 pm	CST (Central Standard Time) HNC (Heure Normale du Centre)
<b>On / le :</b>	May 2, 2018	
<b>Incoterms 2010 "DDP Delivered Duty Paid"</b> See herein — Voir aux présentes	<b>GST – TPS</b> See herein — Voir aux présentes	<b>Duty – Droits</b> See herein — Voir aux présentes
<b>Destination of Goods and Services – Destinations des biens et services</b> See herein — Voir aux présentes		
<b>Instructions</b> See herein — Voir aux présentes		
<b>Address Inquiries to – Adresser toute demande de renseignements à</b> Tania Sentes		
<b>Telephone No. – No. de téléphone</b> 639-625-3463		<b>Facsimile No. – No. de télécopieur</b> 306-780-5232
<b>Delivery Required – Livraison exigée</b> N/A		<b>Delivery Offered – Livraison proposée</b> N/A
<b>Vendor/Firm Name, Address and Representative – Raison sociale, adresse et représentant du fournisseur/de l'entrepreneur:</b>		
<b>Telephone No. – No. de téléphone</b>		<b>Facsimile No. – No. de télécopieur</b>
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) – Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>		
<b>Signature</b>		<b>Date</b>



This amendment is raised to address the following:

- To respond to questions received during the solicitation period; and
- To revise the solicitation accordingly, as applicable.

## **QUESTIONS AND ANSWERS**

**Question 1.** What if Asbestos is suspected on duct or pipe insulation?

**Answer 1:** Re-mediation of asbestos found in the work area will be dealt with by contract amendment.

**Question 2.** Do the furnaces get hooked up electrically to the back-up generator circuits, or main panel?

**Answer 2:** The furnaces and mechanicals get hooked up electrically, to the existing breakers that are in use for the current mechanicals.

**Question 3.** Can the contractor deviate from the mechanical specifications listed in the Schedule?

**Answer 3:** When materials are specified by trade names or trademarks, or by manufacturers' or suppliers' names, the bid shall be based on use of the named materials. During the solicitation period, alternative materials may be considered provided full technical data is received in writing by the Contracting Officer at least ten (10) calendar days prior to the solicitation closing date. If the alternative materials are approved for the purposes of the bid, an addendum to the bid documents shall be issued. *R2410T - General Instructions - Construction Services - G113 (2015-02-25) Approval of alternative materials*

**Question 4.** Is new duct work required around the furnaces to hold filters and other items, or can existing be utilized?

**Answer 4:** Existing ductwork to be utilized; new transition ductwork is required to match the existing ductwork (600x300) and the new furnace return opening (586x356).

**Question 5.** What are the working hours?

**Answer 5:** The Detachment is available 08:30-16:00 hrs Mon-Fri

**Question 6.** How is the gym exhaust fan controlled?

**Answer 6:** The gym exhaust fan is controlled via an ON/OFF switch.

**Question 7.** Regarding the return air from the gym, can it be routed through the mechanical room instead of the electrical room?

**Answer 7:** Yes.

**Question 8.** Due to the proximity of the split air conditioner evaporator in the electrical room to the electrical panel, is there a drip/spill pan required to be placed under the evaporator?

**Answer 8:** Yes. Also, the condensate pump for the evaporator shall pump into the mechanical room and drain into the common condensate drain.

**Question 9.** Regarding the exhaust fan in room 105, what should be done with the duct?

**Answer 9:** The duct is to be removed and capped at the exterior wall penetration complete with insulation. The exhaust fan is to be removed and the hole covered and painted to match existing ceiling finish.

**Question 10.** Are neutralizers to be installed for the condensate?

**Answer 10:** Yes, as per code.

**Question 11:** Will a second site visit be offered.

**Answer 11:** Yes, an additional site visit will be offered on **Friday April 27<sup>th</sup> at 10:00 am at the Detachment.**



**SOLICITATION REVISIONS**

1) On page one (1 )

**DELETE:**

<b>Solicitation Closes – L'invitation prend fin</b>		
<b>At / à :</b>	2 :00 pm	CST (Central Standard Time) HNC (Heure Normale du Centre)
<b>On / le :</b>	April 27, 2018	

**INSERT:**

<b>Solicitation Closes – L'invitation prend fin</b>		
<b>At / à :</b>	2 :00 pm	CST (Central Standard Time) HNC (Heure Normale du Centre)
<b>On / le :</b>	May 2, 2018	

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME