

Project Title:	Addendum No: 2
New Daycare, Iqaluit	
Project Location:	Project Number:
Iqaluit, NU	R082769.001
Consultant's Name:	Date: 2018-04-19
EVOQ Architecture	
<p>The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.</p>	
Drawings	
ARCHITECTURE	
<ol style="list-style-type: none"> Drawing A-102-CONSTRUCTION PLAN – GROUND FLOOR Replace by the attached drawing. Drawing A-103-CONSTRUCTION PLAN – LEVEL 2 Replace by the attached drawing. Drawing A-201-REFLECTED CEILING PLAN – GROUND FLOOR Replace by the attached drawing. Drawing A-501-INTERIOR DETAILS Replace by the attached drawing. Drawing A-801-DOOR SCHEDULE, DOOR & WINDOW ELEVATIONS Replace by the attached drawing. 	
STRUCTURE	
<ol style="list-style-type: none"> Drawing S-204-WOOD COLUMNS PLAN Replace by the attached drawing. Drawing S-205-SECOND FLOOR AND LOWER ROOF PLAN Replace by the attached drawing. 	
MECHANICAL	
<ol style="list-style-type: none"> Drawing M-202-PLUMBING - DRAINAGE – GROUND FLOOR Replace by the attached drawing. Drawing M-305-HEATING – DIAGRAM AND DETAILS Replace by the attached drawing. 	

ELECTRICAL

1. **Drawing E-001-ELECTRICITY – LEGEND**
Replace by the attached drawing.
2. **Drawing E-300-ELECTRICITY – LIGHTING – CRAWL SPACE & GROUND FLOOR**
Replace by the attached drawing.

Specifications

Volume 2 – Technical Divisions

1. **Section 05 50 00 – Metal Fabrications**
2.2 Material, correct as follows:
 - .19 ~~Aluminium~~ **Steel** angle for cove light, dimensions and profile as per drawings.
Holes pre-drilled for fastening to wood beam or gypsum wall, factory pre-painted, color to be confirmed by Departmental Representative.
2. **Section 06 40 00 – Architectural Wood and Plastic Work**
2.10 Casework Accessories, correct as follows:
 - .6 Heavy-duty extensions and drawer slides, Extra-heavy-duty, for large module and pullout stairs, full extension pretension, mechanism in close position with lock lever, steel ball bearing, side capacity: 150 to 550 lbs, length as per woodwork module requirement, ~~white (30)~~ **zinc** finish.
3. **Section 22 05 15 – Plumbing Specialties and Accessories**
Replace by the attached section.
4. **Section 23 21 13.02 – Hydronic Systems –Steel**
Replace by the attached section.
5. **Section 26 50 00 – Lighting**
Replace by the attached section.

End of Addendum 2