

Solicitation No. – N° de l’invitaion
EA003-190013/A

Amd. No. - N° de la modif.
3

Buyer ID – Id de l’acheteur
PWD005

Client ref. No. - N° de ref. du client
R.089934.001

File No. N° du dossier
PWD-8-41005

CCC No./N° CCC – FMS No/N° VME

ADDENDUM NO. 1

**THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE
ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS.**

DRAWINGS

SPECIFICATION SECTION 26 32 13.01 – POWER GENERATION DIESEL

1. Delete section.

DRAWING E1 – ELECTRICAL SITE PLAN

1. Delete and replace with drawing E1-REV. Refer to drawing E1-REV, note #14 for the wording change regarding the generator being supplied by Canada and the responsibility of the Contractor.

DRAWING E2 – ELECTRICAL SITE PLAN DETAILS

1. Delete and replace with drawing E2-REV. Refer to drawing E2-REV, detail 3 for revised generator being supplied by Canada.

DRAWING C6 – DIESEL GENERATOR CONCRETE PAD DETAILS

1. Delete and replace with C6-REV. Any/all references alluding to coordination of concrete pad foundation construction details with electrical shall be deleted and replaced with similar text dictating self-enclosed generator will be supplied by Canada and installed by the Contractor. The contractor will coordinate exact size and placement of concrete pad foundation, anchorage, and necessary penetrations with Departmental Representative.
2. Refer to drawing C6-REV detail 2 for the revised concrete generator pad length.

Solicitation No. – N° de l'invitaion
EA003-190013/A

Amd. No. - N° de la modif.
3

Buyer ID – Id de l'acheteur
PWD005

Client ref. No. - N° de ref. du client
R.089934.001

File No. N° du dossier
PWD-8-41005

CCC No./N° CCC – FMS No/N° VME

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Bid Amount.
