

May 4, 2018

AAFC Admiral Dam & Downie Lake Dam
Contract No. 5
Low Level Gate System Replacement
CONTRACT #4547-928-714-0-C5

Addendum No. 1

Questions & Answers

Q1 After reviewing the tender documentation, I see that this has a requirement for Cast Iron Gates. Would it be possible to ask for a non-cast equal?

A1 A non-cast equal is not acceptable.

Q2 Can the closing date of the tender be extended?

A2 Yes. Tenders will now be received up to 2:00 p.m., local Regina time, Thursday, May 24, 2018.

Additional Information

1. The non-mandatory informational meeting is now changed to 10:00 a.m., Tuesday, May 15, 2018.
2. The use of asbestos-containing materials are not to be used in the delivery of this project.

Natalie O'Neill
Senior Contracting Officer
Regina, Saskatchewan