


1 FLOOR PLAN - SANITARY
SCALE : 1:50
0m 1m 2m 3m 4m 5m

APPROXIMATE LOCATION OF PROPANE STORAGE TANKS. REFER TO ARCHITECTURAL.



2 FLOOR PLAN - WATER
SCALE : 1:50
0m 1m 2m 3m 4m 5m

SYMBOL LEGEND	
—DCW—	DOMESTIC COLD WATER
—DHW—	DOMESTIC HOT WATER
—PG—	PROPANE GAS
—SAN—	SANITARY ABOVE GRADE
—SAN—	SANITARY BELOW GRADE
—V—	SANITARY VENT
	UNION
⊥	END OF LINE CLEANOUT
⊙	PIPE CLEANOUT TO GRADE
⊙	FUNNEL FLOOR DRAIN
⊙	FLOOR DRAIN
⊙	PIPE DROP
⊙	PIPE RISE
⊙	PIPE TEE DOWN
⊙	PIPE TEE UP
⊙	ISOLATION VALVE
⊙	CAP
⊙	TEMPERATURE/PRESSURE RELIEF VALVE
⊙	PRESSURE SWITCH
⊙	THERMOMETER
⊙	PRESSURE GAUGE
XX-X	EQUIPMENT/FIXTURE TYPE
⊙	KEYNOTE
⊙	DRAWING REVISION
SK	SINK
DWH	DOMESTIC WATER HEATER
NTS	NOT TO SCALE

GENERAL NOTES:

1. INSTALL PLUMBING IN ACCORDANCE WITH THE NATIONAL PLUMBING CODE.
2. ALL TRAPS TO BE REMOVABLE AND COMPLETE WITH CLEANOUT.
3. PROVIDE TRAP PRIMER CONNECTIONS TO ALL FD-1 FLOOR DRAINS.

KEYNOTES:

- ① PIPING TO RISE UP TO ATTIC SPACE.
- ② PIPING TO DROP DOWN SERVICE SPACE TO SERVE SHOWER MIXING VALVES. MIXING VALVES TO BE ACCESSIBLE THROUGH ACCESS PANEL FOR SERVICING. REFER TO ARCHITECTURAL.
- ③ DOUBLE CHECK VALVE ASSEMBLY TO BE INSTALLED 900mm AFF AND AS PER CSA B64. MAINTAIN 750mm MINIMUM SERVICE CLEARANCE IN FRONT OF ASSEMBLY.
- ④ PIPING TO DROP DOWN BLOCK WALL AND RUN BELOW COUNTERTOP. SLOPE PIPING TO LOW POINT AND PROVIDE DRAIN VALVES. REFER TO PIPING SCHEMATIC.
- ⑤ SURFACE MOUNT TRAP PRIMER TO BE PPP MODEL PTS-10 C/W 15mm DOUBLE CHECK VALVE ASSEMBLY.



0	ISSUED FOR TENDER	MAR 08 2018
revisions		date

project project

FUNDY NATIONAL PARK HEADQUARTERS & WOLFE LAKE CAMPGROUNDS

PHASE II

drawing dessin

MECHANICAL HQ SERVICE BUILDING SANITARY & WATER FLOOR PLANS

designed P. Arseneault conçu

date MAY 2017

drawn K. Trentowsky dessiné

date MAY 2017

approved approuvé

date

Tender Soumission

PMSC Project Manager Administrateur de projets TPSC

project number no. du projet

R.086534.001

drawing no. no. du dessin

M01