



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fire Suppression System Upgrade	
Solicitation No. - N° de l'invitation EZ899-182692/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2018-05-08
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-8344	
File No. - N° de dossier PWY-7-40394 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-05-22	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada (PCA) - SS Keno National Historic Site - Dawson City, YT	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation. - N° de l'off. à comm.
EZ899-182692/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy036

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-7-40394

CCC No./N° CCC - FMS No/ N° VME

This Amendment #002 is raised to issue Addendum #01.

Please see Addendum #01 herein.

The addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

Facility Name: SS Keno National Historic Site
Project Name: Fire Suppression System Upgrade
Project Number: R.075645.001

Addendum #01

Date: May 8, 2018

The following changes in the tender documents are effective immediately. This Addendum will form part of the contract documents.

1: Reference Tender Specifications 01 35 33 – Health & Safety Requirements

Clarification: Confined space

The hull space and exterior skirted space under the hull has been interpreted to not fit the definition of a confined space as defined by the Yukon OH&S regulations. However, access into the space and moving about spaces is restricted and extraction of a person in the event of an incident will likely prove difficult.

The Contractor shall conduct their own review of space and confirm prior to starting work. As part of the Contractor's Health & Safety Plan (clause 13) and Emergency Procedures (clause 14), the Contractor shall include documented extraction plan for hull space and exterior under hull space. Plan to include all necessary equipment, personnel and procedures.

2: Reference Tender Specifications 01 11 55 – General Instructions:

Revise item 1.16.1 as follows:

.1 Historical asset protection is paramount in this project. If specific...

3: Reference Tender Specifications 01 11 55 – General Instructions:

Delete clause 1.17 and **Replace** with the following:

1.17 Cutting

- .1 Work is to be carried out in accordance with accepted historic conservation techniques, and as outlined in the Standards and Guidelines for the Conservation of Historic Places in Canada.
- .2 Do not cut any holes unless approved by Departmental Representative.
- .3 If approved, make cuts with clean, true, smooth edges.
- .4 Fit work airtight to pipes, sleeves ducts and conduits.
- .5 All patching to be done by Parks Canada Agency forces.

4: Reference Tender Specifications 01 78 00 – Closeout Submittals:

Revise clause 1.6.7.4 as follows:

.4 Digital photographs to be taken for each day of work, minimum...

Add clause 1.6.7.6 as follows:

- .6 Provide keyplan(s) for photographs. Keyplan(s) to indicate location and view direction for each photograph and where context required to provide brief description and notes.

5: Reference Tender Specifications 21 13 16 – Dry Pipe Sprinkler Systems:

Delete clause 2.3.1.3.1 and **Replace** with the following:

- .1 Materials and methods utilized are to minimize visual impact on historic appearances. Confirm seismic restraint type and materials acceptable to Departmental Representative.

6: Reference Tender Drawings M100 through M502, General Notes:

Delete General Note 3 and Replace as follows:

- 3. All adjacent areas disturbed by the scope of work to be patched and make good by Parks Canada Agency forces. Contractor to extend all reasonable effort to minimize affected areas.

Add General Note 6 as follows:

- 6. Applicable guidelines: The Standards and Guidelines for the Conservation of Historic Places in Canada, Second Edition

----End of Addendum----