

The following changes to the tender documents are effective immediately and will form part of the contract documents:

As submitted, the following manufacturers have been reviewed and accepted as “Equal Manufacturers” (acceptable “Substitutes”) to those specified. Final acceptance of the proposed products/items is subject to the review of the shop drawings and the subsequent conformance of the proposed products/items with the specified products’ capabilities and features. Manufacturers reviewed as being accepted shall be subject to the provisions of Sections 23 05 01-1.20.7 “Approved 'Substitutes' And 'Alternates”.

#	Spec. Section	Item Description	Proposed Manufacturer
1	Div. 25	Controls	Trane (Trane)

Questions:

1. Is Distech approved for installation or would we need to submit an equal or alternate request?

Answer: In our opinion it would not be necessary to apply for an equal for Distech Control products.