



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Elevator Inspection & Maintenance	
<b>Solicitation No. - N° de l'invitation</b> W6862-180039/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> W6862-180039	<b>Date</b> 2018-05-18
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-019-8336	
<b>File No. - N° de dossier</b> PWY-7-40291 (019)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-06-05</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ngan, Ken (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy019
<b>Telephone No. - N° de téléphone</b> (604) 671-0219 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DND - CFB Comox - Lazo, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
W6862-180039/A  
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.  
003  
File No. - N° du dossier  
pwy-7-40291

Buyer ID - Id de l'acheteur  
pwy019  
CCC No./N° CCC - FMS No/ N° VME

---

**Les documents français seront disponibles sur demande.**

This Solicitation Amendment 003 is raised to incorporate responses to questions received.

All other terms and conditions remain unchanged.

Q1.) What intervals of maintenance are expected for elevator preventative maintenance (ie. service in accordance with B44.02?) or another pre-described schedule? Taking into consideration of course, usage, application and regulatory requirements.

A1.) How it works is the Technician comes once a month usually mid. month to perform the following;

Control Tower (monthly),

All others (quarterly).

B105 and H14..... 1<sup>st</sup> , 4<sup>th</sup> , 7<sup>th</sup> , 10<sup>th</sup> (month)

H7..... 2<sup>nd</sup> , 5<sup>th</sup> , 8<sup>th</sup> , 11<sup>th</sup> (month)

And B309..... 3<sup>rd</sup> , 6<sup>th</sup> , 9<sup>th</sup> , 12<sup>th</sup> . (month)

Q2.) Please clarify the requirements of **Statement of Work Page 3, item D**. It is our understanding that a “full time” representative is not required as per standard elevator industry practice. Maintenances is provided on an interval basis - typically monthly which would coincide with normal code applicable work for regulated elevating devices.

A2.) A technician who actually works on the base fulltime every day is NOT required.

Q3.) Should bidders be including for regulatory work (based on application of each device as per B44.02) or is that considered in addition to our proposed “maintenance” costs?

A3.) On Annex “A” (Revised) – Statement of Work, under Article 2 – Scope of Work,

INSERT:

- b. Regulatory work, The Tower elevator will require an annual brake test with a governor test once every 5 years. All other lifts, (freight or material) will require an annual pressure test, with the rupture valve or governor tested every 5 years depending on design.

End of Solicitation Amendment 003.