



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier/11, rue Laurier
Place du Portage, Phase III
Core 0B2 / Noyau 0B2
Gatineau, Québec K1A 0S5
Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Parliamentary Precinct Division/Acquisitions de la Cité
parlementaire
222 Queen Street / 222, rue Queen
Ottawa
Ontario
K1A 0S5

Title - Sujet 111 Wellington-Lockers and benches	
Solicitation No. - N° de l'invitation EP751-173057/D	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client EP751-173057	Date 2018-05-18
GETS Reference No. - N° de référence de SEAG PW-\$PPS-017-26811	
File No. - N° de dossier 017pps.EP751-173057	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-05-28	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lemay, Jessica	Buyer Id - Id de l'acheteur 017pps
Telephone No. - N° de téléphone (613) 990-4232 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: See Annex A - Voir l'annexe A.	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EP751-173057/D
Client Ref. No. - N° de réf. du client
EP751-173057

Amd. No. - N° de la modif.
001
File No. - N° du dossier
017pps. EP751-173057

Buyer ID - Id de l'acheteur
017pps
CCC No./N° CCC - FMS No./N° VME

Question and Answer Series 1

- Q1. Will Public Services and Procurement Canada (PSPC) accept a Thermofused Laminate in place of high pressure, if the thermofused is tested to high pressure standards?
- A1. The bidder's proposed product must meet Performance Criteria #1 through #10 in Annex A, Part 2, in addition to the other Mandatory Technical Criteria. If these criteria are met, PSPC will accept the product. The Mandatory Technical Criteria has been updated to reflect this change.
-

Amendment 001 is raised to modify the Mandatory Technical Criteria.

1. At Attachment 1 to Part 4 – Mandatory Technical Criteria, **DELETE** in its entirety and **REPLACE** with the following:

MANDATORY REQUIREMENTS:

At the date of bid closing, bids MUST meet the mandatory requirements specified herein. The complete specifications and/or descriptive literature should be submitted with the proposal but may be submitted afterwards. If the complete specifications and/or descriptive literature are not submitted as requested, the Contracting Authority will so inform the Bidder and provide the Bidder with a time frame within which to meet this requirement. Failure to comply with the request of the Contracting Authority and meet the requirement within that time period will render the bid non-responsive.

Any proposal which fails to meet all mandatory specifications will be deemed non-responsive.

Each requirement should be addressed separately.

Any deviations MUST be approved, in writing, **PRIOR** to bid closing by the Contracting Authority.

Questions will be answered with an amendment to the solicitation and posted on Buy and Sell.

Mandatory Technical Specifications and Requirements:		Comply Yes or No	Supplier Comments	Supplier's Cross Reference to Technical Offer (page #)	For PSPC's Technical Evaluation Purposes Only	
					Met/ Not Met	Comments
1	Phenolic Full Height Locker as per the following mandatory specifications:					
1a	Size must be 254 mm wide x 610 mm deep x 1829 mm high					
1b	Material must meet the Performance Criteria in ANNEX A, PART 2, Performance Criteria - #1 through #10.					
1c	Doors, sloped tops, end panels, and toe kick plates: minimum 13 mm finished thickness					
1d	Sloped locker tops, bottoms, and shelves: minimum 10 mm finished thickness					
1e	Sides and locker backs: minimum 8 mm finish					

1f	Locker door must be the full width of the locker body and shall be frameless					
1g	Must be scratch, impact and water resistant					
1h	Must have interior shelf and 3 coat hooks					
2	<u>68" Length Locker Room Bench</u> as per the following mandatory specifications:					
2a	<u>Minimum</u> 1727 mm wide x 254 mm deep x 419 mm high <u>Maximum</u> 1727 mm wide x 305 mm deep x 520 mm high					
2b	Must be Type 304 stainless steel pedestal Minimum 3 mm (11 ga)					
2c	Must be secured to the floor					
2d	Must be Phenolic Material Bench Top Minimum 19 mm					
3	<u>43" Length Locker Room Bench</u> as per the following mandatory specifications					
3a	<u>Minimum</u> 1092 mm wide x 254 mm deep x 419 mm high <u>Maximum</u> 1092 mm wide x 305 mm deep x 520 mm high					
3b	Must be Type 304 stainless steel pedestal Minimum 3 mm (11 ga)					
3c	Must be secured to the floor					
3d	Must be Phenolic Material Bench Top					

Solicitation No. - N° de l'invitation
EP751-173057/D
Client Ref. No. - N° de réf. du client
EP751-173057

Amd. No. - N° de la modif.
001
File No. - N° du dossier

Buyer ID - Id de l'acheteur
017pps
CCC No./N° CCC - FMS No./N° VME
017pps, EP751-173057

	Minimum 19 mm								
4	Project Requirements								
	Bidder has read and confirms that they will comply with Annex A - Statement of Work.								