



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Bowden Inst. - Boiler replacement	
Solicitation No. - N° de l'invitation EP922-190102/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client CSC EP922-190102	Date 2018-05-22
GETS Reference No. - N° de référence de SEAG PW-\$PWU-066-11365	
File No. - N° de dossier PWU-8-41009 (066)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-05-29	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lee, Mony	Buyer Id - Id de l'acheteur pwu066
Telephone No. - N° de téléphone (780) 224-6675 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT No. 005

The following questions and answers are address to the specifications for clarification purposes only.

Question 1: I am wondering if you will be issuing a schedule for the boilers? At present, no equipment supplier is willing to quote on the boilers as the spec is too vague. Without a quote on the boilers we cannot accurately bid this work.

Answer: See addendum 1.

All other terms and conditions of the Invitation to Tender remain unchanged.

ADDENDUM #1


Project Title:	Addendum No:
Boiler Replacement, Bowden Institution	1
Project Location:	PWGSC Project No:
Innisfail, Alberta	R.090861.001
Consultant's Name:	Date:
DGH Engineering Ltd.	May 22, 2018

The following changes in the bid documents are effective immediately.
This addendum will form part of the contract documents.

Mechanical Drawings and Specifications

Item No.	Change														
1	<p>Supply a total of 8 boilers , each with the following specifications:</p> <table border="1"><thead><tr><th colspan="2">Boiler</th></tr></thead><tbody><tr><td>Energy Source</td><td>Natural Gas</td></tr><tr><td>Output</td><td>112 kw (382,000 BTU/H)</td></tr><tr><td>Input</td><td>117 kw (399,000 BTU/H)</td></tr><tr><td>Max Supply Temperature</td><td>82 C</td></tr><tr><td>Make and Model</td><td>IBC SL 80-399, or equal</td></tr><tr><td>Electrical Requirements</td><td>15 A, 120 V, 60 Hz, 1 ph</td></tr></tbody></table> <ul style="list-style-type: none">• Supply and install 6 boilers in the Administration Building (B-1,2,3,4,5,6).• Supply and install 1 boiler in the Library/School building (B-1L).• Supply 1 boiler and store on site for use as a spare. <p>Alternative acceptable manufacturers: Viessman and Triangle Tube.</p> <p>Supply and install/store boilers as indicated in the contract drawings and specificaitons.</p>	Boiler		Energy Source	Natural Gas	Output	112 kw (382,000 BTU/H)	Input	117 kw (399,000 BTU/H)	Max Supply Temperature	82 C	Make and Model	IBC SL 80-399, or equal	Electrical Requirements	15 A, 120 V, 60 Hz, 1 ph
Boiler															
Energy Source	Natural Gas														
Output	112 kw (382,000 BTU/H)														
Input	117 kw (399,000 BTU/H)														
Max Supply Temperature	82 C														
Make and Model	IBC SL 80-399, or equal														
Electrical Requirements	15 A, 120 V, 60 Hz, 1 ph														

General Changes Approved By:



The seal is circular with the text "PROFESSIONAL ENGINEER ALBERTA" around the perimeter. Inside the circle, it says "JESSE K. NUGENT" above a stylized drawing of a person's head and shoulders. Below the drawing is a shield with the letters "P.E." inside.

Permit to Practice: P6498