



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency**  
**1300 - 635 8 Ave SW**  
**Calgary, AB T2P3M3**  
**Bid Fax: (866) 246-6893**

AMENDMENT / MODIFICATION

005

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**  
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address  
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
**Suite 1300**  
**635 – 8 Ave SW**  
**Calgary, AB T2P3M3**

<b>Title-Sujet</b> Lake Louise Water Reservoir Upgrades – Banff National Park		
<b>Solicitation No. - No. de l'invitation</b> 5P420-18-0061/A	<b>Date:</b> May 23, 2018	
<b>GETS Reference No. – No de reference de SEAG</b> PW-18-00826240	<b>Amendment No. - N° de la modif.</b> 005	
<b>Solicitation Closes:</b>		
<b>at – á</b> 02:00 PM	<b>on – le</b> May 29, 2018	<b>Time Zone - Fuseau horaire</b> MDT - HAR
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/>	<b>Destination:</b> <input checked="" type="checkbox"/>	<b>Other-Autre:</b> <input type="checkbox"/>
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b>		
Jen Maheu <a href="mailto:jennifer.maheu@pc.gc.ca">jennifer.maheu@pc.gc.ca</a>		
<b>Telephone No. - No de téléphone</b>	<b>Fax No. – No de FAX:</b>	
(403) 292-8502	(866) 246-6893	
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>		
See Herein – Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b>	_____
<b>Facsimile No. - N° de télécopieur:</b>	_____
<b>Signature</b>	<b>Date</b>

## Amendment 05

This amendment is being raised to extend the solicitation closing date and distribute the answers to bidder questions.

### A) BID CLOSING DATE

The closing date for tender 5P420-18-0061/A, titled *Lake Louise Water Reservoir Upgrades – Banff National Park* is extended from May 24, 2018 until May 29, 2018 at 2:00PM Mountain Daylight Time (MDT).

### B) QUESTIONS

**Q31** On drawing 3084-01-E-101 it shows a 1” conduit from the Transmitter Control box to the Telephone Service Bix blox. Do we need to stub the 1” out of the transmitter control box and cap it for future use or will this 1” be installed when the telecom company puts in the bix block enclosure?

**A31** The 1” conduit will be stubbed out of the transmitter control box and capped at the location shown on the drawings.

**Q32** On drawing 3084-01-E-101 it shows a 1” conduit from the Telephone Service Bix blox to a pull box. Is this conduit in our scope of supply or is this by future contract?

**A32** 1” conduit is within the scope of this Contract.

**Q33** On drawing 3084-01-E-101 it shows a pull box just S.W. of the bix blox enclosure. Is this in our scope of supply or is this by future contract?

a. If this pull box is by us can you please provide spec on requirement for this pull box?

**A33** Pull box is within the scope of this Contract. Pull box specification is on drawing 3084-01-E-101 under “PRODUCTS”, item number 4.

**Q34** On drawing 3084-01-E-101 it shows 2 – 1-1/4” conduits from the Transmitter Control box to the pull box just S.W. of the Telephone Service Bix blox. Are these 1-1/4” conduits in our scope of supply or are these by future contract?

**A34** 1 ¼” conduits are within the scope of this Contract.

**All other terms and conditions remain unchanged.**