



Procurement Hub – Ottawa Office,
Station 9E255, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

Wednesday May 23, 2018

ADDENDUM NO. 2

Subject: **Invitation to Tender No. FP802-180048**
Title: **Construction of a launching ramp at Cap-des-Caissie**
Location: **Cap-des-Caissie, Kent County, New-Brunswick**
Closing Date: **Thursday, May 31, 2018 @ 2:00 PM (EDT)**

Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this **Addendum no.2** is to advise potential bidders of the following changes and/ or Questions & Answers from Bidders to this tender call to date:

QUESTIONS and ANSWERS

1. Question from Bidder:

I noticed that there's a silt curtain required for this job, but was wondering what type of fabric (woven or non-woven) and what thickness is needed.

DFO Answer 01:

The silt curtain shall be 4mm non-woven fabric.

All other terms and conditions remain unchanged.

Yours truly,

Lynda Coulombe
Procurement and Contracting Consultant
Matériel and Procurement Services
Financial and Matériel Management Operations
200 Kent Street, 9th Floor, 9E255
Ottawa, ON K1A 0E6
Tel: (613) 327-9911
E-mail: Lynda.Coulombe@dfo-mpo.gc.ca