

ADDENDUM NO. 1

CECON Project # 17401 Parks Canada PCA Project # 457

Terra Nova National Park Outdoor Theatre Upgrades

1. PRECEDENCE:

This addendum shall form an integral part of the contract specification to be read in conjunction therewith. This Addendum shall take precedence over all forms for the aforementioned specification with which it may provide to be at variance or may otherwise be qualified in writing by authorized personnel.

2. GENERAL

The general conditions and all documents issued with this specification shall apply to govern all phases of the work covered by this Addendum.

3. PURPOSE

1. **Section 09 03 61 – Repainting Exterior Surfaces Theatre Benches:**

- a. **Colours 2.3.1:** Delete 1.1, 1.2, 1.3, and 1.4.
Replace 1.1 with: “Colours are to be specified by Owner after award.”
- b. **Application 3.4.1.1:** Should read: “Install a minimum of **three coats** of linseed oil paint on **all** surfaces. Colour to be specified after award.”
- c. Please see attached specification section with these revisions.

2. **Section 06 15 00 – Wood Decking:**

- a. **Materials 2.1.1:** Delete.
Replace with: “Wood Decking: **All** lumber to be dressed pressure treated ACQ or CA.”

End of Addendum