



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9**

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9**

Title-Sujet Outdoor Theatre Upgrades, Terra Nova National Park		
Solicitation No. - No. de l'invitation 5P201-18-0060/A		Amendment No./N° de modification de l'invitation 004
Client Ref. No. - No. de réf du client. 457		Date: 07 June 2018
GETS Reference No. - No de reference de SEAG PW-18-00828643		
Solicitation Closes:		
at - à 14:00	on - le 14 June 2018	Time Zone - Fuseau horaire ADT - HAA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Jaime Creaser, Jaime.Creaser@pc.gc.ca		
Telephone No. - No de téléphone (902) 426-7513		Fax No. - No de FAX: (902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 004

This amendment is being raised to answer questions for solicitation 5P201-18-0060/A:

1. Questions and Answers

Q1. Regarding Detail 2 on SP2, what is the span of the double 2 x 10 beams and what is the spacing on the 2 x 8 joist?

A1. The maximum span of the 2 2x10 beams is 2460mm. The spacing of the 2x8 joists is 600mm O.C. See updated drawing SP2 in folder DSP003 5P201-18-0060.

Q2. Can you confirm that the only item that needs Allback Linseed Oil Paint is the theatre benches as Specification 09 03 61 implies?

A2. Allback Linseed Oil Paint required on theatre benches and sign board only.

Q3. Is there any paint required on the new deck and railings?

A3. No

Q4. The spec for the coiling shutter is calling up 5 year warranty which does not exist in the industry. Can you adjust the warranty to industry standard of 2 years? Please advise.

A4. Revised to 2 year warranty.

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.
