



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency**  
**1869 Upper Water Street,**  
**Suite AH 201**  
**Halifax, Nova Scotia**  
**B3J 1S9**

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address  
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
**1869 Upper Water Street,**  
**Suite AH 201**  
**Halifax, Nova Scotia**  
**B3J 1S9**

<b>Title-Sujet</b> Renewal Project - Habitation Building, Port-Royal National Historic Site		
<b>Solicitation No. - No. de l'invitation</b> 5P201-18-0064/A		<b>Amendment No./N° de modification de l'invitation</b> 002
<b>Client Ref. No. - No. de réf du client.</b> 738		<b>Date:</b> 08 June 2018
<b>GETS Reference No. - No de reference de SEAG</b> PW-18-00829122		
<b>Solicitation Closes:</b>		
<b>at - á</b> 14:00	<b>on - le</b> 14 June 2018	<b>Time Zone - Fuseau horaire</b> ADT - HAA
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Jaime Creaser, <a href="mailto:Jaime.Creaser@pc.gc.ca">Jaime.Creaser@pc.gc.ca</a>		
<b>Telephone No. - No de téléphone</b> (902) 426-7513		<b>Fax No. - No de FAX:</b> (902) 426-1775
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>  See Herein - Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**  
**À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)**

<b>Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de téléphone:</b> _____	
<b>Facsimile No. - N° de télécopieur:</b> _____	
<b>Signature</b>	<b>Date</b>

## AMENDMENT 002

**This amendment is being raised to revise specifications and to answer questions for solicitation 5P201-18-0064/A:**

### 1. MODIFICATION TO SPECIFICATIONS

At specification section 07 92 00 Joint Seallants

At section 2.1.5 Sealant Materials

Insert:

REZI-WELD FLEX

### 2. QUESTIONS AND ANSWERS

Q1. It was noted at the site visit that no siding was being replace however the drawings A-4 call up new board and batten siding on the East Elevation Detail 2, North Elevation Detail 3, West Elevation Detail 4, and South Elevation Detail 1. Is this part of our work? Are the boards supplied by the owner?

A1. See addendum 2 item 3 - delete all notes and references to siding removals and replacements. Delete the board and batten siding on a-4 is included in this note.

Q2. Are ridge board by the owner as well as the peak end boards?

A2. Ridge boards and peak end boards are to be supplied by the contractor.

Q3. Mention was made about a new foundation for the palisade, it only shows one wall getting done?

A3. The new foundation for the palisade is as indicated on the drawings. The existing foundations are to have the metal rods inserted to support the new palisade as identified on the drawings.

Q4. Please confirm which boards are the responsibility of the contractor for the cannon platform work/ palisade.

A4. The contractor is responsible for all lumber and boards for the Palisade replacement. Parks Canada Agency is supplying the exterior heavy timbers for the Cannon Platform, all other decking boards, railings, supports etc. for the deck are to be supplied by the contractor. The existing wood flag pole is to be re-installed with the rebuild, see note 5 addendum 2.

Q5. There was also mention about the existing interior stairs to be replace but drawing A-2 notes existing stair to remain. Please clarify.

A5. Delete the note on A-2 stating the stair to remain. The staircase is to be replace with new, as noted on Bid Item 9 in the measurement and payment section.

Q6. Is the wood preservative applied to all wood (existing siding as well) or just the new products we are installing?

A6. The wood preservative is to be applied to all wood elements on the Habitation, this is for new elements (palisade, canon platform, all cuts on PCA supplied roof boards, contractor supplied ridge boards, all cut ends) and existing wood (the siding, flagpole, doors as well). PCA supplied roof boards are pressure treated and do not require wood preservative on flat uncut surfaces. All salvaged and reused roof boards are to have wood preservative applied.

Q7. Just received a call and the noted preservative isn't available anymore, do you have an alternative?

A7. If the noted products are not available, similar alternatives would be considered if they have a clear finish and contain zinc naphthenate: minimum 2%. Spraying preservative is not allowed. Bidders can submit alternate products for review, however they are subject to PCA environmental impact review for acceptance.

Solicitation No. - N° de l'invitation  
5P201-18-0064/A

Amd. No. - N° de la modif.  
002

Buyer - l'acheteur  
Jaime Creaser

Client Ref. No. - N° de réf. du client  
738

File Name - Nom du dossier  
Renewal Project - Habitation Building, Port-Royal National Historic Site

---

**ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.**

---