



Royal Canadian Mounted Police / Gendarmerie royale du Canada

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A: Bid Receiving/Réception
des sousmissions**

RCMP-GRC

Bid Receiving/Réception des sousmissions
Attention: Jordan McKenna
Mail Stop/Arrêt postal 15
73 Leikin Drive,
Ottawa, ON K1A 0R2

AMENDMENT - INVITATION TO TENDER

MODIFICATION - APPEL D'OFFRES

Tender to: Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

Soumission aux: Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur
Facsimile No. - No de télécopieur:
Telephone No. - no de telephone:

| | |
|--|--|
| Title-Sujet: Construction of Water Treatment Plant – Norway House | |
| Solicitation No. - No. de l'invitation 201900293 | Date June 11 th , 2018 |
| Client Reference No. - No. De Référence du Client 201900293 | Amend No.- No. du modif. 002 |
| GETS Reference No. - No. de Référence de SEAG 201900293 | |
| Solicitation Closes –L'invitation prend fin at - à 16 :00 EDT on - le June 15 th , 2018 | |
| F.O.B. - F.A.B. Destination | |
| Address Enquiries to: - Adresser toutes questions à: jordan.mckenna@rcmp-grc.gc.ca | |
| Telephone No. - No de telephone 613.843.5518 | Fax No. - N° de FAX: |
| Destination of Goods, Services, and Construction: Destinations des biens, services et construction: | |
| Delivery Required - Livraison exigée: | Delivery Offered - Livraison proposée |
| Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur | |



Amendment #2 of Solicitation has been issued to make changes to the Tender document

Amendment #2 is being issued in order to amend the tender via addendum 3, respond to questions, and extend the tender closing date to Friday June, 15th:

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.

- 1) The closing date of this tender is extended to June 15th, 2018, at 16:00 EDT**
- 2) See responses to questions submitted as follows.

Part 1 Questions

Question 1:

Please confirm the following part of the specification is required for this project.

Given the location of this project this portion of the controls bid adds significantly to the overall cost. Estimated cost for 2 visits for preventative maintenance by a controls technician is \$7,500 plus we are expected to carry "call back costs".

1.9 MAINTENANCE SERVICE

.1 Section 01 78 10: Submittals for project closeout.

.2 Provide service and maintenance of control system for one year from Date of Substantial Completion.

.3 Provide complete service of controls systems, including call backs. Make minimum of two complete normal inspections of approximately two hours duration in addition to normal service calls to inspect, calibrate, and adjust controls, and submit written reports.

Answer 1:

This will be required

Question 2:

The 5/8" G1S Plywood is not exposed and is covered by FRP Panels on the interior walls by switching to 5/8" Plywood you would achieve some cost savings.

Answer 2:

Supply 5/8" GIS Plywood as specified

Question 3:

We would like to ask if the closing date can be extended from June 13, 2018 to June 20, 2018.

Answer 3:

Closing Date will remain unchanged.



Royal Canadian Mounted Police
Gendarmerie royale du Canada

Question 4:

What is the depth to bedrock below the new Water Treatment Plant Building?

Answer 4:

The exact Depth of Bedrock is unknown however assume that the bedrock is between 6'-0" and 8'-0" below grade.

Question 5:

The 1/2" Plywood under the Hardie Panel Siding could be changed to 1/2" Plywood Strapping 16" O/C to achieve some cost savings.

Answer 5:

Use the 1/2" plywood as designed.

Question 6:

The new metal roof is Vicwest Tradition 150 Metal Siding which is a standing seam style of roof and quite expensive have you considered switching to a screw down style of metal roof instead to achieve some cost savings.

Answer 6:

Use the standing Seam Metal Roof as designed.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.