



Royal Canadian Mounted Police / Gendarmerie royale du Canada

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A: Bid Receiving/Réception
des sousmissions**

RCMP-GRC

Bid Receiving/Réception des sousmissions
Attention: Jordan McKenna
Mail Stop/Arrêt postal 15
73 Leikin Drive,
Ottawa, ON K1A 0R2

AMENDMENT - INVITATION TO TENDER

MODIFICATION - APPEL D'OFFRES

Tender to: Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

Soumission aux: Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur
Facsimile No. - No de télécopieur:
Telephone No. - no de telephone:

Title-Sujet: Construction of Water Treatment Plant – Norway House	
Solicitation No. - No. de l'invitation 201900293	Date June 12 th , 2018
Client Reference No. - No. De Référence du Client 201900293	Amend No.- No. du modif. 003
GETS Reference No. - No. de Référence de SEAG 201900293	
Solicitation Closes –L'invitation prend fin at - à 16 :00 EDT on - le June 15 th , 2018	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: jordan.mckenna@rcmp-grc.gc.ca	
Telephone No. - No de telephone 613.843.5518	Fax No. - N° de FAX:
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:	
Delivery Required - Livraison exigée:	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



Amendment #3 of Solicitation has been issued to make changes to the Tender document

Amendment #3 is being issued in order to amend the tender via addendum 3, and respond to questions

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.

- 1) Please see addendum 3 attached under the Questions and Answers section.
- 2) See responses to questions submitted as follows.

Part 2 Questions

Question 1:

How thick is the proposed gravel around the WTP?

Answer 1:

See drawing C2.0 – proposed and existing elevations are shown

Question 2:

How thick is the proposed rock on the slopes around the WTP?

Answer 2:

See drawing C2.0 – proposed and existing elevations are shown.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Part 1 ADDENDUM NO.3

1.1 General

- .1 This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2 In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

Part 2 Clarifications and Additions

2.1 Revise:

Section 26 91 91

1.3 SYSTEM INTEGRATOR

- .1 Acceptable system integrators shall be Manco Controls, Celco Automation , Indus Automation, Hund Automation, Osorno, Delco Automation, or approved equal.

2.2 Add:

Section 46 07 13

1.2 LIST OF EQUIPMENT SUPPLIERS

- .4 Delco Water - A Division of Delco Automation Inc.

Contact: Kelly Franks, B.Sc.

3711 Thatcher Ave., Saskatoon, Saskatchewan S7R 1B8

Phone: (306) 244-6449 x 273

Email: kfranks@delco-water.com

2.3 Add:

Section 46 07 13

2.14 REDUCED PRESSURE BACKFLOW PREVENTERS

- .1 Backflow preventer shall conform to AWWA 511, CAN/CSA B64 SERIES, and other applicable standards.

- .2 Unit shall be bronze construction and serviceable in line.

- .3 Maximum operating pressure shall be 1.2 MPa (150 psi) and 60 oC (140 oF) operating temperature.

- .1 Acceptable Material: Wilkins Model 975XL Series, or approved equivalent

2.4 Remove Section 26 32 14 – Power Generation Diesel

2.5 Insert Attached Section 26 32 14 – Power Generation Diesel

2.6 “Graveled” areas to be filled with Manitoba Highways Type ‘A’ Base compacted to 100% SPD.

- 2.7** **“Rock” fill on slopes to be minimum 100 mm diameter locally sourced rock.**
- 2.8** **See Attached Request for Equal Delco Water**
- 2.9** **See Attached Mechanical Addendum No. 1**
- 2.10** **See Attached Electrical Addendum No. 2**

END OF SECTION