



Royal Canadian Mounted Police Gendarmerie royale du Canada

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A: Bid Receiving/Réception
des sousmissions**

RCMP-GRC

Bid Receiving/Réception des sousmissions
Attention: Jordan McKenna
Mail Stop/Arrêt postal 15
73 Leikin Drive,
Ottawa, ON K1A 0R2

AMENDMENT - INVITATION TO TENDER

MODIFICATION - APPEL D'OFFRES

Tender to: Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

Soumission aux: Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur
Facsimile No. - No de télécopieur:
Telephone No. - no de telephone:

Title-Sujet: Construction of Water Treatment Plant – Norway House	
Solicitation No. - No. de l'invitation 201900293	Date June 13 th , 2018
Client Reference No. - No. De Référence du Client 201900293	Amend No.- No. du modif. 004
GETS Reference No. - No. de Référence de SEAG 201900293	
Solicitation Closes –L'invitation prend fin at - à 16 :00 EDT on - le June 15 th , 2018	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: jordan.mckenna@rcmp-grc.gc.ca	
Telephone No. - No de telephone 613.843.5518	Fax No. - N° de FAX:
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:	
Delivery Required - Livraison exigée:	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



Amendment #4 of Solicitation has been issued to make changes to the Tender document

Amendment #4 is being issued in order to amend the tender via addendum 4, and respond to questions

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.

- 1) Please see addendum 4 attached under the Questions and Answers section.
- 2) See responses to questions submitted as follows.

Part 3 Questions

Question 1:

I was just wondering what the colour of the tradtion-150 roof sheets are. There is only one standard colour which is stone grey every other colour is non standard, if you could get back to me with a colour on that, that would be great. Also a colour on the HZ10 Hardy panels please.

Answer 1:

Exterior Colors as follows

- | | | |
|----|--------------------------|--|
| a. | Hardi Plank Siding Color | - James Hardie Evening Blue JH 70-30 |
| b. | Hardi Plan Trim Color | - James Hardie Evening Blue JH 70-30 |
| c. | Soffit | - White White QC 16076 |
| d. | Fascia | - James Hardie Cobble Stone JH40-10 |
| e. | Roof Color | - Vicwest Stone Grey 16071 |
| f. | Rain Gear | - Vicwest Stone Grey 16071 |
| g. | Door Trim | - Black |
| h. | Door Slabs | - Dulux Hale Village 2077 22/129 A1827 |

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Part 1 ADDENDUM NO. 4

1.1 General

- .1 This Addendum is issued prior to tender closing and shall become an integral part of the Tender, Specifications, Drawings and Contract Documents for this project.
- .2 In the event of conflicts between the various Contract Documents, the order of precedence shall be as stipulated in the General Conditions of the Contract, except that this Addendum shall take overall precedence.

Part 2 Equals

- 2.1 See attached equal approval.**

END OF SECTION




Associated Engineering

GLOBAL PERSPECTIVE.
LOCAL FOCUS.

REQUEST FOR EQUALS

Associated Engineering
203 - Five Donald Street
Winnipeg, MB R3L 2T4
Tel: 204.942.6391 Fax: 204.942.6399

CLIENT:	RCMP		
PROJECT:	Water Treatment Plant New Construction / Pump House Renovation Norway House, Manitoba		
PROJECT NO:			
FILE NO:			
RFE NO:	001		
DATE:	June 11, 2018		
REQUESTED BY:	-		
SECTION / CLAUSE	SPECIFIED MANUFACTURER / PRODUCT	PROPOSED MANUFACTURER / PRODUCT	ACCEPTED / NOT ACCEPTED
26 91 92	Swan, Hach, E&H	Rosemount FCL	Accepted
26 91 92	E&H, Krohne, ABB	Rosemount 8750W Magnetic Flow Meter	Accepted
Comments:			
<p>The plans and specifications define the performance of the work and the performance of the proposed substitutes must be equal to the original design. Proof of equivalency rests with the bidder. Any costs involved in the modifications to the design to accommodate the proposed substitute are to be included in the base bid.</p>			
<p>Per: ASSOCIATED ENGINEERING (SASK.) LTD.</p>  <p>Ken Anderson, P.Eng.</p>			