

ADDENDUM No. 1

Project Number: R.090980.001

Page 1 of 1

The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.

SPECIFICATIONS

1 Section 23 74 00 – Gas Fired Heater

.1 Article 2.4, Revise:

The heater shall be mid efficiency (80%) so as not to condense flue gasses. Minimum turndown capacity shall be 15:1.

DRAWINGS

1 Drawing ME3, Mechanical & Electrical New Work

.1 Mechanical Drawing Note 2, Append:

Exterior ductwork shall be sloped at a minimum of 10% complete with 0.50 mm, stucco embossed, aluminum protective jacket to ASTM B209 with moisture barrier. Jacket banding and mechanical seals shall be ¾" wide, 0.5 mm thick stainless steel.

END OF ADDENDUM No. 1