



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

| | |
|--|--|
| Title - Sujet HVAC Rooftop Unit Replacement | |
| Solicitation No. - N° de l'invitation EQ754-190380/A | Amendment No. - N° modif. 002 |
| Client Reference No. - N° de référence du client R.090980.001 | Date 2018-06-14 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWL-039-2372 | |
| File No. - N° de dossier PWL-8-41013 (039) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-06-19 | |
| Time Zone Fuseau horaire Eastern Daylight Saving Time EDT | |
| F.O.B. - F.A.B. | |
| Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Hassell, Bob | Buyer Id - Id de l'acheteur pwl039 |
| Telephone No. - N° de téléphone (416) 590-8270 () | FAX No. - N° de FAX (416) 512-5862 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Public Health Agency of Canada Laboratory Building Stone Road Guelph, ON X1X 1X1 Canada | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

QUESTIONS & ANSWERS

Question 1

Please confirm if the bid is to be submitted online through the GETS service or physically delivered to the address listed on the Invitation to Tender Document

Answer 1

Hard copy to be delivered, only change to the bid value can be faxed once hard copy received.

Question 2

Please confirm if the general contractor is required to obtain the services of an independent commissioning agent for the project or if the owner is responsible for obtaining a commissioning agent. If this is the contractor's responsibility please provide a list of acceptable Cx agents who are permitted to complete the work and who have the required security clearances.

Answer 2

Commissioning shall be a line item in the Contractor's breakdown. It is the Contractor's responsibility to ensure that the Cx agents have the necessary security clearances. We do not provide lists of Cx agents or contractors.

Question 3

Please confirm that VAV boxes and humidifier are not required to be included in the commissioning process as listed on page 3, Section 01 91 31 , 1.7. If this is required please identify the number of VAV boxes that are required to be commissioned and please provide a mechanical layout drawing.

Answer 3

Confirmed, VAV Boxes and Humidifiers are not required to be included in the commissioning process.

Question 4

Please confirm if external ductwork insulation is also required for the new roof top ductwork. If this is a requirement please provide approved products for weatherproofing/covering the external insulation

Answer 4

External weatherproof covering on the new ducting to be required. Specification Section 23 07 13 and Section 23 33 53 to be revised in an Addendum to describe the performance requirements.

Question 5

Please confirm if the unit is required to be shipped to site without refrigerant and if the refrigerant charge is to be administered on site when the unit is installed.

Answer 5

The unit may be shipped to site pre-charged from the factory.

Question 6

Please confirm that air balancing is required only at the replacement unit to confirm air flows. If the required scope exceed this please provide a duct layout drawing of the associated systems

Answer 6

Confirmed. Air balancing is only required at the unit.

Question 7

Please provide the contact information for the controls contractor who currently services the building.

Answer 7

Matt Togeretz
Controls Technician
Johnson Controls Canada LP
3070 Mainway Drive, Units 10 & 11
Burlington, ON L7M 3X1
Cell: 905-802-4821
Email: matthew.d.togeretz@jci.com

Question 8

Please confirm if an escort can be utilized for subcontractors that are required to work on site who do not have the valid security clearances. If this is acceptable please provide the cost per day for the escort service

Answer 8

Refer to security requirement check list (SRCL) in the Invitation to Tender document. Subcontractors without valid security clearance will not be allowed to work on site.

Question 9

Please confirm the time duration required for subcontractors to obtain the required security clearances. Will the project completion date take into account the time required for subcontractors to obtain the required clearances.

Answer 9

Unable to confirm time duration. Subcontractors should obtain required clearances in anticipation of working for Canada.

Question 10

Please confirm anticipated award date of the contract.

Answer 10

Unable to confirm.

Question 11

Please provide the make, model and serial number of the existing roof top unit that is to be replaced.

Answer 11

Make is Engineered Air, Model is unknown, serial number is unknown.

Question 12

Please provide the contact information for the fire alarm service provider for the building

Answer 12

Edwards

Ryan Rudavsky

(519) 746-4667

ryan.rudavsky@chubbedwards.com