



Fisheries and Oceans  
Canada

Pêches et Océans  
Canada

Procurement Hub – Ottawa Office,  
Station 9E249, 9th Floor,  
200 Kent Street,  
Ottawa, Ontario K1A 0E6

**ADDENDUM NO. 3**

Subject: **ITT Invitation to Tender No. FP802-180038  
Fabricate, Supply and Install 2 new Aids to Navigation**

Dear Sir/Madam:

Further to the above-mentioned Request for Proposal, this Addendum (#3) is to advise potential bidders that the closing date for this tender call has been changed as follows:

**Delete: June 20, 2018**  
**Insert: June 27, 2018**

All other terms and conditions remain unchanged.

**Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.**

Yours truly,

(Original signed by)

**Beverly Shawana**  
Senior Contracting Officer,  
Financial & Materials Management Operations

**RECEIPT ACKNOWLEDGED**

Name of Company

Signature \_\_\_\_\_

**Canada**

## *Annex A*

- Q1. Is it must to use the Fibergrat for tower supply?
- Q2. For rear tower, tower location is full of debris, are we to clean it?
- Q3. We will be using crane for tower decommissioning and erection, is it allowed for crane to access the mine?
- Q4. Is there any power source that we can use during the construction?
- Q5. Front tower anchor bolt is not being engineered yet, are we to provide the engineering design and stamp for it?
- Q6. Both tower designs are not stamped, are we to have it structure analysed and stamp them?

### Answers

- A1. Yes, the new towers are to be fabricated and installed as per drawings provided in Appendix E. The drawings note that “all FRP members shall be fabricated by Fibergrate...”
- A2. No, the site for the rear tower will be cleared of debris by Compass Minerals staff before construction.
- A3. Yes, a crane can access the mine.
- A4. For bidding purposes, assume that contractor is to provide power.
- A5. No, anchor bolts for both towers have been designed. Details for the bolts are provided on the foundation drawings found in Appendix F.
- A6. No, all new tower and foundation drawings provided are indeed stamped and do not require analysis.