



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
sousmissions**

**RCMP / GRC
Procurement & Contracting services
c/o Commissionaires, F Division
6101 Dewdney Avenue
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:
(306) 780-5232**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

**The referenced document is hereby
revised; unless otherwise indicated, all
other terms and conditions remain the
same.**

**Ce document est par la présente révisé;
sauf indication contraire, les modalités
de l'invitation demeurent les memes.**

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Lunchroom Expansion	
Solicitation No. - No. de l'invitation M5000-18-7363/A	Date 18 June 2018
Amendment No. - No modif. 04	
Client Reference No. - No. De Référence du Client M5000-18-7363/A	
GETS Reference No. - No. de Référence de SEAG PW-18-00828975	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 22 June 2018	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Teresa Hengen, Procurement Officer	
Telephone No. - No de téléphone (639) 625-3449	Fax No. - N° de FAX: (306) 780-5232
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police Dog Service Training Centre Highway 2, Exit 365 East Innisfail, AB	
This document does not contain a PERSONNEL SECURITY Clearance requirements	
Delivery Required - Livraison exigée: See Herein Voir aux présentes	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



This amendment is raised to address the following:

- To respond to questions received during the solicitation period;
- To attached Addendum No.:01; and
- To revise the solicitation accordingly, as applicable.

Delete:

Solicitation Closes –L'invitation prend fin
at - à 2 :00 pm Central Standard Time
on - le 21 June 2018

Replace with:

Solicitation Closes –L'invitation prend fin
at - à 2 :00 pm Central Standard Time
on - le 22 June 2018

Q1) Drawing S-06, detail 01 indicates the new pile P6 scheduled as 400mm Dia x 8000mm long . There is also a notation indicating... *"CONCRETE PILE DESIGN PARAMETERS HAVE BEEN BASED ON INFORMATION SHOWN ON EXISTING DRAWINGS AVAILABLE FROM THE DEPARTMENTAL REPRESENTATIVE. THE CONTRACTOR SHALL RETAIN A GEOTECHNICAL ENGINEER WHO SHALL BE RESPONSIBLE FOR THE FINAL DESIGN AND INSTALLATION OF PILES. SIZE 400Ø SHAFT 8000LENGTH REINFORCEMENT 5-15M VERT 10M@200 HORZ PILE LOADING..."*. Please confirm if the piling is a design build type pricing requirement as we will not know the soils condition until the existing sub-surface soil conditions are known.

R1) The piling is treated as a design-build exercise; the information provided on the contract documents is based on the existing drawings and is to be used as basis for costing the project: Base bid price for pile installation to be in accordance with the provisions of contract documents; where it is identified by the Geotechnical Engineer retained by the Contractor that the final pile design differs substantially than that indicated on the contract documents, the Contractor shall provide written evidence of final pile design, certified by the Geotechnical Engineer. Additions/deletions to the contract price shall be assessed using unit rates as per attached table.

Q2) Is there an existing soils report available for reference from the original building?

R2) No there is not. Contract documents require that the Contractor retain a geotechnical engineer to confirm the soil conditions and undertake professional responsibility for the design and installation of the piles. The costs for this work are to be included in the bid price.

Q3) Has there been any hazardous materials testing done on any of the visible or hidden existing building finishes, etc.?

R3) No there is not, however, the building was originally built in 2007.

List of drawings for project:

-NCCA 17-0028 Innisfail PDSTC Lunchroom Expansion (IFT)
-NNCCA17-0228 RCMP DTF - ELEC IFT
-CCA17-0228 RCMP DTF - ARCH IFT_update



Royal Canadian Mounted Police
Gendarmerie royale du Canada

Government
of Canada

Gouvernement
du Canada

Solicitation No./No de l'invitation: M5000-18-7363/A
Amendment No./ No modif: 004

-NCCA17-0228 RCMP DTF - MECH IFT
-NCCA17-0228 RCMP DTF - STRUC IFT

Delete:

BA03 THE OFFER

The Bidder offers to Her Majesty the Queen in right of Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the Total Bid Amount of

\$ _____ excluding GST/HST

Replace with:

BA03 THE OFFER

The Bidder offers to Her Majesty the Queen in right of Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the TOTAL BID AMOUNT INDICATED IN APPENDIX 1.



APPENDIX 1 - COMBINED PRICE FORM

- 1) The prices per unit shall govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

LUMP SUM

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

- a. Work included in the Lump Sum Amount represents all work not included in the unit price table.

LUMP SUM AMOUNT (LSA) Excluding GST / HST

UNIT PRICE TABLE

The Unit Price Table designates Work to which a Unit Price Arrangement applies.

- a. Work included in each item is as described in the referenced specification section.
- b. The Price per Unit shall not include any amounts for Work that is not included in that unit price Item.

Item	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity (EQ)*	Price per Unit GST/HST extra (PU)	Extended amount (EQ x PU) GST/HST extra
1.		Concrete piles (including installation) Minimum 32 mPa	cu.m.	1		
2.		Concrete pile reinforcement (including installation) 5-15M VERT; 10M ties	lin.m	1		
TOTAL EXTENDED AMOUNT (TEA) Excluding GST / HST						

TOTAL BID AMOUNT (LSA +TEA) Excluding GST / HST

*These numbers are estimated usage for cost evaluation purposes only and do not constitute a guarantee or commitment on behalf of Canada of the quantity or amount to be used under the Contract.