

June 15, 2018

TENDER ADDENDUM No.:001

Project No.

NCCA 17-0228

To

All Bidders of Record

Project Name

Innisfail PDSTC Lunchroom Expansion

Attached is a copy of **TENDER Addendum No. 001**, consisting of **2 pages**, including this cover sheet.

The following items shall constitute an addendum to the Drawings and Specifications for the above noted project. Allow for and include in the Bid all costs/credits applicable to the noted clarifications.

Bidders are reminded that, with respect to the Bid Form, should any item be omitted or illegible, should any alteration be made to the text, or should any condition be added on or submitted with the Bid Form, the bid may be declared invalid and rejected by the Owner



Signature

NORR Architects Engineers Planners

Doug Hider, P.Eng.

Associate

Tel: 403 451 1117 | Doug.Hider@norr.com



This Addendum forms part of the Bid and Contract Documents and modifies them as follows:

CLARIFICATIONS & REVISIONS:

1. Discipline: Electrical
 - 1) The buildings power is 3 phase, 4 wire.
 - 2) New panel D is to be 3 phase, 4 wire.
 - 3) New circuit breaker feeding panel D shall be a 3 pole breaker.
 - 4) Revise range plug to be a 40A 2 pole breaker.
 - 5) The cash allowance for fire alarm verification if the contractor chooses to carry NORR for fire alarm verification services shall be \$1,400.00.

END OF TENDER ADDENDUM No. 001
