



1  
E-401

**FIRE ALARM PLAN**  
SCALE 1:50

FIRE ALARM	
SYMBOL	DESCRIPTION
	HEAT DETECTOR (COMBINATION FIXED RATE AND RATE OF RISE - 57°F) - CR 135

- GENERAL NOTES:**
- CONTRACTOR IS RESPONSIBLE TO PROVIDE HEAT DETECTORS (CR135) IN THE SPACE AS SHOWN AND CONNECT THEM TO THE EXISTING FIRE ALARM LOOP IN THE SAME MANNER AS EXISTING DETECTOR COMPONENTS ARE CONNECTED.
  - MAINTAIN MINIMUM CLEARANCE OF 450mm BETWEEN THE HEAT DETECTOR AND AIR DUCT.
  - CONTRACTOR IS RESPONSIBLE TO PROVIDE UPDATED VERIFICATION REPORT.