


DRAWING NOTES:

1. TYPICAL. ALL EXISTING LIGHTING TO BE MADE OPERATIONAL, CONSISTING OF 2 LAMPS PER FIXTURE. REPLACE ALL LAMPS AND BALLASTS. PROVIDE NEW CHAIN FASTENING OF ALL EXISTING LIGHT FIXTURES TO CEILING STRUCTURE. ALL ANCHOR DRILLING TO BE COMPLETED AFTER HOURS. INCLUDE FOR SEISMIC APPROVAL FROM STRUCTURAL ENGINEER AT COMPLETION.
2. TYPICAL. REPLACE ALL EXIT SIGNS WITH NEW PICTOGRAM TYPE, ENSURE PROPER OPERATION.
3. TYPICAL. PROVIDE NEW FIRE ALARM SPEAKER TO ACCOMMODATE NEW OFFICE UPGRADE. COMPLETE WITH 25 METERS OF FIRE RATED CABLE FASTENED TO CEILING STRUCTURE AND CONCEALED IN CEILING SPACE. CONNECT TO NEAREST FLOOR ZONE SPEAKER. SYSTEM MODIFICATION AND VERIFICATION TO BE COMPLETED AFTER HOURS.
4. TYPICAL. FEED LIGHTING FROM EXISTING EMERGENCY POWER CIRCUIT.
5. EXISTING 347/600V 3 PHASE 4 WIRE NORMAL LIGHTING PANEL TO REMAIN OPERATIONAL. INSPECT, CLEAN AND RE-TORQUE CONNECTION POINTS AND REPORT FINDINGS TO DEPARTMENT REPRESENTATIVE. TRACE AND CONFIRM CIRCUIT IDENTIFICATION PANEL AND PROVIDE UPDATED SCHEDULE.
6. PROVIDE NEW EXIT SIGN AND FEED FROM EXISTING EMERGENCY POWER EXIT SIGN CIRCUITS.
7. LIGHTING IN COMMON BUILDING CORE CORRIDOR AND ELEVATOR LOBBY NOT INCLUDED IN SCOPE OF WORK. INCLUDE FOR EXIT SIGN REPLACEMENT.

GENERAL NOTES:

1. REMOVE AND REPLACE ALL EXISTING EXIT SIGNS WITH NEW PICTOGRAM TYPE.
2. VERIFY FIRE ALARM SPEAKER OPERATION AND REPORT FINDINGS TO DEPARTMENT REPRESENTATIVE.
3. PROVIDE CHAIN FASTENING OF ALL EXISTING LIGHT FIXTURES TO CEILING STRUCTURE. ALL ANCHOR DRILLING TO BE COMPLETED AFTER HOURS. INCLUDE FOR SEISMIC APPROVAL FROM STRUCTURAL ENGINEER AT COMPLETION.



L'ENTREPRENEUR DEVRA VÉRIFIER TOUTES LES DIMENSIONS ET LES CONDITIONS SUR LE CHANTIER ET AVISER SANS DÉLAI LE REPRÉSENTANT DU MINISTÈRE DE TOUTE ANOMALIE.

Contractor to verify all dimensions and conditions on site and immediately notify the departmental representative of all discrepancies.

9	ISSUED FOR ADDENDUM #3	2018-06-21
8	RE-ISSUED FOR TENDER	2018-04-23
7	ISSUED FOR TENDER	2017-12-13
6	ISSUED FOR 100% REVIEW	2017-10-27
5	ISSUED FOR 99% REVIEW	2017-09-26
4	ISSUED FOR 66% REVIEW	2017-09-01
3	ISSUED FOR M/E/COMM/DATA PLANS	2017-07-12
2	ISSUED FOR M/E DESIGN CONCEPT	2017-06-26
1	ISSUED FOR DESIGN DEVELOPMENT	2017-04-07
revisions	description	date

A C	A detail no. no. du détail B location drawing no. sur dessin no. C drawing no. dessin no.	A B C
--------	--	-------------

project project

L'ESPLANADE LAURIER  
WEST TOWER RE-FIT

300 LAURIER AVE., OTTAWA, ONTARIO

drawing dessin

ELECTRICAL LIGHTING &  
FIRE ALARM 8TH FLOOR

Designed By	M.T.	Conçu par	
Date	MAR/17	(yyyy/mm/dd)	
Drawn By	M.T.	Dessiné par	
Date	MAR/17	(yyyy/mm/dd)	
Reviewed By	M.T.	Examiné par	
Date	MAR/17	(yyyy/mm/dd)	
Approved By	A.M.	Approuvé par	
Date	MAR/17	(yyyy/mm/dd)	
Tender		Soumission	
Project Manager	AHMAD KHODR	Administrateur de projets	
Project no.		No. du projet	

R.081640.302

Drawing no. No. du dessin

E801R



1 8TH FLOOR ELECTRICAL PLAN  
E801R/1100