


10TH FLOOR ELECTRICAL PLAN

PWGSC: B1 (1000 x 707)



DRAWING NOTES:

1. **TYPICAL**
ALL EXISTING LIGHTING TO BE MADE OPERATIONAL, CONSISTING OF 2 LAMP TYPES TO BE REPLACED. ALL LAMPS AND BALLASTS PROVIDE NEW CHAIN FASTENING OF ALL EXISTING LIGHT FIXTURES TO CEILING STRUCTURE. ALL ANCHOR BOLLING TO BE COMPLETED AFTER HOURS. INCLUDE SEISMIC APPROVAL FROM STRUCTURAL ENGINEER AT COMPLETION.
2. **TYPICAL**
REPLACE ALL EXIT SIGNS WITH NEW PICTOGRAM TYPE. ENSURE PROPER OPERATION.
3. **TYPICAL**
PROVIDE NEW FIRE ALARM SPEAKER TO ACCOMMODATE NEW OFFICE UPGRADE. COMPLETE WITH 50 METERS OF FIRE RATED CABLE FASTENED TO CEILING STRUCTURE AND CONCEALED IN CEILING SPACE. CONNECTION TO NEAREST FLOOR ZONE SPEAKER. SYSTEM MODIFICATION AND VERIFICATION TO BE COMPLETED AFTER HOURS.
4. **TYPICAL**
FLEET LIGHTING FROM EXISTING EMERGENCY POWER CIRCUIT.
5. **TYPICAL**
EXISTING 347/600V 3 PHASE 4 WIRE NORMAL LIGHTING PANEL TO REMAIN OPERATIONAL. INSPECT, CLEAN AND RE-TORQUE CONNECTION POINTS AND REPORT FINDINGS TO DEPARTMENT REPRESENTATIVE. TRACE AND CONFIRM CIRCUIT IDENTIFICATION. RENEW AND REPAIR UPDATED SCHEDULE.
6. **TYPICAL**
PROVIDE NEW EXIT SIGN AND FEED FROM EXISTING EMERGENCY POWER EXIT SIGN CIRCUITS.
7. **TYPICAL**
LIGHTING IN COMMON BUILDING CORSE CORRIDOR AND ELEVATOR LOBBY NOT INCLUDED IN SCOPE OF WORK. INCLUDE FOR EXIT SIGN REPLACEMENT


GENERAL NOTES:

1. REMOVE AND REPLACE ALL EXISTING EXIT SIGNS WITH NEW PICTOGRAM TYPE.
2. VERIFY FIRE ALARM SPEAKER OPERATION AND REPORT FINDINGS TO DEPARTMENT REPRESENTATIVE.
3. PROVIDE CHAIN FASTENING OF ALL EXISTING LIGHT FIXTURES TO CEILING. ALL ANCHOR DRILLING TO BE COMPLETED AFTER HOURS. INCLUDE FOR SEISMIC APPROVAL FROM STRUCTURAL ENGINEER AT COMPLETION.

Canada




GOODKEY WEEDMARK & ASSOCIATES LIMITED
1688 Woodward Dr. 613 727-5111 Voice
Ottawa Ontario 613 727-5115 Fax
Canada K2C 3R8 www.gwal.com Web



L'ENTREPRENEUR DEVRA VÉRIFIER TOUTES LES DIMENSIONS ET LES CONDITIONS SUR LE CHANTIER ET AVISER SANS DÉLAI LE REPRÉSENTANT DU MINISTÈRE DE TOUTE ANOMALIE.

Contractor to verify all dimensions and conditions on site and immediately notify the departmental representative of all discrepancies.

9	ISSUED FOR ADDENDUM #3	2018-06-21
8	RE-ISSUED FOR TENDER	2018-04-23
7	ISSUED FOR TENDER	2017-12-15
6	ISSUED FOR 100% REVIEW	2017-10-27
5	ISSUED FOR 99% REVIEW	2017-09-29
4	ISSUED FOR 66% REVIEW	2017-09-01
3	ISSUED FOR M/E/COMM/DATA PLANS	2017-07-12
2	ISSUED FOR M/E DESIGN CONCEPT	2017-06-29
1	ISSUED FOR DESIGN DEVELOPMENT	2017-04-07



project	projet
---------	--------

L'ESPLANADE
LAURIER
WEST TOWER RE-FIT

300 LAURIER AVE., OTTAWA, ONTARIO

drawing	dessin
---------	--------

ELECTRICAL LIGHTING
& FIRE ALARM
10TH FLOOR

Designed By	Conçu par
-------------	-----------

Date	M.I. MAR/17	(yyyy/mm/dd)
------	----------------	--------------

Drawn By	Dessiné par
----------	-------------

Date	MAR/17	(yyyy/mm/dd)
------	--------	--------------

Reviewed By	Examiné par
-------------	-------------

Date	MAR/17	(yyyy/mm/dd)
------	--------	--------------

Approved By	Approuvé par
AM	

Date	A.M. MAR/17	(yyyy/mm/dd)
------	----------------	--------------

Tender	Soumission
--------	------------

AHMAD KHODR
Project Manager Administrateur de projets

Project Manager	Administrateur de projets
Project no.	No. du projet

P 081640 302

R.001040.502

Drawing no.	No. du dessin
E1001P	

