



LEGEND	
SYMBOL	DESCRIPTION
\$	SINGLE POLE SWITCH, 3 = 3-WAY SWITCHING, D = DIMMER, G = GFCI P=PILOT LIGHT
⌚	DUPLEX RECEPTACLE, SIZE PER PANEL & EQUIPMENT SCHEDULE. DESIGNATIONS AS FOLLOWS: G=GFCI, C=RECESSED CEILING MOUNTED U= C/W USB PORTS E= EXTERIOR GFCI RATED IN USED RECEPTACLE; EXTERIOR RECEPTACLE HOUSING SHALL BE BLACK
⌚	DUPLEX 20A T-SLOT RECEPTACLE, G=GFCI, C=COUNTERTOP
⌚	DUPLEX SPLIT 20A T-SLOT RECEPTACLE, G=GFCI, C=COUNTERTOP
⌚	SINGLE RECEPTACLE, 5-30R
⌚	RECEPTACLE, 208V, SIZE PER PANEL & EQUIPMENT SCHEDULE.
⌚	DIRECT CONNECTION, 120V, LOAD AS INDICATED.
⌚	DIRECT CONNECTION, 208V, LOAD AS INDICATED.
⌚	DIRECT CONNECTION C/W DISCONNECT, 208V, LOAD AS INDICATED.
⌚	ELECTRICAL PANEL
⌚	DATA/TELEPHONE OUTLET.
⌚	THERMOSTAT
⌚	SECURITY - MOTION DETECTOR MOUNTED ON WALL
⌚	SECURITY - SIREN/STROBE WARNING DEVICE
⌚	JUNCTION ENCLOSURE - OLDCASTLE ENCLOSURE SOLUTIONS: DURALITE 1015 MAX C/W VANDAL RESISTANT BOLT DOWN COVER
⌚	POLYMER CABLE CHANNEL SYSTEM - OLDCASTLE PLASTIBETON CHANNEL 10X10

NOTES:  
1. CONFIRM EXACT QUANTITY OF FIELD CONNECTIONS ON SITE.  
2. INSTALL AS PER MANUFACTURERS RECOMMENDATIONS

Public Works and Government Services Canada

Travaux Publics et Services gouvernementaux Canada

# NINE YARDS

**FUNDY Engineering**

27 Wellington Row  
P.O. Box 6626  
Saint John, NB  
E2L 4S1

Tel: (506) 635-1566  
Fax: (506) 635-0206  
fundy@fundyeng.com  
www.fundyeng.com

Serving Our Clients' Needs First

3	ISSUED FOR TENDER	03/13/18
2	99% REVIEW	09/02/18
1	50% REVIEW	01/12/17
revisions		date

project

AMPHITHEATRE REPLACEMENT

Fundy National Park

drawing

designed KMC

date 09/15/17

drawn JDB

date 09/15/17

approved KMC

date 09/15/17

Tender

PWGSC Project Manager

project number

R.075852.001

drawing no.

E1

dessein

conçu

dessiné

approuvé

Soumission

Administrateur de projets TPSGC

no. du projet

no. du dessin

E-DRM/GDD-E: 551992 V 1