



LIGHTING FIXTURE SCHEDULE				
TYPE	SYMBOL	MANUFACTURER-MODEL	DESCRIPTION	LAMP
A		1.EATON-INNUE SERIES WALLPACK 2.PHILIPS LIGHTING-LYTEPRO 32 SERIES 3.ELITE-OWP SERIES	EXTERIOR WALL-PACK - DARK SKY COMPLIANT - BLACK COLOR ENCLOSURE	4000 LUMEN LED, 4000K
B		1.EATONMETALUX - SNLED SERIES 2.PHILIPS LIGHTING-FLUXSTREAM SERIES 3.ELITE-4-OEC-LED SERIES	LED STRIP LIGHT SUSPENDED (WIRE HUNG) AT 2400mm AFF. HANGER LENGTHS VARY, COORDINATE WITH CEILING HEIGHT AT EACH FIXTURE LOCATION	4000 LUMEN LED, 4000K
C		PHILIPS LIGHTOLIER LYTEPROFILE - FRAME: P6RD25NZ101VB LIGHT: P6RD635VB REFLECTOR: P6RDCCP	LED POT LIGHT RECESSED IN CANOPY - BLACK COLOR ENCLOSURE/TRIM	2500 LUMEN LED, 3500K
-		1.LUMACELL-LA SERIES 2.AIMLITE-RP SERIES 3.READY-LITE-RA1 W SP	GREEN RUNNING MAN EXIT SIGN AND DUAL LAMP EMERGENCY LIGHT C/W 2 HOUR EMERGENCY BACKUP	LED
-		1.LUMACELL - RGS SERIES 2.AIMLITE - EBST SERIES	12VDC/120VAC, 44W, 10YR MAINTENANCE FREE BATTERY	LED
-		1.LUMACELL - RGS REMOTE HEAD 2.AIMLITE - EBST REMOTE HEAD SERIES	REMOTE HEAD COMPATIBLE WITH SPECIFIED BATTERY UNIT	LED




3
E2

CHANGE ROOM-MAKEUP STATION



2
E2

EXTERIOR LIGHTING CONTROLS



3	ISSUED FOR TENDER	03/13/18
2	99% REVIEW	09/02/18
1	50% REVIEW	01/12/17
revisions		date

project

AMPHITHEATRE
REPLACEMENT

Fundy National Park

drawing

LIGHTING PLAN
& DETAILS

designed **KMC**

date **09/15/17**

drawn **JSB**

date **09/15/17**

approved **KMC**

date **09/15/17**

Tender

PWGS&C Project Manager

project number

R.075852.001

drawing no.

E2