

PART 1 - GENERAL

- 1.1 RELATED REQUIREMENTS
- .1 Section 03 30 00.01 - Cast-In-Place Concrete Short Form.
  - .2 Section 32 11 17 - Reshaping Granular Roadbed.
- 1.2 ADMINISTRATIVE REQUIREMENTS
- .1 Co-ordination: arrange with authority having jurisdiction for relocation of buried services that interfere with execution of work.
    - .1 Pay costs of relocating services.

PART 2 - PRODUCTS

- 2.1 MATERIALS
- .1 Granular 'A', Granular 'B', and Granular 'C'.

PART 3 - EXECUTION

- 3.1 EXAMINATION
- .1 Evaluation and Assessment:
    - .1 Examine test pit information as shown on drawings.
    - .2 Before commencing work establish locations of buried services on and adjacent to site.
- 3.2 PREPARATION
- .1 Temporary erosion and sedimentation control:
    - .1 Provide temporary erosion and sedimentation control measures to prevent soil erosion and discharge of soil-bearing water runoff or airborne dust to adjacent properties and walkways, according to requirements of authorities having jurisdiction.
    - .2 Inspect, repair, and maintain erosion and sedimentation control measures during construction until permanent vegetation has been established.
    - .3 Remove erosion and sedimentation controls and restore and stabilize areas disturbed during removal.
-

3.2 PREPARATION  
(Cont'd)

- .2 Protection of in-place conditions:
  - .1 Protect excavations from freezing.
  - .2 Keep excavations clean, free of standing water, and loose soil.
  - .3 Where soil is subject to significant volume change due to change in moisture content, cover and protect to Departmental Representative's approval.
  - .4 Protect natural and man-made features required to remain undisturbed. Unless otherwise indicated or located in an area to be occupied by new construction, protect existing trees from damage.
  - .5 Protect buried services that are required to remain undisturbed.
- .3 Removal:
  - .1 Remove trees, stumps, logs, brush, shrubs, bushes, vines, undergrowth, rotten wood, dead plant material, exposed boulders and debris within work area.

3.3 EXCAVATION

- .1 Shore and brace excavations, protect slopes and banks and perform work in accordance with Provincial regulations.
- .2 Strip topsoil over areas to be covered by new construction, over areas where grade changes are required, and so that excavated material may be stockpiled without covering topsoil.
  - .1 Stockpile topsoil on site for later use.
- .3 Excavate as required to carry out work.
  - .1 Do not disturb soil or rock below bearing surfaces.
  - .2 Notify Departmental Representative when excavations are complete.
  - .3 If bearings are unsatisfactory, additional excavation will be authorized in writing and paid for as additional work.
  - .4 Excavation taken below depths shown without Departmental Representative's written authorization to be filled with concrete of same strength as for footings at Contractor's expense.

3.4 FIELD QUALITY CONTROL

- .1 Testing of materials and compaction of backfill will be carried out by testing laboratory designated by Departmental Representative.
- .2 Not later than 1 week minimum before backfilling or filling, submit to designated testing agency, samples of backfill as described in PART 1 - ACTION AND INFORMATIONAL SUBMITTALS.
- .3 Do not begin backfilling or filling operations until material has been approved for use by Departmental Representative .
- .4 Not later than 48 hours before backfilling or filling with approved material, notify Departmental Representative to allow compaction tests to be carried out by designated testing agency.

3.5 BACKFILLING

- .1 Remove snow, ice, construction debris, organic soil and standing water from spaces to be filled.
- .2 Lateral support: maintain even levels of backfill around structures as work progresses, to equalize earth pressures.
- .3 Compaction of subgrade: compact existing subgrade under walks, paving, and slabs on grade, to same compaction as fill.
  - .1 Fill excavated areas with selected subgrade material compacted as specified for fill.
- .4 Placing:
  - .1 Place backfill, fill and base course material in 150 mm lifts: add water as required to achieve specified density.
- .5 Compaction: compact each layer of material to following densities for material to ASTM D 698:
  - .1 To underside of base courses: 95%.
  - .2 Base courses: 100%.
  - .3 Elsewhere: 90%.
- .6 Under paving:

- 3.5 BACKFILLING .6 (Cont'd)
- (Cont'd)
- .1 Use select backfill up to bottom of granular base courses.
- .2 Use Granular 'B' for base courses.
- .7 Under seeded and sodded areas: use site excavated material to bottom of topsoil except in trenches and within 600 mm of foundations.
- .8 Against foundations (except as applicable to trenches and under slabs and paving): excavated material or imported material with no stones larger than 200 mm diameter within 600 mm of structures.
- 3.6 GRADING .1 Grade so that water will drain away from buildings, walls and paved areas, to catch basins and other disposal areas approved by Departmental Representative.
- 3.7 CLEANING .1 Leave Work area clean at end of each day.
- .2 Dispose of cleared and grubbed material off site daily.
- .3 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.