

PART 1 - GENERAL

1.1 NOT USED .1 Not Used.

PART 2 - PRODUCTS

2.1 SUPPORT CHANNELS .1 U shape, size 41 x 41 mm, 2.5 mm thick, surface mounted or suspended.

PART 3 - EXECUTION

3.1 INSTALLATION .1 Secure equipment to masonry, with lead anchors or nylon shields.

.2 Secure equipment to poured concrete with expandable inserts.

.3 Secure equipment to hollow masonry walls with toggle bolts.

.4 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.

.5 Fasten exposed conduit or cables to building construction or support system using straps.

.1 One-hole steel straps to secure surface conduits and cables 53 mm and smaller.

.2 Two-hole steel straps for conduits and cables larger than 53 mm.

.3 Beam clamps to secure conduit to exposed steel work.

.6 Suspended support systems.

.1 Support individual cable or conduit runs with 6 mm dia threaded rods and spring clips.

.2 Support 2 or more cables or conduits on channels supported by 6 mm dia threaded rod

---

- 3.1 INSTALLATION .6 (Cont'd)  
(Cont'd) .2 (Cont'd)  
hangers where direct fastening to building  
construction is impractical.
- .7 For surface mounting of two or more conduits  
use channels at 1.5 m on centre spacing.
- .8 Provide metal brackets, frames, hangers,  
clamps and related types of support structures  
where indicated or as required to support  
conduit and cable runs.
- .9 Ensure adequate support for raceways and  
cables dropped vertically to equipment where  
there is no wall support. Provide vertical  
galvanized steel strut supports from building  
structure.
- .10 Do not use wire lashing or perforated strap  
to support or secure raceways or cables.
- .11 Do not use supports or equipment installed  
for other trades for conduit or cable support  
except with permission of other trade and  
approval of Departmental Representative.
- .12 Install fastenings and supports as required  
for each type of equipment cables and  
conduits, and in accordance with  
manufacturer's installation recommendations.