

PART 1 - GENERAL

1.1 NOT USED .1 Not used.

PART 2 - PRODUCTS

2.1 BUILDING WIRES .1 Conductors: stranded for 8 AWG and larger.
Minimum size: 12 AWG. All conductors to be
100% copper.
.2 Copper conductors: size as indicated, with
600 V insulation of cross-linked thermosetting
polyethylene material rated RW90 XLPE and
RWU90 XLPE.

PART 3 - EXECUTION

3.1 INSTALLATION OF BUILDING WIRES .1 Install wiring as follows:
.1 In conduit systems in accordance with
Section 26 05 34 - Conduits, Conduit
Fastenings and Conduit Fittings.

3.2 INSTALLATION OF CONTROL CABLES .1 Install control cables in conduit.
.2 Ground control cable shield.