

PART 1 - GENERAL

- | | | |
|--|----|---|
| <u>1.1 REFERENCES</u> | .1 | Canadian Gas Association (CGA) |
| | .2 | Canadian General Standards Board (CGSB) |
| | .1 | CAN/CGSB-1.60, Interior Alkyd Gloss Enamel. |
| | .2 | CAN/CGSB-24.3, Identification of Piping Systems. |
| <u>1.2 ACTION AND INFORMATIONAL SUBMITTALS</u> | .1 | Product Data: |
| | .2 | Submittals: in accordance with Section 01 33 00 - Submittal Procedures. |
| | .3 | Product data to include paint colour chips, other products specified in this section. |
| | .4 | Samples: |
| | .1 | Submit samples in accordance with Section 01 33 00 - Submittal Procedures. |
| | .2 | Samples to include nameplates, labels, tags, lists of proposed legends. |
| <u>1.3 QUALITY ASSURANCE</u> | .1 | Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures. |
| | .2 | Health and Safety: |
| | .1 | Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements. |
| <u>1.4 DELIVERY, STORAGE, AND HANDLING</u> | .1 | Packing, shipping, handling and unloading: |
| | .1 | Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements. |
| | .2 | Deliver, store and handle materials in accordance with manufacturer's written instructions. |
-

1.4 DELIVERY, STORAGE, AND HANDLING (Cont'd)	.2 Waste Management and Disposal: .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling.
---	--

PART 2 - PRODUCTS

2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES	.1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
	.2 Lettering and numbers raised or recessed.
	.3 Information to include, as appropriate: .1 Equipment: manufacturer's name, model, size, serial number, capacity. .2 Motor: voltage, Hz, phase, power factor, duty, frame size.

2.2 SYSTEM NAMEPLATES	.1 Colours: .1 Hazardous: red letters, white background. .1 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
	.2 Construction: .1 3 mm thick laminated plastic, matte finish, with square corners, letters accurately aligned and machine engraved into core.
	.3 Sizes: .1 Conform to following table:

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1	10 x 50	1	3
2	13 x 75	1	5
3	13 x 75	2	3
4	20 x 100	1	8
5	20 x 100	2	5
6	20 x 200	1	8
7	25 x 125	1	12
8	25 x 125	2	8

2.2 SYSTEM NAMEPLATES (Cont'd)

- .3 Sizes: (Cont'd)
.1 Conform to following table: (Cont'd)

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
9	35 x 200	1	20

- .2 Use maximum of 25 letters/numbers per line.
- .4 Identification for PWGSC Preventive Maintenance Support System (PMSS):
.1 Use arrangement of Main identifier, Source identifier, Destination identifier.
.2 Equipment in Mechanical Room:
.1 Main identifier: size #9.
.2 Source and Destination identifiers: size #6.
.3 Terminal cabinets, control panels: size #5.
.3 Equipment elsewhere: sizes as appropriate.

2.3 EXISTING IDENTIFICATION SYSTEMS

- .1 Apply existing identification system to new work.
- .2 Where existing identification system does not cover for new work, use identification system specified this section.
- .3 Before starting work, obtain written approval of identification system from Departmental Representative.

2.4 IDENTIFICATION OF PIPING SYSTEMS

- .1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.
- .2 Pictograms:
.1 Where required: Workplace Hazardous Materials Information System (WHMIS) regulations.

2.4 IDENTIFICATION .3
OF PIPING SYSTEMS
(Cont'd)

Legend:

.1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.

- .4 Arrows showing direction of flow:
.1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.
.2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.
.3 Use double-headed arrows where flow is reversible.
- .5 Extent of background colour marking:
.1 To full circumference of pipe or insulation.
.2 Length to accommodate pictogram, full length of legend and arrows.
- .6 Materials for background colour marking, legend, arrows:
.1 Pipes and tubing 20 mm and smaller: waterproof and heat-resistant pressure sensitive plastic marker tags.
.2 Other pipes: pressure sensitive plastic-coated cloth vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100% RH and continuous operating temperature of 150 degrees C and intermittent temperature of 200 degrees C.
- .7 Colours and Legends:
.1 Where not listed, obtain direction from Departmental Representative.
.2 Colours for legends, arrows: to following table:

Background colour:	Legend, arrows:
Yellow	BLACK
Green	WHITE
Red	WHITE

.3 Background colour marking and legends for piping systems:

2.4 IDENTIFICATION .7 Colours and Legends: (Cont'd)
OF PIPING SYSTEMS .3 (Cont'd)
(Cont'd)

Contents	Background colour marking	Legend
Refrigeration suction	Yellow	REF. SUCTION
Refrigeration liquid	Yellow	REF. LIQUID
Refrigeration hot gas	Yellow	REF. HOT GAS

2.5 IDENTIFICATION .1 50 mm high stencilled letters and directional
DUCTWORK SYSTEMS arrows 150 mm long x 50 mm high.

- .2 Colours: back, or co-ordinated with base colour to ensure strong contrast.
- .3 Identify System: eg. Supply MUA-1; Exhaust EF-1.

2.6 VALVES, .1 Brass tags with 12 mm stamped identification
CONTROLLERS data filled with black paint.

.2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

2.7 CONTROLS .1 Identify all systems, equipment, components,
COMPONENTS controls, sensors with system nameplates
IDENTIFICATION specified in this section.

.2 Inscriptions to include function and (where appropriate) fail-safe position.

2.8 LANGUAGE .1 Identification in English.

PART 3 - EXECUTION

- 3.1 MANUFACTURER'S INSTRUCTIONS .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.
- 3.2 INSTALLATION .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
- .2 Provide ULC and or CSA registration plates as required by respective agency.
- .3 Identify systems, equipment to conform to PWGSC PMSS.
- 3.3 NAMEPLATES .1 Locations:
- .1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:
- .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:
- .1 Do not paint, insulate or cover.
- 3.4 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: at not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
-

3.4 LOCATION OF
IDENTIFICATION ON
PIPING AND DUCTWORK
SYSTEMS
(Cont'd)

- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.
- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, and dampers. Where this is not possible, place identification as close as possible, preferably on upstream side.
- .9 Identification easily and accurately readable from usual operating areas and from access points.
 - .1 Position of identification approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.

3.5 VALVES,
CONTROLLERS

- .1 Valves and operating controllers, except at plumbing fixtures, radiation, or where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
 - .2 Install one copy of flow diagrams, valve schedules mounted in frame behind non-glare glass where directed by Departmental Representative. Provide one copy (reduced in size if required) in each operating and maintenance manual.
 - .3 Number valves in each system consecutively.
-

NORTHWEST ATLANTIC FISHERIES	MECHANICAL	Sect 23 05 53.01
CENTRE (NAFC)	IDENTIFICATION	Page 8
COOLING & VENTILATION		
RENOVATIONS FOR POD G10		2018-06-08
PROJECT. R.999102.002		

- 3.6 CLEANING .1 Proceed in accordance with Section 01 74 11 -
Cleaning.
- .2 Upon completion and verification of
performance of installation, remove surplus
materials, excess materials, rubbish, tools
and equipment.