

PART 1 - GENERAL

1.1 NOT USED .1 Not used.

PART 2 - PRODUCTS

2.1 MATERIALS .1 Pressure type wire connectors to:
CAN/CSA-C22.2 No.65, with current carrying
parts of copper sized to fit copper conductors
as required.

.2 Fixture type splicing connectors to:
CAN/CSA-C22.2 No.65, with current carrying
parts of copper sized to fit copper conductors
10 AWG or less.

.3 Bushing stud connectors: to EEMAC 1Y-2 to
consist of:
.1 Connector body and stud clamp for
stranded copper aluminum and conductors bar.
.2 Clamp for stranded copper conductors.
.3 Stud clamp bolts.
.4 Bolts for copper conductors and bar.
.5 Sized for conductors and bars as
indicated.

.4 Clamps or connectors for armoured cable, TECK
cable and flexible conduit.

PART 3 - EXECUTION

3.1 INSTALLATION .1 Remove insulation carefully from ends of
conductors and cables and install in
accordance with manufacturer's instructions.