



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
sousmissions**

**RCMP / GRC
Procurement & Contracting services
c/o Commissionaires, F Division
6101 Dewdney Avenue
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:
(306) 780-5232**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

**The referenced document is hereby
revised; unless otherwise indicated, all
other terms and conditions remain the
same.**

**Ce document est par la présente révisé;
sauf indication contraire, les modalités
de l'invitation demeurent les memes.**

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Interior Renovations and Roof Replacement, Resource Centre	
Solicitation No. - No. de l'invitation M5000-19-0321/A	Date 11 July 2018
Amendment No. - No modif. 07	
Client Reference No. - No. De Référence du Client M5000-19-0321/A	
GETS Reference No. - No. de Référence de SEAG PW-18-00831371	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 12 July 2018	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Teresa Hengen, Procurement Officer	
Telephone No. - No de téléphone (639) 625-3449	Fax No. - N° de FAX: (306) 780-5232
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police Academy-Depot Division 5600 11th Ave Regina, SK	
This document does not contain a PERSONNEL SECURITY Clearance requirements	
Delivery Required - Livraison exigée: See Herein Voir aux présentes	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



This amendment is raised to address the following:

- To respond to questions received during the solicitation period.

Q11) 2.2.8 indicates end panels to match existing mobile storage shelving. Is there an existing mobile filing system that is to be used? If so, can arrangements be made to view the existing system & inventory the components in order to properly incorporate the existing parts into the new system design? During the walk through, we were not able to view the existing system.

R11) No need to match existing. Delete reference.

Q12) 3.2.2 indicates a grouted installation. Is the system to be designed utilizing an elevated deck with the track grouted in place and anchored into the floor or is an anchorless system required?

R12) System to be grouted in place and anchored into the floor

Q13) 2.1.4 indicates to provide sheet metal gables and backs between each shelving unit. Is it acceptable to use back and center stops rather than panels? (this will reduce the weight of the system)

R13) Back and centre stops are acceptable