



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Transformers Upgrade	
<b>Solicitation No. - N° de l'invitation</b> EP922-190710/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> AAFC	<b>Date</b> 2018-07-13
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-004-11400	
<b>File No. - N° de dossier</b> PWU-8-41049 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-07-20</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Espedido, Karielen K.	<b>Buyer Id - Id de l'acheteur</b> pwu004
<b>Telephone No. - N° de téléphone</b> (780) 497-3859 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> AAFC Lethbridge Research and Development Centre Lethbridge, AB (See Herein)	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EP922-190710/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
pwu004

Client Ref. No. - N° de réf. du client  
AAFC

File No. - N° du dossier  
PWU-8-41049

CCC No./N° CCC - FMS No./N° VME

---

This amendment has been raised with the following changes:

**AMENDMENT #002:**

**ADDENDUM #002:**

The following changes to the tender documents are effective immediately and will form part of the contract documents:

***BIDDERS' QUESTIONS & ANSWERS***

**Q1:** Which parts of the scope would be done in accordance with C22.1 vs C22.3? My interpretation of 3.2.1 below is that all work will follow part 1 (as I don't see references to C22.3 on the drawings), but that is contradictory to 3.2.2. Who are the authorities having jurisdiction for the electrical installation for part 1 and part 3 work?

**A1:** With regard to the CSA references in Spec section 26 05 00, clause 3.2 Installation we provide the following clarification.

Subclause .1 instructs that work follow CSA 22.1 for all work except where otherwise demanded.

Subclause .2 instructs that all work on the overhead and underground portions system be carried out in compliance with CSA 22.3 except where specified otherwise.

The drawings do not modify these requirements so they prevail in that CSA 22.1 governs all work in the project except the overhead and underground portions which is governed by CSA 22.3.

We believe that this hierarchy is clear and workable.

The design engineers through the authority of the Departmental Representative will interpret the application of the Canadian Electrical Code and serve as the AHJ.

**END OF AMENDMENT**