

PART 1 - GENERAL

1.1 GENERAL

- .1 Work in this section includes patching of existing firestopping as a result of mechanical work being performed. Coordinate work to ensure all areas affected by work are

1.2 REFERENCE STANDARDS

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .2 Underwriter's Laboratories of Canada (ULC)
 - .1 CAN-ULC-S101-14, Standard Methods of fire Endurance Tests of Building Construction and Materials.
 - .2 CAN-ULC-S102-07, Method of Test for Surface Burning Characteristics of Building Materials and Assemblies.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit two copies of WHMIS MSDS - Material Safety Data Sheets.
- .3 Samples: submit duplicate 300 x 300 mm size sample of exposed fireproofing for approval of texture and colour.
- .4 Quality assurance submittals: submit following:
 - .1 Test Reports:
 - .1 Submit product data including certified copies of test reports verifying fireproofing applied to substrate as constructed on project will meet or exceed requirements of Specification.
 - .2 Submit test results in accordance with CAN-ULC-S101 for fire endurance and CAN-ULC-S102 for surface burning characteristics.
 - .3 Submit Design Test Sheets to suit application from ULC or Intertek.
 - .4 For assemblies not tested and rated, submit proposals based on related designs using accepted fireproofing design criteria.
 - .2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .3 Manufacturer's Instructions: submit manufacturer's installation instructions and special handling criteria, installation sequence, cleaning procedures.
 - .4 Manufacturer's Field Reports: submit to manufacturer's written reports within 3 days of review, verifying compliance of Work, as described in PART 3 - FIELD QUALITY CONTROL.

1.4 QUALITY ASSURANCE

- .1 Qualifications:
 - .1 Installer: company specializing in sprayed-on fireproofing with 5 years documented experience.

- .2 Site Meetings:
 - .1 Convene pre-installation meeting two weeks prior to beginning work of this Section, with contractor's representative and Departmental Representative to:
 - .1 Verify Project requirements.
 - .2 Review installation and substrate conditions.
 - .3 Co-ordination with other building subtrades.
 - .4 Review manufacturer's installation instructions and warranty requirements.
 - .5 Review safety precautions and occupant restrictions:
 - .2 Prior to start of Work arrange for site visit with Departmental Representative to examine existing site conditions adjacent to demolition work.
 - .3 Hold project meetings in coordination with Contractor's Representative and Departmental Representative.
 - .4 Ensure key personnel attend.
- .3 Site Meetings: as part of Manufacturer's Services described in PART 3 - FIELD QUALITY CONTROL, schedule site visits, to review Work, at stages listed.
 - .1 After delivery and storage of products, and when preparatory Work is complete but before installation begins.
 - .2 Twice during progress of Work.
 - .3 Upon completion of Work, after cleaning is carried out.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
 - .2 Deliver packaged materials in original unopened containers, marked to indicate brand name, manufacturer, ULC markings.
- .2 Storage and Protection:
 - .1 Store materials indoors.
 - .2 Store and protect materials from exposure to harmful weather conditions and at temperature and humidity conditions recommended by manufacturer.
 - .3 Damaged or opened containers will be rejected.
 - .4 Packaging to indicate shelf-life and materials to be applied prior to expiration of shelf-life.
 - .5 Provide temporary enclosures to prevent spray from contaminating air beyond application area.
 - .6 Protect adjacent surfaces and equipment from damage by overspray, fall-out, and dusting of fireproofing materials.

1.6 AMBIENT CONDITIONS

- .1 At temperatures less than 5 degrees C, ensure that 5 degrees C air and substrate temperature is maintained during and for 24 hours after application. Ensure that natural ventilation to properly dry the fireproofing during and subsequent to its application is provided. In enclosed areas lacking openings for natural ventilation, ensure that interior air is circulated and exhausted to the outside.
- .2 Maintain relative humidity within limits recommended fireproofing manufacturer.
- .3 Ensure that natural ventilation to properly dry fireproofing during and subsequent to its application is provided.
- .4 In enclosed areas lacking openings for natural ventilation, provide minimum of 4 air exchanges per hour by forced air circulation.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Sprayed fireproofing: ULC certified cementitious asbestos-free mineral fibre fireproofing qualified for use in ULC or Intertek Designs specified and fungus resistant for 28 days.
- .2 Curing compound: type recommended by fireproofing manufacturer, qualified for use in ULC or Intertek Designs specified.
- .3 Sealer: type recommended by fireproofing manufacturer, qualified for use in ULC Design specified.
 - .1 Colour: white.
- .4 Fireproofing: minimum dry density and cohesion/adhesion properties as follows:
 - .1 Fireproofing for structural components located in mechanical rooms and storage areas: minimum applied dry density of 640 kg per cubic metre and cohesion/adhesion strength of 350 kPa.
 - .2 Ensure spray-applied fireproofing: does not crack, spall or delaminate under downward deflection conditions over 3 m clear span.
 - .3 Minimum compressive strength: 48 kPa.
 - .4 Spray-Applied fireproofing material: not contribute to corrosion of test panels.
 - .5 Dust removal: not exceed 0.25 gram per square meter.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 PREPARATION

- .1 Substrate: free of material, which would impair bond.
- .2 Verify that painted substrates are compatible and have suitable bonding characteristics to receive fireproofing.
- .3 Remove incompatible materials. Ensure existing fireproofing and new are compatible.
- .4 Ensure that items required to penetrate fireproofing are placed before installation of fireproofing.
- .5 Ensure that ducts, piping, equipment, or other items which would interfere with application of fireproofing are not positioned until fireproofing work is completed.

3.3 APPLICATION

- .1 Apply bonding adhesive or primer to substrate if recommended by manufacturer.

- .2 Apply fireproofing to correspond with tested assemblies, or acceptable calculation procedures to provide following fire resistance ratings.
- | Location | Rating | ULC Design Test |
|-----------------------|--------|---------------------|
| Roof supports (Beams) | 2 Hrs. | BXUVC.F816 or equal |
- .3 Apply fireproofing over substrate, building up to required thickness to cover substrate with monolithic blanket of uniform density and texture. Ensure patches are same depth as surrounding material.
- .4 Tamp smooth, surfaces visible in finished work.
- .5 Apply curing compound to surface of cementitious fireproofing as required by manufacturer.
- .6 Apply sealer to surface of mineral fibre fireproofing as required by manufacturer.

3.4 FIELD QUALITY CONTROL

- .1 Manufacturer's Field Services:
- .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.
- .2 Inspection and Site Tests:
- .1 Inspection and testing of fireproofing will be carried out by Testing Laboratory designated by Departmental Representative.
 - .2 Departmental Representative will pay costs for testing.

3.5 PATCHING

- .1 Patch damage to fireproofing caused by testing or by other trades before fireproofing is concealed, or if exposed, before final inspection.

3.6 CLEANING

- .1 Clean surfaces not indicated to receive fireproofing of sprayed material within 24 hours period after application.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION