

PART 1 GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Division 01 – General Requirements.
 - .2 General requirements that are common to Sections of Division 26.
 - .3 Sustainable requirements for construction and verification.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International) Latest Edition of the following:
 - .1 CSA C22.1-18, Canadian Electrical Code, Part 1, Safety Standard for Electrical Installations.
 - .2 CAN3-C235-83, (R2000), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
- .2 Electrical and Electronic Manufacturer's Association of Canada (EEMAC) Latest Edition of the following:
 - .1 EEMAC 2Y-1, (1958) Light Gray Colour for Indoor Switch Gear.
- .3 Health Canada / Workplace Hazardous Materials Information System (WHMIS) Latest Edition of the following:
 - .1 Material Safety Data Sheets (MSDS).

1.3 DEFINITIONS

- .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.

1.4 DESIGN REQUIREMENTS

- .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
 - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Language operating requirements: provide identification nameplates and labels for control items in English and French.
- .4 Use one nameplate or label for each language.

1.5 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Indicate details of construction, dimensions, capacities, weights and electrical performance characteristics of equipment or material.
 - .2 Where applicable, include wiring, single line and schematic diagrams.

- .3 Include wiring drawings or diagrams showing interconnection with work of other Sections.
- .2 Product Data: submit WHMIS MSDS in accordance with Section 01 33 00 – Submittal Procedures.
- .3 Submit for review single line electrical diagrams under plexiglass and locate as indicated:
 - .1 Electrical distribution system in main electrical room.
- .4 Shop drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Nova Scotia.
 - .2 Submit required number of copies of drawings and specification to Authority Having Jurisdiction and Inspection Authorities.
 - .3 If changes are required, notify Departmental Representative of these changes before they are made.
- .5 Quality Control: in accordance with Section 01 45 00 - Quality Control.
 - .1 Provide CSA certified equipment and material.
 - .2 Where CSA certified equipment and material is not available, submit such equipment and material to inspection authorities for special approval before delivery to site.
 - .3 Submit test results of installed electrical systems and instrumentation.
 - .4 Permits and fees: in accordance with General Conditions of contract.
 - .5 Submit, upon completion of Work, load balance report as described in PART 3 - Load Balance.
 - .6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.
- .6 Manufacturer's Field Reports: submit to Departmental Representative manufacturer's written report, within 3 days of review, verifying compliance of Work and electrical system and instrumentation testing, as described in PART 3 - FIELD QUALITY CONTROL.

1.6 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00- Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data as follows:
 - .1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.
 - .2 Operating instructions to include following:
 - .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
 - .2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
 - .3 Safety precautions.
 - .4 Procedures to be followed in event of equipment failure.
 - .5 Other items of instruction as recommended by manufacturer of each system or item of equipment.

- .3 Print or engrave operating instructions and frame under glass or in approved laminated plastic.
- .4 Post instructions where directed.
- .5 For operating instructions exposed to weather, provide weather-resistant materials or weatherproof enclosures.
- .6 Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.

1.7 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Testing and Quality Control.
- .2 Qualifications: electrical Work to be carried out by qualified, licensed electricians who hold valid Master Electrical Contractor license or apprentices in accordance with authorities having jurisdiction as per the conditions of Provincial Act respecting manpower vocational training and qualification.
 - .1 Employees registered in provincial apprentices program: permitted, under direct supervision of qualified licensed electrician, to perform specific tasks.
 - .2 Permitted activities: determined based on training level attained and demonstration of ability to perform specific duties.
- .3 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.8 DELIVERY, STORAGE AND HANDLING

- .1 Material Delivery Schedule: provide Departmental Representative with schedule within 30 days after award of Contract.
- .2 Deliver, store and handle materials in accordance with Section 01 61 00- Common Product Requirements.
- .3 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .4 Storage and Handling Requirements:
 - .1 Store materials in dry location, indoors, off ground and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Replace defective or damaged materials with new.
- .5 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.9 ELECTRICAL DRAWINGS

- .1 Drawings are diagrammatic.
- .2 Obtain accurate dimensions from architectural and equipment layout drawings.

1.10 VOLTAGE RATINGS

- .1 Operating Voltages: to CAN3-C235-83.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard. Equipment to operate in extreme operating conditions established in above standard without damage to equipment.

1.11 PERMITS, FEES AND INSPECTION

- .1 Submit to Electrical Inspection Department and Supply Authority necessary number of drawings and specifications for examination and approval prior to commencement of work.
- .2 Obtain an electrical work permit and pay associated fees.
- .3 Departmental Representative will provide drawings, specifications required by Electrical Inspection Department and Supply Authority at no cost.
- .4 Notify Departmental Representative of changes required by the Inspection Department prior to making changes.
- .5 Furnish Certificates of Acceptance from Electrical Inspection Department on completion of work to Departmental Representative.
- .6 Within 30 days of award of contract, submit a list of suppliers and delivery dates for equipment.

PART 2 PRODUCTS

2.1 MATERIALS AND EQUIPMENT

- .1 Provide material and equipment in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Material and equipment to be CSA certified. Where CSA certified material and equipment are not available, obtain special approval from authority having jurisdiction, inspection authorities before delivery to site and submit such approval as described and in PART 1 - Submittals.
- .3 Factory assemble control panels and component assemblies.

2.2 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS

- .1 Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.
- .2 Division 26 responsibility is as follows:
 - .1 Supply and installation of breakers and/or switches.

- .2 Supply and installation of power feeder (conduit and wire) from panel to starter, from starter to disconnect switch and from disconnect switch to motor.
- .3 Supply and installation of starters complete with motor protection unless noted otherwise.
- .4 Supply and installation of disconnect switches at motors unless noted otherwise on mechanical drawings.
- .5 Supply and installation of 120V power feeders to mechanical equipment such as time clocks and control panels.
- .3 Control wiring and conduit is by Division 25 unless noted otherwise on electrical drawings.

2.3 WARNING SIGNS

- .1 Warning Signs: in accordance with requirements of authority having jurisdiction, inspection authorities and Departmental Representative.
- .2 Signs, minimum size 175 x 250 mm.

2.4 WIRING TERMINATIONS

- .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.

2.5 EQUIPMENT IDENTIFICATION

- .1 Identify electrical equipment with nameplates and labels as follows:
 - .1 Nameplates: 3 mm thick plastic engraving sheet, matt white finish face, black core, lettering accurately aligned and engraved into core, mechanically attached with self tapping screws.
 - .2 Sizes as follows:

NAMEPLATE SIZES			
Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters
Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

- .3 Wording on nameplates to be approved by Departmental Representative prior to manufacture.
- .4 Allow for minimum of twenty-five (25) letters per nameplate.
- .5 Identification to be English and French. Use one (1) nameplate for each language.
- .6 Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .7 Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .8 Terminal cabinets and pull boxes: indicate system and voltage.

- .9 Transformers: indicate capacity, primary and secondary voltages.
- .10 Receptacles: Mounted above device plate, to indicate panel and circuit number.
- .11 Communications, voice, data, radio, CATV outlets: Size 1 nameplate.

2.6 WIRING IDENTIFICATION

- .1 Identify wiring with permanent indelible identifying markings, either numbered or coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.
- .2 Maintain phase sequence and colour coding throughout.
- .3 Colour coding: to CSA C22.1 – 2015.
- .4 Use colour coded wires in communication cables, matched throughout system.

2.7 CONDUIT AND CABLE IDENTIFICATION

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.
- .3 Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.

	PRIMARY	AUXILIARY
up to 250 V	Yellow	
up to 600 V	Yellow	Green
up to 5 Kv	Yellow	Blue
up to 15 Kv	Yellow	Red
Telephone	Green	
Other Communication Systems	Green	Blue
Fire Alarm	Red	
Emergency Voice	Red	Blue
Other Security Systems	Red	Yellow
51-240V	Yellow	
Above 240V	Yellow	Green
Telephone	Green	
Public Address	Blue	
Data	Blue	White
Security	Brown	
Fire Alarm	Red	
Television		
Emergency Lighting & Exit Signs	(ac) Orange	White
Emergency Lighting & Exist Signs	(dc) Brown	White
Mechanical Controls	Orange	

2.8 FINISHES

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
 - .1 Paint outdoor electrical equipment "equipment green" finish to EEMACV1-1-1955.
 - .2 Paint indoor switchgear and distribution enclosures light gray to EEMAC 2Y-1-1958.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Do complete installation in accordance with CSA C22.1 except where specified otherwise.
- .2 Do overhead and underground systems in accordance with CSA C22.3 No.1 except where specified otherwise.

3.2 NAMEPLATES AND LABELS

- .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

3.3 CONDUIT AND CABLE INSTALLATION

- .1 Install conduit and sleeves prior to pouring of concrete.
 - .1 Sleeves through concrete: schedule 40 steel pipe, sized for free passage of conduit, and protruding 50 mm.
- .2 If plastic sleeves are used in fire rated walls or floors, remove before conduit installation.
- .3 Install cables, conduits and fittings to be embedded or plastered over, neatly and close to building structure so furring can be kept to minimum.

3.4 LOCATION OF OUTLETS

- .1 Locate outlets in accordance with Section 26 05 32- Outlet Boxes, Conduit Boxes and Fittings.
- .2 Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.
- .3 Change location of outlets at no extra cost or credit, providing distance does not exceed 3000mm, and information is given before installation.
- .4 Locate light switches on latch side of doors.

3.5 MOUNTING HEIGHTS

- .1 Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
- .3 Install electrical equipment at following heights unless indicated otherwise.
 - .1 Local switches: 1120mm.
 - .2 Wall receptacles:
 - .1 General: 460mm.
 - .2 Above top of continuous baseboard heater: 200mm.
 - .3 Above top of counters or counter splash backs: 175mm.
 - .4 In mechanical rooms: 1120mm.
 - .3 Panelboards: as required by Code or as indicated.
 - .4 Fire alarm stations: 1120mm.
 - .5 Fire alarm bells: 2100mm.

3.6 FIELD QUALITY CONTROL

- .1 Load Balance:
 - .1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
 - .2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
 - .3 Provide upon completion of work, load balance report as directed in PART 1 - Submittals: phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.
- .2 Conduct and pay for following tests in accordance with Section 01 45 00 - Testing and Quality Control:
 - .1 Insulation resistance testing:
 - .1 Megger circuits, feeders and equipment up to 350 V with a 500 V instrument.
 - .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
 - .3 Check resistance to ground before energizing.
 - .4 Replace conductors as required.
- .3 Carry out tests in presence of Departmental Representative.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.

3.7 FIRESTOPPING & SMOKE SEALS

- .1 Fire seal any penetrations for conduits or cables running between rooms or floors. Fire ratings of walls/floors are to be maintained utilizing a proper firestop system. Firestop systems are to be tested to ASTM E-814 criteria.
- .2 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.

3.8 FIREPROOFING

- .1 Where cables or conduits pass through floors and fire rated walls, pack space between wiring and sleeve fill with foam sealant system and seal with caulking compound conforming to CAN/CGSB 19.130M82.

3.9 AS-BUILT RECORD DRAWING BY CONTRACTOR

- .1 General: To be read in conjunction with Section 01 78 00 - Closeout Submittals.
- .2 Site Records:
 - .1 Obtain sets of white prints and mark thereon all changes as work progresses and as changes occur. Incorporate all information issued in Addenda, Site Instructions, Change Orders and all changes in actual installation as a result of site conditions and coordination. At the end of the project, obtain a copy of CAD files of tender documents and update the CAD files to reflect the As-Built conditions.
- .3 As-Built Drawings:
 - .1 Prior to start of testing, balancing and adjusting, finalize production of as-built drawings.
 - .2 Identify each drawing in lower right hand corner in letters at least 1/2" high as follows: AS-BUILT DRAWINGS (This drawing has been revised to show electrical systems as installed) (Signature of Contractor) (Date)
 - .3 Submit to the Departmental Representative for approval and make all corrections as directed.
 - .4 Testing, balancing and adjusting to be performed using as-built drawings.
 - .5 Hand over 100 % updated CAD files and one hard copy of as-built drawings with Operating and Maintenance Manuals.

3.10 CLEANING

- .1 As per Section 01 74 11 – Cleaning.
- .2 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .3 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

3.11 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 SUMMARY

- .1 This Section includes requirements for selective demolition and removal of electrical components, including removal of conduit, junction boxes, and panels to source (home run removal) and incidentals required to complete work described in this Section.

1.2 RELATED REQUIREMENTS

- .1 Division 01 – General Requirements.
- .2 Section 26 05 00 – Common Work Results – Electrical

1.3 DEFINITIONS

- .1 Demolish: Detach items from existing construction and legally dispose of items off site, unless indicated as removed and salvaged, or removed and reinstalled.
- .2 Remove: Planned deconstruction and disassembly of electrical items from existing construction including removal of conduit, junction boxes, cabling and wiring from electrical component to panel taking care not to damage adjacent assemblies designated to remain; legally dispose of items off site, unless indicated as removed and salvaged, or removed and reinstalled.
- .3 Remove and Salvage: Detach items from existing construction and deliver them to Departmental Representative ready for reuse.
- .4 Remove and Reinstall: Detach items from existing construction, prepare them for reuse, and reinstall them where indicated.
- .5 Existing to Remain: Existing items of construction that are not removed and that are not otherwise indicated as being removed and salvaged, or removed and reinstalled.
- .6 Hazardous Substances: Dangerous substances, dangerous goods, hazardous commodities and hazardous products may include asbestos, mercury and lead, PCB's, poisons, corrosive agents, flammable substances, radioactive substances, or other material that can endanger human health or wellbeing or environment if handled improperly as defined by Federal Hazardous Products Act (RSC 1985) including latest amendments.

1.4 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Action Submittals: Provide in accordance with Section 01 33 00– Submittal Procedures before starting work of this Section:
 - .1 Construction Waste Management Plan (CWM Plan): Submit plan addressing opportunities for reduction, reuse, or recycling of materials prepared in accordance with Section 01 74 19– Construction Waste Management and Disposal.
 - .2 Landfill Records: Indicate receipt and acceptance of selective demolition waste and hazardous wastes by a landfill facility licensed to accept hazardous wastes.

1.5 SITE CONDITIONS

- .1 Existing Conditions: Condition of materials identified as being salvaged or demolished are based on their observed condition.
- .2 Discovery of Hazardous Substances: It is not expected that Hazardous Substances will be encountered in Work; immediately notify Departmental Representative if materials suspected of containing hazardous substances are encountered and perform following activities:
 - .1 Refer to Section 01 41 00– Regulatory Requirements for directives associated with specific material types.
 - .2 Hazardous substances will be as defined in Hazardous Products Act.
 - .3 Stop work in area of suspected hazardous substances.
 - .4 Take preventative measures to limit users' and workers' exposure, provide barriers and other safety devices and do not disturb.
 - .5 Hazardous substances will be removed under a separate contract or as a change to Work.
 - .6 Proceed only after written instructions have been received from Departmental Representative.

PART 2 PRODUCTS

2.1 NOT USED REPAIR MATERIALS

- .1 General Patching and Repair Materials: Refer to Section 02 41 19.23 for listing of patching and repair materials incidental to removal or demolition of components associated with work of this Section.
- .2 Electrical Repair Materials: Use only new materials, CSA or ULC labelled as appropriate and matching components remaining after work associated with components identified for removal or demolition are completed.
- .3 Firestopping Repair Materials: Use firestopping materials compatible with existing firestopping systems where removal or demolition work affects rated assemblies, restore to match existing fire rated performance.

2.2 SALVAGE AND DEBRIS MATERIALS

- .1 Material Ownership: Demolished materials become Contractor's property and will be removed from Project site; except for items indicated as being reused, salvaged, reinstalled, or otherwise indicated to remain Departmental Representative's property.
- .2 Salvaged Materials: Carefully remove materials designated for salvage and store in a manner to prevent damage or devaluation of materials in accordance with Section 02 42 00 and as follows:
 - .1 Leave main electrical distribution panel in place; panel can be used for temporary construction power for this and subsequent contracts in accordance with Section 01 50 00– Temporary Facilities.

PART 3 EXECUTION

3.1 PREPARATION

- .1 Protection of Existing Systems to Remain: Protect systems and components indicated to remain in place during selective demolition operations and as follows:
 - .1 Prevent movement and install bracing to prevent settlement or damage of adjacent services and parts of existing buildings scheduled to remain.
 - .2 Notify Departmental Representative and cease operations where safety of buildings being demolished, adjacent structures or services appears to be endangered and await additional instructions before resuming demolition work specified in this Section.
 - .3 Prevent debris from blocking drainage inlets.
 - .4 Protect mechanical systems that will remain in operation.
- .2 Protection of Building Occupants: Sequence demolition work so that interference with use of the building by Departmental Representative and users is minimized and as follows:
 - .1 Prevent debris from endangering safe access to and egress from occupied buildings.
 - .2 Notify Departmental Representative and cease operations where safety of occupants appears to be endangered and await additional instructions before resuming demolition work specified in this Section.

3.2 EXECUTION

- .1 Demolition: Coordinate requirements of this Section with information contained as follows:
 - .1 Disconnect electrical circuits and panel feeders; maintain electrical service and main distribution panel as is, ready for subsequent Work.
 - .2 Remove existing luminaires, electrical devices and equipment including associated conduits, boxes, wiring, and similar items unless specifically noted otherwise.
 - .3 Disconnect and remove existing fire alarm system including associated conduits, boxes, wiring, and similar items unless specifically noted otherwise.
 - .4 Disconnect and remove communication systems including associated conduits, boxes, cabling, and similar items unless specifically noted otherwise.
 - .5 Disconnect and remove telephone outlets, associated conduit, cabling and sub terminal backboards and related accessories; maintain telephone service and main terminal backboard as is.
 - .6 Perform demolition work in a neat and workmanlike manner:
 - .1 Remove tools or equipment after completion of work and leave site clean and ready for subsequent renovation work.
 - .2 Repair and restore damages caused as a result of work of this Section to match existing materials and finishes.

- .7 Disconnect panel feeders back to main distribution panel and re label respective circuit breaker as "SPARE".
- .8 Place weatherproof blank cover plates on exterior outlet boxes remaining after demolition and removal activities.
- .9 Remove existing conduits, boxes, cabling and wiring associated with removed luminaires, electrical devices and equipment.
- .10 Grind off conduits and make flush with surface of concrete where conduits are cast into concrete; seal open ends of conduit with silicone sealant and leave in place.
- .11 Seal open ends of conduit with silicone sealant and leave in place where they are inaccessible or cannot be removed without damaging adjacent construction.

3.3 CLOSEOUT ACTIVITIES

- .1 Demolition Waste Disposal: Arrange for legal disposal and remove demolished materials to accredited provincial landfill site or alternative disposal site (recycle centre) except where explicitly noted otherwise for materials being salvaged for re use in new construction in accordance with Section 02 42 00.

END

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Materials and installation for wire and box connectors.

1.2 RELATED SECTIONS

- .1 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.3 REFERENCES

- .1 Canadian Standards Association (CSA International) Latest Edition of the following:
 - .1 CAN/CSA-C22.2, No. 18, Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware.
 - .2 CSA C22.2 No. 65 Wire Connectors.
- .2 Electrical and Electronic Manufacturers' Association of Canada (EEMAC) Latest Edition of the following:
 - .1 EEMAC 1Y-2, 1961 Bushing Stud Connectors and Aluminum Adapters (1200 Ampere Maximum Rating).
- .3 National Electrical Manufacturers Association (NEMA) Latest Edition.

1.4 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material for recycling in accordance with Waste Management Plan.
- .4 Divert unused wiring materials from landfill to metal recycling facility as approved by Departmental Representative.

PART 2 PRODUCTS

2.1 MATERIALS

- .1 Pressure type wire connectors with current carrying parts of copper sized to fit copper conductors as required.
- .2 Fixture type splicing connectors with current carrying parts of copper sized to fit copper conductors 10 AWG or less.

- .3 Bushing stud connectors to consist of:
 - .1 Connector body and stud clamp for stranded, copper or conductors.
 - .2 Clamp for stranded copper conductors.
 - .3 Stud clamp bolts.
 - .4 Bolts for copper conductors.
 - .5 Bolts for aluminum conductors.
 - .6 Sized for conductors as indicated.
- .4 Clamps or connectors for armoured cable, flexible conduit, as required.
- .5 Joints required in connecting all wiring up to and including # 8, are to be made using twist-on connectors.
- .6 Joints for all other wiring shall be made using colour-keyed compression type connectors. A first layer of tape shall be compound type followed by a layer of vinyl electrical tape. Vinyl tape shall be 7mm thick, flame-retardant all-weather vinyl-insulating tape for cable splices up to 600V, suitable for 0-220°F environments and CSA certified, RoHS Compliant.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Remove insulation carefully from ends of conductors and:
 - .1 Apply coat of zinc joint compound on aluminum conductors prior to installation of connectors.
 - .2 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2No.65.
 - .3 Install fixture type connectors and tighten. Replace insulating cap.
 - .4 Install bushing stud connectors in accordance with EEMAC 1Y-2 NEMA.

END

PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 26 05 20 - Wire and Box Connectors - 0 - 1000 V.

1.2 REFERENCES

- .1 CSA C22.2 No .0.3-96, Test Methods for Electrical Wires and Cables Latest Edition.
- .2 CAN/CSA-C22.2 No. 131-M89 (R1994), Type TECK 90 Cable Latest Edition.

1.3 PRODUCT DATA

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

1.4 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal, and with the Waste Reduction Workplan.
- .2 Collect and separate plastic, paper packaging and corrugated cardboard in accordance with Waste Management Plan.
- .3 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 PRODUCTS

2.1 BUILDING WIRES

- .1 Conductors: stranded for 10 AWG and larger. Minimum size: 12 AWG.
- .2 Copper conductors: size as indicated, with 600V insulation of chemically cross-linked thermosetting polyethylene material rated RW90.
- .3 Neutral conductor insulated for 600V shall be continuous with no fuses, switches, or breaks of any kind.

- .4 The voltage drop in no case shall exceed 3% of the line volts for 15A, 120V branch circuits. The following table shall be used:

Branch Circuit Run From Panel to Load Incl. Vertical Drops	Branch Circuit Conductor Size	Dedicated Neutral	Common Neutral	Bond Wire Size
24.4M	#12	#12	#10	#14
24.4M - 38.1M	#10	#10	#8	#12
38.2M - 56.4M	#8	#8	#6	#10
56.4M – 103.5M	#6	#6	#4	#8

- .5 Oversized #10 AWG branch circuit wiring conductors to be extended to outlet box of device they feed. Oversized #8 AWG branch circuit wiring conductors to be extended from panelboard to junction box located on wall or ceiling directly above receptacles. #8 AWG wire to be reduced to #10 AWG for vertical portion of drop only.
- .6 Voltage drop calculation: distance is measured to the last device along the conductor run.

2.2 TECK CABLE

- .1 Cable: to CAN/CSA-C22.2 No. 131.
- .2 Conductors:
- .1 Grounding conductor: copper.
 - .2 Circuit conductors: copper, size as indicated.
- .3 Insulation:
- .1 Type: ethylene propylene rubber.
 - .2 Chemically cross-linked thermosetting polyethylene rated type RW90, 600V.
- .4 Inner jacket: polyvinyl chloride material.
- .5 Armour: interlocking.
- .6 Overall covering: thermoplastic polyvinyl chloride material.
- .7 Fastenings:
- .1 Channel type supports for two or more cables at 1500 mm centers.
 - .2 Threaded rods: 6 mm dia. to support suspended channels.
- .8 Connectors:
- .1 Watertight, approved for TECK cable.

2.3 ARMOURED CABLES

- .1 Conductors: insulated, copper, size as indicated.
- .2 Type: AC90.

- .3 Armour: interlocking type fabricated from galvanized steel strip.
- .4 Connectors: Steel set screw.
- .5 AC-90 cables may only be used:
 - .1 As individual cable drops from junction boxes to fixtures provided they are not longer than 1.5M, do not run from room to room and are adequately supported.
 - .2 The wiring of outlets or devices in cabinetry where it is impractical to install conduit.

PART 3 EXECUTION

3.1 INSTALLATION OF BUILDING WIRES

- .1 Install wiring as follows:
 - .1 In conduit systems in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings
 - .2 Use vibration proof expanding spring wire connectors for No. 10 and smaller.

3.2 INSTALLATION OF TECK CABLE 0 -1000 V

- .1 Install cables only where explicitly indicated on plans.
 - .1 Group cables wherever possible on channels.
- .2 Terminate cables in accordance with Section 26 05 20 - Wire and Box Connectors - 0 - 1000V.

3.3 INSTALLATION OF ARMoured CABLES

- .1 Group cables wherever possible.
- .2 Terminate cables in accordance with Section 26 05 20 - Wire and Box Connectors - 0 - 1000 V.
- .3 The installation of AC90 cables shall be limited to the following:
 - .1 As final connection to light fixtures from junction box.
 - .2 Fixture drops are to run from the junction box in the respective room and not to fixtures in other rooms.
 - .3 Fixture drops shall be from the side of the outlet boxes and not through the coverplate. Maximum of four fixture drops from any single junction box.
- .4 AC 90 cables shall be secured within one foot of the junction boxes.
- .5 Support and securing of AC 90 cables shall not be derived from suspended ceiling support wires or by laying on top of the ceiling.

END

PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .3 Section 26 05 00 - Common Work Results - Electrical.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/Institute of Electrical and Electronics Engineers (IEEE) Latest Edition of the following:
 - .1 ANSI/IEEE 837, Qualifying Permanent Connections Used in Substation Grounding.
- .2 Canadian Standards Association, (CSA International) Latest Edition.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material, in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 PRODUCTS

2.1 EQUIPMENT

- .1 Grounding conductors: bare stranded copper, soft annealed, size as indicated.
- .2 Insulated grounding conductors: green, type RW90.
- .3 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
 - .1 Grounding and bonding bushings.
 - .2 Protective type clamps.

- .3 Bolted type conductor connectors.
- .4 Thermit welded type conductor connectors.
- .5 Bonding jumpers, straps.
- .6 Pressure wire connectors.

PART 3 EXECUTION

3.1 INSTALLATION GENERAL

- .1 Install complete permanent, continuous grounding system including, conductors, connectors, accessories. Where EMT is used, run ground wire in conduit.
- .2 Install connectors in accordance with manufacturer's instructions.
- .3 Protect exposed grounding conductors from mechanical injury.
- .4 Use mechanical connectors for grounding connections to equipment provided with lugs.
- .5 Soldered joints not permitted.
- .6 Install bonding wire for flexible conduit, connected at both ends to grounding bushing, solderless lug, clamp or cup washer and screw. Neatly cleat bonding wire to exterior of flexible conduit.
- .7 Make grounding connections in radial configuration only, with connections terminating at single grounding point. Avoid loop connections.
- .8 Bond single conductor, metallic armoured cables to cabinet at supply end, and provide non-metallic entry plate at load end.

3.2 EQUIPMENT GROUNDING

- .1 Install grounding connections to typical equipment included in, but not necessarily limited to following list. Service equipment, transformers, switchgear, duct systems, frames of motors, motor control centres, starters, control panels, building steel work, generators, elevators, distribution panels, outdoor lighting, cable tray, access floor pedestals, and static flooring.

END

PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.

1.2 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material, in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 PRODUCTS

2.1 SUPPORT CHANNELS

- .1 U shape, size 41 x 41 mm, 2.5 mm thick, surface mounted or suspended.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Secure equipment to hollow or solid masonry, tile and plaster surfaces with lead anchors or nylon shields.
- .2 Secure equipment to poured concrete with expandable inserts.
- .3 Secure equipment to hollow masonry walls or suspended ceilings with toggle bolts.
- .4 Secure surface mounted equipment with twist clip fasteners to inverted T bar ceilings. Ensure that T bars are adequately supported to carry weight of equipment specified before installation.
- .5 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.
- .6 Fasten exposed conduit or cables to building construction or support system using straps.

- .1 One-hole steel straps to secure surface conduits and cables 50 mm and smaller.
- .2 Two-hole steel straps for conduits and cables larger than 50 mm.
- .3 Beam clamps to secure conduit to exposed steel work.
- .7 Suspended support systems.
 - .1 Support individual cable or conduit runs with 6 mm diameter threaded rods and spring clips.
 - .2 Support 2 or more cables or conduits on channels supported by 6 mm diameter threaded rod hangers where direct fastening to building construction is impractical.
- .8 For surface mounting of two or more conduits use channels at 1.5 m on centre spacing.
- .9 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.
- .10 Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
- .11 Do not use wire lashing or perforated strap to support or secure raceways or cables.
- .12 Do not use supports or equipment installed for other trades for conduit or cable support except with permission of other trade and approval of Departmental Representative.
- .13 Install fastenings and supports as required for each type of equipment cables and conduits, and in accordance with manufacturer's installation recommendations.
- .14 Powder actuated fasteners are not acceptable.

END

PART 1 GENERAL

1.1 SHOP DRAWINGS AND PRODUCT DATA

- .1 Division 01 – General Requirements.
- .2 Submit shop drawings and product data for cabinets in accordance with Section 01 33 00 - Submittal Procedures.

1.2 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal, and with the Waste Reduction Workplan.
- .2 Collect and separate plastic, paper packaging and corrugated cardboard in accordance with Waste Management Plan.
- .3 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 PRODUCTS

2.1 SPLITTERS

- .1 Construction: sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.
- .2 Terminations: main and branch lugs to match required size and number of incoming and outgoing conductors as indicated.
- .3 Spare Terminals: minimum three spare terminals on each connection or lug block sized less than 400 A.

2.2 JUNCTION AND PULL BOXES

- .1 Welded steel construction with gasketed screw-on flat covers for surface mounting.
- .2 Covers with 25 mm minimum extension all around, for flush-mounted pull and junction boxes.

2.3 CABINETS

- .1 Type E: sheet steel, hinged door and return flange overlapping sides, handle, lock and catch, for surface mounting.

- .2 Type T: sheet steel cabinet, with hinged door, latch, lock, 2 keys, containing 19 mm G1S plywood backboard for surface mounting.

PART 3 EXECUTION

3.1 SPLITTER INSTALLATION

- .1 Mount plumb, true and square to building lines.
- .2 Extend splitters full length of equipment arrangement except where indicated otherwise.

3.2 JUNCTION, PULL BOXES AND CABINETS INSTALLATION

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Mount cabinets with top not higher than 2 m above finished floor.
- .3 Install terminal block as indicated in Type T cabinets.
- .4 Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run or 2-90° bends between pull boxes.

3.3 IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Install size 2 identification labels indicating system name, voltage and phase.

END

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Division 01 – General Requirements.
- .2 26 05 00 – Common Work Results for Electrical.

1.2 REFERENCES

- .1 CSA C22.1, Canadian Electrical Code, Part 1, Latest Edition.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal, and with the Waste Reduction Workplan.
- .2 Collect and separate plastic, paper packaging and corrugated cardboard in accordance with Waste Management Plan.

PART 2 PRODUCTS

2.1 OUTLET AND CONDUIT BOXES GENERAL

- .1 Size boxes in accordance with CSA C22.1-18.
- .2 102 mm square or larger outlet boxes as required for special devices.
- .3 Gang boxes where wiring devices are grouped.
- .4 Blank cover plates for boxes without wiring devices.
- .5 347 V outlet boxes for 347 V switching devices.
- .6 Combination boxes with barriers where outlets for more than one system are grouped.

2.2 SHEET STEEL OUTLET BOXES

- .1 Electro-galvanized steel single and multi gang flush device boxes for flush installation, minimum size 76 x 50 x 38 mm or as indicated. 102 mm square outlet boxes when more than one conduit enters one side with extension and plaster rings as required.
- .2 Electro-galvanized steel utility boxes for outlets connected to surface-mounted EMT conduit, minimum size 102mm x 54 mm x 48 mm.
- .3 102 mm square or octagonal outlet boxes for lighting fixture outlets.

- .4 102 mm square outlet boxes with extension and plaster rings for flush mounting devices in finished plaster walls.
- .5 Extension and tile rings for flush mounting devices in finished walls.

2.3 MASONRY BOXES

- .1 Electro-galvanized steel masonry single and multi gang boxes for devices flush mounted in exposed block walls.

2.4 CONCRETE BOXES

- .1 Electro-galvanized sheet steel concrete type boxes for flush mount in concrete with matching extension and plaster rings as required.

2.5 CONDUIT BOXES

- .1 Cast FS or boxes with factory-threaded hubs and mounting feet for surface wiring of switches and receptacle.

2.6 FITTINGS FOR FLEXIBLE CONDUIT

- .1 Threaded type steel couplings and fittings.
- .2 Bushing and connectors with nylon insulated throats.
- .3 Knock-out fillers to prevent any debris.
- .4 Conduit outlet bodies for conduit up to 35mm and pull boxes for larger conduits.
- .5 Double locknuts and insulated bushings on sheet metal boxes.
- .6 Compression nut, grounding ferrule, sealing ring and body shop.

2.7 FITTINGS FOR THIN WALL CONDUIT

- .1 Steel set screw type connectors and couplings.
- .2 Double locknuts and insulated bushings on sheet metal boxes.

2.8 FITTINGS IN WET OR DAMP LOCATIONS

- .1 Watertight fittings on conduit in wet or damp locations.

2.9 FITTINGS - GENERAL

- .1 Bushing and connectors with nylon insulated throats.
- .2 Knock-out fillers to prevent entry of debris.
- .3 Conduit outlet bodies for conduit up to 32 mm and pull boxes for larger conduits.
- .4 Double locknuts and insulated bushings on sheet metal boxes.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Support boxes independently of connecting conduits.
- .2 Fill boxes with paper, sponges or foam or similar approved material to prevent entry of debris during construction. Remove upon completion of work.
- .3 For flush installations mount outlets flush with finished wall using plaster rings to permit wall finish to come within 6 mm of opening.
- .4 Provide correct size of openings in boxes for conduit, mineral insulated and armoured cable connections. Reducing washers are not allowed.

END

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Division 01 – General Requirements.
- .2 26 05 00 – Common Work Results for Electrical.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA) Latest Edition of the following:
 - .1 CAN/CSA C22.2, Outlet Boxes, Conduit Boxes, and Fittings and Associated Hardware.
 - .2 CSA C22.2 No. 45, Rigid Metal Conduit.
 - .3 CSA C22.2 No. 56, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
 - .4 CSA C22.2 No. 83, Electrical Metallic Tubing.
 - .5 CSA C22.2 No. 211.2, Rigid PVC (Unplasticized) Conduit.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal, and with the Waste Reduction Workplan.
- .2 Place materials defined as hazardous or toxic waste in designated containers.
- .3 Ensure emptied containers are sealed and stored safely for disposal away from children.
- .4 Collect and separate plastic, paper packaging and corrugated cardboard in accordance with Waste Management Plan.

PART 2 PRODUCTS

2.1 CONDUITS

- .1 Rigid metal conduit: to CSA C22.2 No. 45, galvanized steel threaded.
- .2 Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings.
- .3 Rigid pvc conduit: to CSA C22.2 No. 211.2.
- .4 Flexible metal conduit: to CSA C22.2 No. 56, steel and liquid-tight flexible metal.

2.2 CONDUIT FASTENINGS

- .1 One-hole steel straps to secure surface conduits 50mm and smaller. Two hole steel straps for conduits larger than 50mm.
- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Channel type supports for two or more conduits at 1.5m oc.
- .4 Threaded rods, 6 mm dia., to support suspended channels.

2.3 CONDUIT FITTINGS

- .1 Galvanized rigid steel couplings shall be used with all rigid steel threaded conduit.
- .2 Rain tight EMT connectors shall be used on "vertical" sections of conduit runs where terminating into tops of electrical equipment incorporating drip shields or hoods.
- .3 Fittings: Use steel set screw connectors for EMT. Coating: same as conduit.
- .4 Factory "ells" where 90° bends are required for 27mm and larger conduits.
- .5 Couplings and connectors for PVC rigid conduit shall be CSA approved for their respective use.
- .6 Connectors for flexible conduit, shall be set screw galvanized steel.
- .7 Connectors for liquid tight flexible conduit shall be water tight, compression type galvanized steel.
- .8 Threaded plastic or metal bushings to be installed on all EMT connectors sizes 35mm and larger.
- .9 Fittings: manufactured for use with conduit specified. Coating: same as conduit.
- .10 Factory "ells" where 90° bends are required for 25 mm and larger conduits.

2.4 FISH CORD

- .1 Polypropylene.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.

- .2 Conceal conduits except in mechanical and electrical service rooms and in unfinished areas.
- .3 Use rigid galvanized steel threaded conduit for branch circuits in hazardous areas.
- .4 EMT shall be installed as a complete system.
- .5 Support of electrical systems raceway shall be independent of any type of suspended ceiling support rods, wires, etc. and mechanical piping or duct systems.
- .6 Use electrical metal tubing (EMT) for all work, unless otherwise indicated, for panelboard feeders, branch circuit wiring, fire alarm and communications, etc., where not installed underground unless specifically indicated otherwise. Provide a separate green ground for all conduit systems, including E.M.T.
- .7 Use rigid pvc conduit underground. Include a separate ground wire.
- .8 Flexible Metal Conduit:
 - .1 Use flexible metal conduit for connection to surface or recessed fluorescent fixtures.
 - .2 Flexible metal conduit, permitted above T-bar ceilings, for drops to various fire alarm devices mounted on flush outlet boxes in finished ceiling. Minimum size of flexible conduit: 21mm, Maximum length of drop: 1.5 meters.
 - .3 For connection to access Floor Boxes and under floor smoke detectors, include a separate ground wire.
- .9 Use flexible metal conduit for connection to motors in dry areas connection to recessed incandescent fixtures without a prewired outlet box connection to surface or recessed fluorescent fixtures work in movable metal partitions.
- .10 Use liquid tight flexible metal conduit for connection to motors or vibrating equipment, furniture and transformers. Include a separate ground wire.
- .11 Use explosion proof flexible connection for connection to explosion proof motors.
- .12 Install conduit sealing fittings in hazardous areas. Fill with compound.
- .13 Minimum conduit size for lighting and power circuits: 21mm.
- .14 Bend conduit cold. Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .15 Mechanically bend steel conduit over 21mm dia.
- .16 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .17 Install fish cord in empty conduits.

- .18 Run 2-25 mm spare conduits up to ceiling space and 2-25 mm spare conduits down to ceiling space from each flush panel. Terminate these conduits in 152 x 152 x 102 mm junction boxes in ceiling space or in case of an exposed concrete slab, terminate each conduit in surface type box.
- .19 Remove and replace blocked conduit sections. Do not use liquids to clean out conduits.
- .20 Dry conduits out before installing wire.
- .21 Securely fasten in place within 1 meter of each outlet box, junction box, cabinet, coupling or fitting, maximum spacing between supports as follows:
 - .1 1.5 meters for 21mm EMT.
 - .2 2.1 meters for 27mm and 35mm EMT.
 - .3 3 meters for 41mm EMT and larger.
- .22 Ground Wires:
- .23 Provide a separate green ground wire in all conduit, including EMT.

3.2 SURFACE CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Run conduits in flanged portion of structural steel.
- .3 Group conduits wherever possible on suspended or surface channels.
- .4 Do not pass conduits through structural members except as indicated.
- .5 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.

3.3 CONCEALED CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Do not install horizontal runs in masonry walls.
- .3 Do not install conduits in terrazzo or concrete toppings.

3.4 CONDUITS IN CAST-IN-PLACE CONCRETE

- .1 Conduits shall not be installed in slabs.

3.5 CONDUITS IN CAST-IN-PLACE SLABS ON GRADE

- .1 Conduits shall not be installed in slabs.

3.6 CONDUITS UNDERGROUND

- .1 Slope conduits to provide drainage.
- .2 Waterproof joints (pvc excepted) with heavy coat of bituminous paint.

END

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Materials and components for dry type transformers up to 600 V primary, equipment identification and transformer installation.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 26 05 00 - Common Work Results - Electrical.

1.3 REFERENCES

- .1 Canadian Standards Association (CSA International) Latest Edition of the following:
 - .1 CAN/CSA-C22.2 No.47-M90, Air-Cooled Transformers (Dry Type).
 - .2 CSA C9, Dry-Type Transformers.
 - .3 CSA C802.2 Maximum Losses for Distribution, Power and Dry-Type Transformers.

1.4 PRODUCT DATA

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused wiring materials from landfill to metal recycling facility as approved by Departmental Representative.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 PRODUCTS

2.1 TRANSFORMERS

- .1 Use transformers of one manufacturer throughout project and in accordance with CAN/CSA-C22.2, No.47, CSA-C9, and CSA C802.2.

- .2 All 3 Phase transformers shall be constructed with 3 windings and a single coil, 2 winding transformers are not acceptable.
- .3 Design 1: General Purpose.
 - .1 Type: ANN.
 - .2 3 phase, 600 V input, 208/120 V output, 60 Hz.
 - .3 Copper Windings
 - .4 Voltage taps: 4 - 2.5%, 2-FCBN, 2-FCAN.
 - .5 Insulation: Class H, 220 degrees C temperature rise.
 - .6 Basic Impulse Level (BIL): 1.2kv class.
 - .7 Hipot: 4kv.
 - .8 Electrostatic Shielding.
 - .9 Impedance at 170 degrees C: 4 - 4.2%
 - .10 Enclosure: EEMAC 3R, removable metal front panel, complete with sprinkler proof hood.
 - .11 Mounting: floor or wall, as indicated.
 - .12 Finish: ASA 61 Light Grey

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Label size: 7.
- .3 Nameplate wording: Transformer No., Source; Equipment fed.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Mount dry type transformers up to 75 kVA as indicated.
- .2 Mount dry type transformers above 75 kVA on floor.
- .3 Ensure adequate clearance around transformer for ventilation.
- .4 Install transformers in level upright position.
- .5 Remove shipping supports only after transformer is installed and just before putting into service.
- .6 Loosen isolation pad bolts until no compression is visible.
- .7 Make primary and secondary connections in accordance with wiring diagram.
- .8 Energize transformers after installation is complete.

- .9 Make conduit entry into bottom 1/3 of transformer enclosure.

3.2 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 RELATED REQUIREMENTS

- .1 Division 01 – General Requirements.
- .2 Section 26 05 00 – Common Work Results – Electrical.

PART 2 PRODUCTS

2.1 SWITCHBOARDS

- .1 Switchboards are existing to remain, to be revised as indicated on plans.
- .2 New fusible switch shall match existing manufacturer and interrupting capacity of existing switchboard.
- .3 Existing switchboard is as follows:
 - .1 Main Switchboard:
 - .1 Westinghouse 08B351200.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Remove and install new circuit breakers as indicated on floor plans.

3.2 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Materials and installation for standard and custom breaker type panelboards.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .3 Section 06 10 11 - Rough Carpentry - Short Form: Plywood Backboard.
- .4 Section 26 05 00 - Common Work Results - Electrical.
- .5 Section 26 28 21 - Moulded Case Circuit Breakers.
- .6 Section 26 28 24 – Transient Voltage Surge Suppressors.

1.3 REFERENCES

- .1 Canadian Standards Association (CSA International) Latest Edition of the following:
 - .1 CSA C22.2No.29, Panelboards and enclosed Panelboards.

1.4 SHOP DRAWINGS

- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Drawings to include electrical detail of panel, branch breaker type, quantity, ampacity and enclosure dimension.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal and wiring materials from landfill to metal recycling facility approved by Departmental Representative.

PART 2 PRODUCTS

2.1 PANELBOARDS

- .1 Panelboards: to CSA C22.2No.29 and product of one manufacturer.

- .1 Install circuit breakers in panelboards before shipment.
- .2 In addition to CSA requirements manufacturer's nameplate must show fault current that panel including breakers has been built to withstand.
- .2 250 and 600 V panelboards: bus and breakers rated for A (symmetrical) and interrupting capacity as indicated on plans.
- .3 Sequence phase bussing with odd numbered breakers on left and even on right, with each breaker identified by permanent number identification as to circuit number and phase.
- .4 Panelboards: mains, number of circuits, and number and size of branch circuit breakers as indicated.
- .5 Two keys for each panelboard and key panelboards alike.
- .6 Copper bus with neutral of same ampere rating as mains.
- .7 Mains: suitable for bolt-on breakers.
- .8 Trim with concealed front bolts and hinges.
- .9 Trim and door finish: baked grey enamel.
- .10 Panel complete with sprinkler-proof hoods.

2.2 BREAKERS

- .1 Breakers: to Section 26 28 21 - Moulded Case Circuit Breakers.
- .2 Breakers with thermal and magnetic tripping in panelboards except as indicated otherwise.
- .3 Main breaker: separately mounted on top or bottom of panel to suit cable entry. When mounted vertically, down position should open breaker.
- .4 Lock-on devices for 10% of 15 to 20 A breakers installed as indicated. Turn over unused lock-on devices to Departmental Representative.
- .5 Lock-on devices for fire alarm, emergency lighting, night lighting and exit lighting circuits.

2.3 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Nameplate for each panelboard size 4 engraved as indicated.
- .3 Nameplate for each circuit in distribution panelboards size 2 engraved as indicated.
- .4 Complete circuit directory with typewritten legend showing location and load of each circuit.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Locate panelboards as indicated and mount securely, plumb, true and square, to adjoining surfaces.
- .2 Install surface mounted panelboards on plywood backboards in accordance with Section 06 10 10 - Rough Carpentry. Where practical, group panelboards on common backboard.
- .3 Mount panelboards to height specified in Section 26 05 00 - Common Work Results - Electrical or as indicated.
- .4 Connect loads to circuits.
- .5 Connect neutral conductors to common neutral bus with respective neutral identified.

3.2 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Switches, receptacles, wiring devices, cover plates and their installation.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 26 05 00 - Common Work Results - Electrical.

1.3 REFERENCES

- .1 Canadian Standards Association (CSA International) Latest Edition of the following:
 - .1 CSA-C22.2 No.42, General Use Receptacles, Attachment Plugs and Similar Devices.
 - .2 CSA-C22.2 No.42.1-00, Cover Plates for Flush-Mounted Wiring Devices (Bi-national standard, with UL 514D).
 - .3 CSA-C22.2 No.55, Special Use Switches.
 - .4 CSA-C22.2 No.111-00, General-Use Snap Switches (Bi-national standard, with UL 20, twelfth edition).

1.4 SHOP DRAWINGS AND PRODUCT DATA

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal and wiring materials from landfill to metal recycling facility as approved by Departmental Representative.

PART 2 PRODUCTS

2.1 SWITCHES

- .1 15 A, 120 V, single pole, switches to: CSA-C22.2 No.55 and CSA-C22.2 No.111.

- .2 Manually-operated general purpose ac switches with following features:
 - .1 Terminal holes approved for No. 10 AWG wire.
 - .2 Silver alloy contacts.
 - .3 Urea or melamine moulding for parts subject to carbon tracking.
 - .4 Suitable for back and side wiring.
 - .5 Ivory toggle.
- .3 Toggle operated locking fully rated for tungsten filament and fluorescent lamps, and up to 80% of rated capacity of motor loads.
- .4 Switches of one manufacturer throughout project.

2.2 RECEPTACLES

- .1 Duplex receptacles, CSA type 5-15 R, 125 V, 15 A, U ground, to: CSA-C22.2 No.42 with following features:
 - .1 White urea moulded housing.
 - .2 Suitable for No. 10 AWG for back and side wiring.
 - .3 Break-off links for use as split receptacles.
 - .4 Eight back wired entrances, four side wiring screws.
 - .5 Triple wipe contacts and rivetted grounding contacts.
- .2 Single receptacles CSA type 5-15 R, 125 V, 15 A, U ground with following features:
 - .1 Colored receptacles with matching cover plates as follows:
 - Red – Emergency
 - Blue – Surge Protected
 - White for any others
 - .2 Suitable for No. 10 AWG for back and side wiring.
 - .3 Four back wired entrances, 2 side wiring screws.
- .3 Other receptacles with ampacity and voltage as indicated.
- .4 Receptacles of one manufacturer throughout project.

2.3 COVER PLATES

- .1 Cover plates for wiring devices to: CSA-C22.2 No.42.1.
- .2 Cover plates from one manufacturer throughout project.
- .3 Sheet steel utility box cover for wiring devices installed in surface-mounted utility boxes.
- .4 Cover plates for all specified receptacles shall be thermoplastic for wiring devices mounted in flush-mounted outlet box.
- .5 Sheet metal cover plates for wiring devices mounted in surface-mounted FS or FD type conduit boxes.

- .6 Weatherproof double lift spring-loaded cast aluminum cover plates, complete with gaskets for duplex receptacles as indicated.
- .7 Weatherproof spring-loaded cast aluminum cover plates complete with gaskets for single receptacles or switches.
- .8 All cover plates to have Lamacoid nameplates.
- .9 Identification:
 - .1 All housekeeping receptacles throughout including those located in corridors, mechanical, electrical rooms, etc., in addition to non-housekeeping types in labs, offices, collegial spaces and lobbies, to each have individual "Lamacoid" nameplate installed on wall directly above and abutting to top of its receptive receptacle plate, with information as indicated in item .2 below.
 - .2 Each "Lamacoid" plate to have designated panel numbers and/or letters, circuit no(s) and any other information as may be deemed necessary. Each conductor within receptacle outlet box to have same panel and circuit numbers as identifying "Lamacoid" plate, installed on wires as close as possible to where termination takes place on receptacle using "Panduit" write-on, self-laminating labels Nos. PLD-1 and PLD-2 or approved equal.

2.4 SPECIAL WIRING DEVICES

- .1 Other receptacles with ampacity and voltage as indicated on drawings.

2.5 4-GANG FLOOR BOX

- .1 4-Gang floor box.
- .2 Cast iron construction.
- .3 Durable powder coat finish.
- .4 Internal barrier between power and communications.
- .5 Conduit Hubs.
- .6 Complete with devices as indicated on drawings.

2.6 IDENTIFICATION

- .1 Provide size 1 nameplate in accordance with Section 26 05 00 – Electrical General Requirement.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Switches:

- .1 Install single throw switches with handle in "UP" position when switch closed.
- .2 Install switches in gang type outlet box when more than one switch is required in one location.
- .3 Mount toggle switches at height in accordance with Section 26 05 00 - Common Work Results - Electrical as indicated.
- .2 Receptacles:
 - .1 Install receptacles in gang type outlet box when more than one receptacle is required in one location.
 - .2 Mount receptacles at height in accordance with Section 26 05 00 - Common Work Results - Electrical as indicated.
 - .3 Where split receptacle has one portion switched, mount vertically and switch upper portion.
- .3 Cover plates:
 - .1 Protect cover plate finish with paper or plastic film until painting and other work is finished.
 - .2 Install suitable common cover plates where wiring devices are grouped.
 - .3 Do not use cover plates meant for flush outlet boxes on surface-mounted boxes.

3.2 TESTS

- .1 Test each receptacle for polarity and retention of blades.
- .2 Submit a written report in tabulated form to the Departmental Representative.

3.3 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Materials for moulded-case circuit breakers.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 – Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .3 Section 26 05 00 – Common Work Results for Electrical.

1.3 REFERENCES

- .1 Canadian Standards Association (CSA International) Latest Edition of the following:
 - .1 CSA-C22.2 No. 5, Moulded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, tenth edition, and the second edition of NMX-J-266-ANCE).

1.4 SUBMITTALS

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Include time-current characteristic curves for breakers with ampacity of 100 A and over.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .3 Separate for reuse and recycling and place in designated containers Steel, Metal, Plastic waste in accordance with Waste Management Plan.

PART 2 PRODUCTS

2.1 BREAKERS GENERAL

- .1 Moulded-case circuit breakers: to CSA C22.2 No. 5.

- .2 Bolt-on moulded case circuit breaker: quick- make, quick-break type, for manual and automatic operation with temperature compensation for 40°C ambient.
- .3 Common-trip breakers: with single handle for multi-pole applications.
- .4 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting.
 - .1 Trip settings on breakers with adjustable trips to range from 3-8 times current rating.

2.2 THERMAL MAGNETIC BREAKERS DESIGN A

- .1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install circuit breakers as indicated.

3.2 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 01 45 00 - Quality Control.
- .4 Section 26 05 00 - Common Work Results - Electrical.

1.2 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit product data and shop drawings.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal and wiring materials from landfill to metal recycling facility approved by Departmental Representative.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 PRODUCTS

2.1 EQUIPMENT

- .1 Components comprising ground fault protective system to be of same manufacturer.

2.2 GROUND FAULT PROTECTOR UNIT

- .1 Self-contained with 15A/20A, 120 V circuit interrupter and duplex receptacle complete with:
 - .1 Solid state ground sensing device.
 - .2 Facility for testing and reset.
 - .3 CSA Enclosure 1, flush mounted with ivory face plate.
- .2 Demonstrate simulated ground fault tests on random receptacles as selected by the Departmental Representative.

- .3 Measure the amount of ground fault current required to trip and replace the receptacle if the current exceeds 5 ma.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Do not ground neutral on load side of ground fault relay. Provide a separate neutral for each circuit.
- .2 Pass phase conductors including neutral through zero sequence transformers.
- .3 Connect supply and load wiring to equipment in accordance with manufacturer's recommendations.

3.2 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results – Electrical.

3.3 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 SECTION INCLUDES

- .1 Materials and installation for fused and non-fused disconnect switches.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .3 Section 26 05 00 - Common Work Results - Electrical.

1.3 REFERENCES

- .1 Canadian Standards Association (CSA International) Latest Edition of the following:
 - .1 CAN/CSA C22.2 No.4, Enclosed Switches.
 - .2 CSA C22.2 No.39, Fuseholder Assemblies.

1.4 SUBMITTALS

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

1.5 HEALTH AND SAFETY

- .1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.6 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, and packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Separate for reuse and recycling and place in designated containers Steel Metal Plastic waste in accordance with Waste Management Plan.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 PRODUCTS

2.1 DISCONNECT SWITCHES

- .1 Fusible, non-fusible, horsepower rated disconnect switch in CSA Enclosure 1, to CAN/CSA C22.2 No.4 size as indicated.
- .2 Provision for padlocking in off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Quick-make, quick-break action.
- .5 ON-OFF switch position indication on switch enclosure cover.

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install disconnect switches complete with fuses if applicable, where indicated.

3.2 TESTING

- .1 Operate each disconnect switch to verify that the loads are disconnected.

END

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section: 26 05 00 – Common Work Results - Electrical

1.2 REFERENCE STANDARDS

- .1 CSA Group (CSA)
 - .1 CSA C22.2 No.14-18, Industrial Control Equipment.
- .2 National Electrical Manufacturers Association (NEMA)
 - .1 NEMA ICS 2-2003 (R2012) , Controllers, Contactors and Overload Relays Rated 600 V.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for contactors and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00- Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for contactors for incorporation into manual.
- .3 Include operating information required for start-up, synchronizing and shut-down of generating units.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00- Common Product Requirements with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect contactors from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 CONTACTORS

- .1 Contactors: to CSA C22.2 No.14.
- .2 Mechanically held controlled by pilot devices as indicated and rated for type of load controlled.
- .3 Definite purpose type, suitable for electric resistive loads.
- .4 Complete with 3 normally open auxiliary contacts unless indicated otherwise.
- .5 Mount in NEMA 1 Enclosure
- .6 Electrical Characteristics:
 - .1 Voltage: 575V, 3-phase, 60Hz.
 - .2 Rating: 20A.
 - .3 Coil Voltage: 24VAC.

2.2 EQUIPMENT IDENTIFICATION

- .1 Identify equipment in accordance with Section 26 05 00- Common Work Results for Electrical.
- .2 Size 4 nameplate indicating name of load controlled and electrical characteristics.

Part 3 Execution

3.1 INSTALLATION

- .1 Install contactors and connect power wires. Auxiliary control by Division 25
- .2 Identify contactors with nameplates or labels indicating panel and circuit number.

END OF SECTION

PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Division 01 – General Requirements.
- .2 Section 26 05 00 - Common Work Results - Electrical.

1.2 SHOP DRAWINGS AND PRODUCT DATA

- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Indicate:
 - .1 Mounting method and dimensions.
 - .2 Starter size and type.
 - .3 Layout of identified internal and front panel components.
 - .4 Enclosure types.
 - .5 Wiring diagram for each type of starter.
 - .6 Interconnection diagrams.

1.3 CLOSEOUT SUBMITTALS

- .1 Provide operation and maintenance data for motor starters for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
- .2 Include operation and maintenance data for each type and style of starter.

1.4 EXTRA MATERIALS

- .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Provide listed spare parts for each different size and type of starter:
 - .1 3 contacts, stationary.
 - .2 3 contacts, movable.
 - .3 1 contacts, auxiliary.
 - .4 1 control transformers.
 - .5 1 operating coil.
 - .6 2 fuses.
 - .7 10% indicating lamp bulbs used.

1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal, and with the Waste Reduction Workplan.
- .2 Place materials defined as hazardous or toxic waste in designated containers.

- .3 Ensure emptied containers are sealed and stored safely for disposal away from children.

PART 2 PRODUCTS

2.1 MATERIALS

- .1 Starters: to EEMAC E14-1.
- .2 Half size starters not acceptable.

2.2 MANUAL MOTOR STARTERS

- .1 Single and three phase manual motor starters of size, type, rating, and enclosure type as indicated, with components as follows:
 - .1 Switching mechanism, quick make and break.
 - .2 One or Three overload heaters, manual reset, trip indicating handle.
- .2 Accessories:
 - .1 Toggle switch: heavy duty labelled as indicated.
 - .2 Indicating light: standard type and colour as indicated.
 - .3 Locking tab to permit padlocking in "ON" or "OFF" position.

2.3 FULL VOLTAGE MAGNETIC STARTERS

- .1 Combination magnetic starters of size, type, rating and enclosure type as indicated with components as follows:
 - .1 Contactor solenoid operated, rapid action type.
 - .2 Motor overload protective device in each phase, manually reset from outside enclosure.
 - .3 Wiring and schematic diagram inside starter enclosure in visible location.
 - .4 Identify each wire and terminal for external connections, within starter, with permanent number marking identical to diagram.
 - .5 Power and control terminals.
 - .6 Combination type starters to include motor circuit interrupter with operating lever on outside of enclosure to control motor circuit interrupter, and provision for:
 - .1 Locking in "OFF" position with up to 3 padlocks.
 - .2 Independent locking of enclosure door.
 - .3 Provision for preventing switching to "ON" position while enclosure door open.
 - .7 Starters for motors rated 5HP and larger shall have single phase protection.
- .2 Accessories:
 - .1 Selector switches: standard labelled as indicated.
 - .2 Indicating lights: transformer type and color as indicated, lamp voltage: 120 V.
 - .3 4-N/O and 4-N/C spare auxiliary contacts unless otherwise indicated.

2.4 CONTROL TRANSFORMER

- .1 Single phase, dry type, control transformer with primary voltage as indicated and 120 V secondary, complete with secondary fuse, installed in with starter as indicated.
- .2 Size control transformer for control circuit load plus 20% spare capacity.

2.5 FINISHES

- .1 Apply finishes to enclosure in accordance with Section 26 05 00 - Common Work Results - Electrical.

2.6 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Magnetic starter designation label, white plate, black letters, size 3 engraved as indicated.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install starters, connect power and control as indicated.
- .2 Ensure correct fuses and overload devices elements installed.

3.2 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical and manufacturer's instructions.
- .2 Operate switches, contactors to verify correct functioning.
- .3 Perform starting and stopping sequences of contactors and relays.
- .4 Check that sequence controls, interlocking with other separate related starters, equipment, control devices, operate as indicated.

3.3 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 01 45 00 - Quality Control.

PART 2 PRODUCTS

2.1 FIXTURES

- .1 Equipment is existing to be removed, stored and re-installed in concert with ceiling removals and re-installation.

Type E17: Existing surface mounted 300mm x 1200mm 2-lamp fluorescent wrap c/w acrylic lens.

Type E36: Existing surface mounted 300mm x 1200mm 2-lamp fluorescent vapour tight.

Type E37: Existing surface mounted 1200mm 2-lamp fluorescent cube c/w acrylic lens.

Type E44: Existing surface mounted 300mm x 1200mm 2-lamp fluorescent wrap c/w acrylic lens.

Type E45: Existing recessed 600mm x 1200mm 3-lamp direct/indirect fluorescent troffer c/w centre basket lens.

Type E47: Existing recessed 600mm x 1200mm 3-lamp direct fluorescent troffer c/w acrylic lens.

Type E49: Existing surface mounted 1200mm 2-lamp fluorescent industrial strip.

PART 3 EXECUTION

3.1 REMOVALS

- .1 Disconnect, remove and store existing luminaires as indicated on floor plans for re-installation in concert with ceiling replacements.

3.2 INSTALLATION

- .1 Locate and install luminaires in original locations as indicated.

3.3 WIRING

- .1 Re-work and extend existing wiring as required to suit re-installation of fixtures.

3.4 LUMINAIRE SUPPORTS

- .1 For suspended ceiling installations support luminaires independently of ceiling support luminaires from ceiling grid in accordance with local inspection requirements.

3.5 LUMINAIRE ALIGNMENT

- .1 Align luminaires mounted in continuous rows to form straight uninterrupted line.
- .2 Align luminaires mounted individually parallel or perpendicular to building grid lines.

3.6 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END

PART 1 GENERAL

1.1 RELATED REQUIREMENTS

- .1 Division 01 – General Requirements.
- .2 Section 26 05 00 – Common Work Results – Electrical.

1.2 REFERENCE STANDARDS

- .1 CSA Group (CSA)
 - .1 CSA C22.2 No.141-10, Emergency Lighting Equipment.

1.3 SHOP DRAWINGS

- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Drawings to include electrical detail of panel, branch breaker type, quantity, ampacity and enclosure dimension.

1.4 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal and wiring materials from landfill to metal recycling facility approved by Departmental Representative.

1.5 WARRANTY

- .1 For batteries in this Section, 12 months warranty period is extended to 120 months.

PART 2 PRODUCTS

2.1 EQUIPMENT

- .1 Emergency lighting equipment: to CSA C22.2 No.141.
- .2 Supply voltage: 120V, AC.
- .3 Output voltage: 24V DC.
- .4 Operating time: 30 minutes.
- .5 Battery: sealed, maintenance free.
- .6 Charger: solid state, multi-rate, voltage/current regulated, inverse temperature compensated, short circuit protected with regulated output of plus or minus 0.01 V for plus or minus 10% input variations.

- .7 Solid state transfer circuit.
- .8 Low voltage disconnect: solid state, modular, operates at 80% battery output voltage.
- .9 Signal lights: solid state, for 'AC Power ON'.
- .10 Lamp heads: integral on unit, 345 degrees horizontal and 180 degrees vertical adjustment. Lamp type: LED.
- .11 Cabinet: suitable for direct or shelf mounting to wall and c/w knockouts for conduit. Removable or hinged front panel for easy access to batteries.
- .12 Finish: White.
- .13 Auxiliary equipment:
 - .1 Ammeter.
 - .2 Voltmeter.
 - .3 Test switch.
 - .4 Time delay relay.
 - .5 Battery disconnect device.
 - .6 AC input and DC output terminal blocks inside cabinet.
 - .7 RFI suppressors.

2.2 WIRING OF REMOTE HEADS

- .1 Conduit: type EMT 26 05 34 – Conduits, Conduit Fastenings and Conduit Fittings.
- .2 Conductors: in accordance with manufacturer's recommendations.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install unit equipment and remote mounted fixtures and direct heads.
- .2 Connect exit lights to unit equipment.

3.2 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by emergency lighting installation.

3.3 COMMISSIONING

- .1 Building Commissioning is a requirement of this project in order to comply with sections of Division 01 – General Requirements. A Commissioning Agent has been engaged and will provide all systems commissioning in conjunction with all trade contractors. The Commission Agent will provide a Commissioning Plan with commissioning start-up and test procedure sheets to be performed and completed by the various trade contractors.

END