



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet Seawater System and Pumphouse Const	
Solicitation No. - N° de l'invitation EB144-190610/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EB144-19-0610	Date 2018-07-20
GETS Reference No. - N° de référence de SEAG PW-\$PWA-104-5757	
File No. - N° de dossier PWA-8-80026 (104)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-08-02	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Nowakowski, Leanne	Buyer Id - Id de l'acheteur pwa104
Telephone No. - N° de téléphone (902) 403-7112 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

1.0 QUESTIONS

Q3: Has the Owner obtained permits for side casting or offshore disposal of material from the marine trench?

A3: PSPC has received all the environmental permits required, including agreement for a 20 year lease of the harbour bottom from Transport Canada. Please note, the sea water pipe simply sits on harbour bottom, weighted down with concrete anchors, it is not buried in a trench. Please see the drawings for clarification. (12-M-100)


Q4: Can you please provide typical cross sections for the marine trench that shows required separation of pipes and backfill?

A4: Please see answer to Q3.

Q5 Can you please provide additional cross sections of the shoreline protection to aid in take offs and show the transition from shoreline protection to backfilled trench?

A5: Please see attached sketch "538447-12-CSK-01-SHORELINE PROTECTION-ADDENDUM"

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.



Public Works and Government Services Canada
M&S ENGINEERING
exp
CANADIAN COAST GUARD COLLEGE, SYDNEY, NS
MECHANICAL & ELECTRICAL UPGRADES
PROPOSED SEAWATER PUMPHOUSE
SECTION DETAILS
R.065476.711
CSK-01
E-PM/000-C-538447