



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
Mailroom
30 Victoria street
Gatineau, Quebec, J8X 0B3

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
Mailroom
30 Victoria street
Gatineau, Quebec, J8X 0B3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
Salleducourier
30 rue Victoria
Gatineau (Québec) J8X 0B3

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
Salleducourier
30 rue Victoria
Gatineau (Québec) J8X 0B3

Title: Rehabilitation and development of the Information and Discovery Centre, Forillon National Park		
Solicitation No.: / N° de l'invitation : 5P201-18-0090/A	Amendment No.: / N° de modification de l'invitation : 007	Date: July 20, 2018 Date : 20 juillet 2018
GETS Reference No.: / N° de référence de SEAG : PW-18-00832432		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: August 14, 2018	Time Zone: Eastern Daylight Time (EDT)
À : 14h00	Le : 14 août 2018	Fuseau horaire : Heure avancée de l'est (HAE)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : 819-420-9868	Fax No.: / N° de télécopieur :	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 007

This amendment is being raised to post specifications addendums and respond to questions submitted in response to solicitation 5P201-18-0090/A.

A. QUESTIONS AND ANSWERS

- Q29. In specification section 0746 23, article 2.1.1 mentions three colours for the same products, but there are no notes in the plans regarding how to set up the different colours.
- A29. Article 2.1.1.7 mentions «voir 3.5.17 pour la pose». Article 3.5.17 gives instructions for the installation of the 3 colors, the installation pattern shall be random and as such is not illustrated on the drawings.
- Q30. In specification section 0746 13, article 2.1.1 mentions a Prestige profile, Graphite MXL #9822, cal. 24 on special order; do you want it in 16 to 20 in?
- A30. We knew that this specific combination of profile and color would require a special order using limited length steel sheets, please use the longest available sheet lengths.
- Q31. In specification section 09 51 13, suspended ceiling panels, article 2.1.3, type 2: Can you clarify which room, which is not mentioned in the plans for this type of product?
- A31. An answer has already been given concerning this question. Type 2 acoustic panels are linked to Note G on the reflected ceiling plan, by way of detail 10 / A808.
- Q32. If, in section 09 51 13, there are black acoustic panels, model 1729, would specification section 09 5300 include a black Prelude XL grid for acoustic ceilings?
- A32. Type 2 acoustic panels are used WHITOUT grid, they are simply laid over a custom MDF ceiling. The only grid to provide is white and is to be used with Type 1 acoustic panels.
- Q33. Specification section 0746 13, article 2.1.2, colour A: I would like clarification on how this should be interpreted. Is this for the corrugated metal cladding, or for the trim around the Prestige cladding, or something else?
- A33. Article 2.1.2 of specifications section 07 46 13 only applies to the metal cladding itself (corrugated), please refer to section 07 62 00 for flashing colors and section 07 61 13 for the color of the Prestige metal roofing.
- Q34. In section 13 34 23, prefabricated containers, would it be possible to use standard-size container dimensions for a 40', insulated and finished with gypsum and white trim to avoid damaging the product during transport? I also believe that the brackets will not be sufficiently solid to receive the decorative structure. If we are using non-standard dimensions, there will be delivery delays of 3 to 4 months.
- A34. The container's dimensions shall be as confirmed by Addendum A03 (to come), 8' x 8' x 20'. The containers will not be heated in winter and as such gypsum boards are not acceptable as the interior finish. For the bracket's dimensions, an answer has already been provided, the dimensions can exceed those given on the drawings in order to resist anticipated structural loads.
- Q35. In specification section 10 15 20 for the fitting room rails: we would like to check the placement of these items. We cannot find them in the architecture plans.
- A35. See details 4 and 5, sheet A807.
- Q36. The civil plans indicate three types of pavement structures:
- Note 1 = approximately 90m² (70 mm ESG-14)
 - Note 2 = approximately 1650 m² (70 mm ESG-14)
 - Note 3 = approximately 65 m² (50 mm ESG-10)



The slip indicates:

Pavement structure 1: 105 m²

Pavement structure 2: 1650m²

Does structure 1 on the slip correspond to 50 mm ESG-10?

A36. The structure described at note 3 (ESG-10) was removed in addendum C-01.

B. SPECIFICATION REVISION

See folder DSP 6 – 5P201-18-0090 for an addendum to the architectural specifications.

All other terms and conditions remain the same.