



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
PWGSC/TPSGC Acquisitions Bid
Receiving/Réception des Soumissions
126 Prince William Street/
126, rue Prince William
Saint John
New Brunswick
E2L 2B6
Bid Fax: (506) 636-4376

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada-Bid
Receiving / Réception des soumissions
126 Prince William Street/
126, rue Prince William
Saint John
New Bruns
E2L 2B6

Title - Sujet Amphitheater Replacement	
Solicitation No. - N° de l'invitation EC015-190461/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client EC015-190461	Date 2018-07-24
GETS Reference No. - N° de référence de SEAG PW-\$PWB-101-4325	
File No. - N° de dossier PWB-8-41017 (101)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-07-26	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lomax (PWB), Sandra	Buyer Id - Id de l'acheteur pwb101
Telephone No. - N° de téléphone (506) 639-8503 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EC015-190461/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
PWJ005

Client Ref. No. - N° de réf. du client
R.075952.001

File No. - N° du dossier
PWC-8-41017

CCC No./N° CCC - FMS No./N° VME

This Solicitation Amendment No. three (3) is raised to include the following Addendum No. three (3).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Questions and Answers

- Q1. In Section 01 50 00 Item #1.4.2 it asks for a 1800mm high site fence enclosure with truck gates. Is this required?
- A1. This is not required, however, a construction fence/barrier will need to be installed at the following locations to prevent public access to the site:
1. The top of the stairs/upper entrance to the tiered seating area to prevent access from The Cannontown Campground and Day Use area
 2. The trail entrances at McLarens Pond
- The Contractor will be responsible for site safety and security.
- Q2. In Section 01 50 00 Item #1.12.2 asks for a wooden sign to be erected by the Contractor for Parks to place a vinyl sign on. Is this needed?
- A2. This is not required, however, a construction sign is to be installed at the following areas to prevent public access to the site:
1. The top of the stairs/upper entrance to the tiered seating area to prevent from the Cannontown Campground and Day Use area.
 2. The trail entrances at McLarens Pond
 3. The entrance to the site at the Point Wolfe Road.
- Q3. In Section 05 50 00 Item #2.2.5 indicates there is animal control netting. I cannot find this mentioned anywhere on the architectural drawings. Can you advise what rooms or locations this is required?
- A3. Animal control netting is indicated to be located on the vertical perimeter of the deck in Section 05 50 00. Please also refer to detail 2/A6 which indicates stainless steel animal control netting and detail 6/A7 which indicates stainless steel animal screen. Screen should be revised to say control netting. Animal control netting is to be located around the entire outer perimeter of the building and deck.
- Q4. Is the entire floor to be 25mm x 140mm deck boards through the entire theatre?
- A4. Yes

Solicitation No. - N° de l'invitation
EC015-190461/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
PWJ005

Client Ref. No. - N° de réf. du client
R.075952.001

File No. - N° du dossier
PWC-8-41017

CCC No./N° CCC - FMS No./N° VME

Q5. Can you please confirm that the existing band shelter is being removed by others? There is mention in the environmental report that it has lead paint and creosote timber deck frame and appears the demo is by this contract however on A1 it identifies its being removed by others. Please advise.

A5. The existing amphitheatre will be demolished by Parks staff the week of September 4th. Then construction can start September 10th as indicated in the solicitation docs.

Q6. On wall type 1 (A2) it indicates a "25mm double lock standing seam siding". There is no information in the specification for this, only the standing seam roof. Can you please advise on some details for this.

A6. The 25mm double lock standing seam siding and the 25mm double lock standing seam roofing are to be the same material. Rename Section 07 42 43.01 Metal Panel Roofing System to be Metal Panel Siding and Roofing System.

Q7. In reference to Section 07 46 23 – Wood Siding: item 2.1.1.1 specifies the T&G siding to be nominal 25.4mm x 127mm high. This is essentially a 1x5 board, which I don't believe is actually produced. The drawings however indicate a 1x6 T&G board (actual dimensions shown on drawing 19mm x 140mm). We will price using 1x6 T&G boards.

A7. This is acceptable.