

Solicitation No. – N° de l’invitaion
EA003-190876/A

Amd. No. - N° de la modif.
001

Buyer ID – Id de l’acheteur
PWD-005

Client ref. No. - N° de ref. du client
R.089926.001

File No. N° du dossier
PWD-8-41064

CCC No./N° CCC – FMS No/N° VME

ADDENDUM NO. 1

**THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE
ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS.**

SPECIFICATION:

1. The following is issued for clarification, anywhere in the specification where galvanizing is stated to be to CSA G164 shall be replaced with galvanizing to be done in accordance with ASTM 123.
2. Refer to specification section 31 37 10 – Rip-rap. Remove clause 3.1.2 in its entirety and replace with clause 3.1.2, Place rip-rap on slopes as indicated.

DRAWINGS:

1. Refer to detail 3 on MA3, replace with attached SK1 detail indicating dimensions.
2. Refer to detail 4 on MA3, replace dimensions as per detail SK1 attached.
3. Refer to detail 1 on MA4, add additional cross-ties to support deck as per attached SK2 detail.
4. Refer to detail 4 on MA 8, revise note 3 to read “8-12.7mm dia. lag screws by 45mm long.

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Bid Amount.
