



# TENDER AMENDMENT

## RETURN BIDS TO:

Parks Canada Agency  
Mailroom  
30 Victoria street  
Gatineau, Quebec, J8X 0B3

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

## Issuing Office:

Parks Canada Agency  
Mailroom  
30 Victoria street  
Gatineau, Quebec, J8X 0B3

# MODIFICATION D'APPEL D'OFFRES

## RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada  
Salleducourier  
30 rue Victoria  
Gatineau (Québec) J8X 0B3

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

## Bureau de distribution :

Agence Parcs Canada  
Salleducourier  
30 rue Victoria  
Gatineau (Québec) J8X 0B3

<b>Title:</b> Rehabilitation and development of the Information and Discovery Centre, Forillon National Park		
<b>Solicitation No.: / N° de l'invitation :</b> 5P201-18-0090/A	<b>Amendment No.: / N° de modification de l'invitation :</b> 008	<b>Date:</b> July 26, 2018  <b>Date :</b> 26 juillet 2018
<b>GETS Reference No.: / N° de référence de SEAG :</b> PW-18-00832432		
<b>Solicitation Closes: / L'invitation prend fin :</b>		
<b>At:</b> 02:00 PM	<b>On:</b> August 14, 2018	<b>Time Zone:</b> Eastern Daylight Time (EDT)
<b>À :</b> 14h00	<b>Le :</b> 14 août 2018	<b>Fuseau horaire :</b> Heure avancée de l'est (HAE)
<b>Address Inquiries to: / Adresser toute demande de renseignements à :</b> Nicole Levesque-Welch		
<b>Telephone No.: / N° de téléphone :</b> 819-420-9868	<b>Fax No.: / N° de télécopieur :</b>	<b>Email Address: / Courriel :</b> <a href="mailto:nicole.levesque-welch@pc.gc.ca">nicole.levesque-welch@pc.gc.ca</a>
<b>TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)</b>		
<b>Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur</b>		
<b>Address - Adresse</b>		
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>		
<b>Title - Titre</b>		
<b>Signature</b>		<b>Date</b>




**AMENDMENT 008**

This amendment is being raised to respond to questions submitted in response to solicitation 5P201-18-0090/A.

**A. QUESTIONS AND ANSWERS**

- Q37. Équiparc has decided not to bid on this project. We are currently seeking some kind of equivalence for these trash cans. We will get back to you with the suggested product in due course.
- A37. Ok
- Q38. In terms of plans and specifications, no model has been specified for urban furniture. Do you want specific models, or custom-made ones? Product specifications, please.
- A38. It's a customized product.
- Q39. I am attaching a document for information, since architecture plans A-251, General Note L state: New soffit in 19x64mm wood plank. This product is not listed among Juste Pins products... Do you have further specifications on this item.
- A39. According to our information, Juste du Pin can provide rectangular wood planks with custom dimensions (such as the soffit specified in Note F) even though it is not explicitly shown in their brochure.
- Q40. With regard to the wood to be used for furniture, the architect states that he wants red cedar, but he does not specify whether knotty or select. This could almost double the price.
- A40. Select, see specifications 323700 2.4.1.1
- Q41. I would like to have more information on the dimensions of the window. There is a space between the walls of 2,159mm, and you are asking for a window of 2,535mm ...?



- A41. We do not specify a 2535mm wide window, the exterior dimension given is ±1537mm, which corresponds with the existing opening's dimension

**Architecture**

- Q42. The angle brackets for the canopy must be bigger (I am told that they will not be strong enough). (For the booth)
- A42. We published an addendum which oversized the brackets. If this is still not strong enough, the sub-contractor can use even bigger brackets according to expected loads.



## Structure

- Q43. The structure section of the specifications (05 12 13) seems to be missing from the tender documents. It appears, though, in the list of documents on page 7 of 1,090 in the "DEVIS\_SOUMISSION\_2018-06-22" pdf file.
- A43. The section number in the table of content is wrong. The right number is 05 12 23. The section 05 12 23 is at page 681 of 1090 of the PDF file.

***All other terms and conditions remain the same.***