



**IMPORTANT NOTICE TO BIDDERS**

Parks Canada will be relocating its office on July 26, 2018. The Bid Receiving Unit will be closed from July 27, 2018 until July 29, 2018 inclusive. No bids will be accepted during the period of this closure including bids submitted by facsimile. It is the Bidder's responsibility to ensure that its bid is delivered on time to the appropriate address as identified below.

**RETURN BIDS TO:**

**BEFORE JULY 26, 2018**

Parks Canada Agency Bid Receiving Unit  
National Contracting Services  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3

**AFTER JULY 29, 2018**

Parks Canada Agency Bid Receiving Unit  
National Contracting Services  
220 - 4 Avenue S.E., suite 720  
Calgary, AB T2G 4X3

**AMENDMENT / MODIFICATION 002**

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Issuing Office - Bureau de distribution

**Parks Canada Agency**

**Suite 1300**

**635 – 8 Ave SW**

**Calgary, AB T2P3M3**

<b>Title-Sujet</b> Peyto Lake Day Use Area Rehabilitation – Banff National Park		
<b>Solicitation No. - No. de l'invitation</b> 5P420-18-0100/A	<b>Date:</b> July 26, 2018	
<b>GETS Reference No. – No de reference de SEAG</b> PW-18-00831913	<b>Amendment No. - N° de la modif.</b> 2	
<b>Solicitation Closes:</b>		
<b>at – à</b> 02:00 PM	<b>on – le</b> August 8, 2018	<b>Time Zone - Fuseau horaire</b> MDT - HAR
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/>	<b>Destination:</b> <input checked="" type="checkbox"/>	<b>Other-Autre:</b> <input type="checkbox"/>
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Rebecca Chen		
<b>Telephone No. - No de téléphone</b> (403) 292-8509	<b>Fax No. – No de FAX:</b> 1-866-246-6893	
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b> See Herein – Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Title - Titre</b>	
<b>Telephone No. - N° de telephone:</b>	_____
<b>Facsimile No. - N° de télécopieur:</b>	_____
<b>Signature</b>	<b>Date</b>

## **IMPORTANT NOTICE TO BIDDERS**

**Parks Canada will be relocating its office on July 26, 2018 to:**

**Parks Canada Agency Bid Receiving Unit  
National Contracting Services  
220 - 4 Avenue S.E., suite 720  
Calgary, AB T2G 4X3**

**The Bid Receiving Unit will be closed from July 27, 2018 until July 29, 2018 inclusive.**

**No bids will be accepted during the period of this closure including bids submitted by facsimile.**

**It is the Bidder's responsibility to ensure that its bid is delivered on time to the appropriate address as identified on the cover page.**

This amendment is being raised to make changes to the tender package and to distribute question and answers.

## A) TENDER PACKAGE REVISIONS

**ADD:** DSP2\_18-0100: Viewpoint Details

**DELETE:** 2.3 Project Schedule

### REPLACE WITH:

2.3 Project Schedule

2.3.1 Planning and design schedule shall meet these milestone dates:

- .1 September 10, 2018 - Complete pre-design report.
- .2 October 1, 2018 - Complete Schematic Design Report - Concept Plans & Story Boards for Park Management approval.
- .3 TBD - Attend key community stakeholder meetings and present Concept Plans and design rationale.
- .5 November 19, 2018 - Complete design development report of preferred option.
- .6 December 10, 2018 - 33% design review.
- .7 January 7, 2019 - 66% design review.
- .9 January 28, 2019 - 99% design review.
- .10 February 11, 2019 - 100% (Final) Drawings and Specifications ready for Tender.
- .11 February 18, 2019 - Construction public tender call/bid evaluation.
- .12 March 18, 2019 - Contract award.

## B) QUESTIONS AND ANSWERS

**Q1** Please confirm Appendix E (Project Brief) item **2.3 Project Schedule** – appears work is due before solicitation closes?

**A1** See tender package revisions above.

**Q2** Please confirm and describe specific requirements outlined in Appendix E (Project Brief) item 3.2.2.6 Language Adaptation. Language adaptation applies to which deliverables specifically?

**R2** Language adaptation applies to all deliverables that would be viewed at Peyto Lake by public / tourists, such as signage and maps.

**Q3** Please confirm; Appendix E (Project Brief) items **3.2.2.4 and 3.2.2.5** are missing?

**R3** Administrative error. Omit items 3.2.2.4 and 3.2.2.5.

**Q4** Site Closure. Would Parks be able to close the Peyto Lake site to public in order to complete the land survey and geotechnical investigation for the pre-design report? Is there a planned date for this?

**A4** No, the site will need to remain open. It is suggested that this work be completed early in the morning when visitor traffic is at its lowest.

**Q5** Viewpoint Scope. Is Parks looking to expand the viewpoint structure? We believe it will be challenging for a geotechnical investigation to be done in this location, will we be expected to complete a new investigation in this area? Is there as-builds available for the structure? Are there existing geotechnical

reports that could be used for design if the structure needs to be expanded or if a new structure needs to be built?

**A5** There is a design drawing available but no as built for the viewpoint structure, see DSP 2\_18-0100. Parks is looking to expand the viewpoint structure as well as address safety concerns for visitors. A new geotechnical investigation must be completed as there are no existing geotechnical reports available.

**All other terms and conditions remain unchanged.**