



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet Seawater System and Pumphouse Const	
Solicitation No. - N° de l'invitation EB144-190610/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client EB144-19-0610	Date 2018-07-27
GETS Reference No. - N° de référence de SEAG PW-\$PWA-104-5757	
File No. - N° de dossier PWA-8-80026 (104)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-08-09	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Nowakowski, Leanne	Buyer Id - Id de l'acheteur pwa104
Telephone No. - N° de téléphone (902) 403-7112 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation Amendment 003 is being issued to provide additional questions and answers, a revision to the Invitation to Tender, as well as an extension to the closing date.

Please note that another amendment with the remaining questions and answers is expected to be posted in a few days.

Questions and Answers:

- 6) Ref Drawing 12-M-100 "SITE PLAN & DETAILS" – can you provide a cross section detail or clarify the underwater pipe bedding and backfill? The specification sect 33 65 16 PIPING-HDPE, Page 4, PART 3 EXECUTION, 3.1.3 INSTALLATION "Install buried pipe on 150mm bed of clean washed sand. Backfill with 150mm of clean washed sand"

What does this look like where you are backfilling with 150mm of sand and pipe is 300mm dia = ~halfway up the pipe? Is this correct - Please clarify.

- a. The pipe installed in the harbour does not require bedding and backfill. See details on drawings 12-M-100. The specification section noted applies only to the pipe installed in the dry, where it transitions from below LNT to above 0.00 elevation on dry land, where it will connect to the new Pump House.

- 7) Drawing 12-A-100 Pumphouse Plan, Elevations – Insulated mandoor note "Hardware, closure and lockset – Refer to specification". Specification Section 08 11 13 METAL DOORS and FRAMES does not specify hardware – please clarify.

a. :

1 HINGE CONTINUOUS	MCKINNEY MCK12HD x door height	628
1 LOCKSET	SARGENT 8251 LNL rigid pull	630
1 DOOR CLOSER	SARGENT 351 P3 EN	
1 OVERHEAD STOP	RIXSON 8 HD STOP TO SUIT	626
(restrict closer to 110 degrees)		
1 KICK PLATE	Std Metal K10A 8" X DOOR WIDTH LESS 2"	628
1 Threshold therm. broken 1/2"		KN
CROWDER CT48 with lip x door width		AL
1 DOOR BOTTOMS	KN CROWDER W13 X DOOR WIDTH	AL
1 WEATHERSTRIP	KN CROWDER W14 X HEAD AND JAMBS	AL

- 8) Is the HXWS & HXWR piping from Cabot to the exchanger in the pump house filled with a glycol mixture (if so need water/glycol percentage) or is this not in the contract?

- a. The glycol for the HXWS and HXWR piping from Cabot to the pump house is not in this contract.

9) The ability to submit revisions to a bid via facsimile has been requested.

- a. Revisions will be accepted via facsimile. Please see the following amendment to the Invitation to Tender:

At: SI06 Revision of Bid:

Delete: in its entirety;

Insert: "A bid may be revised by letter or facsimile in accordance with GI10 of R2710T.
The facsimile number for receipt of revisions is (902) 496-5016."