



Fisheries and Oceans
Canada

Pêches et Océans
Canada

Procurement Hub – Ottawa Office,
Station 9E249, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

ADDENDUM NO. 1

Subject: **ITT Invitation to Tender No. FP802-180038
Trailer Improvements**

Dear Sir/Madam:

Further to the above-mentioned Request for Proposal, this Addendum (#1) is to advise potential bidders of the question(s) received during this tender call to date. Both the question(s) and the response(s) are indicated in the attached Annex A

All other terms and conditions remain unchanged.

Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.

Yours truly,

(Original signed by)

Beverly Shawana
Senior Contracting Officer,
Financial & Materials Management Operations

RECEIPT ACKNOWLEDGED

Name of Company

Signature _____

Canada

Annex A

Question:

Please advise the distance of the existing water main from trailer to water main. This is shown on the electrical and mechanical drawings note #3 on electrical and note #10 on mechanical.

Answer:

25 meters