

RÉPONSE AUX QUESTIONS

QUESTION 002 - DEMANDE D'ÉQUIVALENCE :

Il est demandé l'analyse du produit PENTREAT 244-40 comme substitut pour le SIKAGARD SN40.

Currently, below spec from above mentioned project documents call for SIKAGARD SN40.

Fisheries and Oceans Canada		Section 03 25 00
Sorel Base	Concrete Accessories	Page 4
Project: R. 3380-9L275		

- .17 Sealer for concrete surfaces: Silane based sealer such as **Sikagard SN40** from Sika Canada or approved equivalent.

We would like to request that our PENTREAT 244-40 please be reviewed for alternate acceptance. Attached are the relevant documents to assist and if you could please let me know if acceptable, it would be greatly appreciated.

REPONSE À LA QUESTION 002 – PAR STRUCTURE:

Le scellant Pentreat 244-40 de W.R Meadows possède les performances et caractéristiques équivalentes au scellant Sikagard SN40 de Sika mentionné au devis. La demande d'équivalence est approuvée par Stantec.

FIN DES QUESTIONS